

**Bangladesh Power Development Board**  
**DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation  
Tel : 3564667, 3551095

| Month June, 2023                       |                                                |                              |                         |                                | Day : Saturday                         |         |                               |         | Date : 03.06.23               |         |                                                   |         |                                                 |  |                      |                        |
|----------------------------------------|------------------------------------------------|------------------------------|-------------------------|--------------------------------|----------------------------------------|---------|-------------------------------|---------|-------------------------------|---------|---------------------------------------------------|---------|-------------------------------------------------|--|----------------------|------------------------|
| Probable Maximum Demand : 15500 MW     |                                                |                              |                         |                                | Probable Maximum Generation : 14567 MW |         |                               |         |                               |         |                                                   |         |                                                 |  |                      |                        |
| Water Level of Kaptai Lake at 06:00 AM |                                                |                              |                         |                                | Yesterday = 72.64 ft                   |         | Today = 72.58 ft              |         | Rule Curve = 76.52 ft         |         |                                                   |         |                                                 |  |                      |                        |
| Sl. No.                                | Name of Power Station                          | Nos. of Unit X Capacity (MW) | Installed Capacity (MW) | Derated/ Present Capacity (MW) | 02.06.23 (Yesterday)                   |         | 03.06.23 (Today)              |         | 02.06.23 (Yesterday)          |         | 02.06.23 (Yesterday)                              |         | Status of Machines under shut-down/ Maintenance |  |                      |                        |
|                                        |                                                |                              |                         |                                | Actual Peak Generation (MW)            |         | Probable Peak Generation (MW) |         | Probable Peak Generation (MW) |         | Gen. shortfall for : Gas/Coal/Water Limitation MW |         | Machines shut down (MW)                         |  | Description/ Remarks | Probable start-up date |
|                                        |                                                |                              |                         |                                | Day                                    | Evening | Day                           | Evening | Day                           | Evening | Day                                               | Evening |                                                 |  |                      |                        |
| (A) Plants in operation:               |                                                |                              |                         |                                |                                        |         |                               |         |                               |         |                                                   |         |                                                 |  |                      |                        |
| 1                                      | Ghorasal Repowered CCPP Unit-3 (GT)            | Gas (PDB)                    | 1 x 260                 | 260                            | 260                                    | 0       | 0                             | 0       | 0                             |         |                                                   | 260     | Under project work                              |  |                      |                        |
| 2                                      | a) Ghorasal Repowered CCPP Unit-4              | Gas (PDB)                    | 1 x 210                 | 210                            | 180                                    | 130     | 130                           | 130     | 130                           |         |                                                   |         |                                                 |  |                      |                        |
|                                        | b) Ghorasal TPP Unit-5                         | Gas (PDB)                    | 1 x 210                 | 210                            | 190                                    | 180     | 180                           | 180     | 180                           |         |                                                   |         |                                                 |  |                      |                        |
| 3                                      | Ghorasal 365 MW CCPP Unit-7                    | Gas (PDB)                    | 1x 254+1x 126           | 365                            | 365                                    | 0       | 0                             | 0       | 0                             |         |                                                   |         |                                                 |  |                      |                        |
| 4                                      | Ghorashal 108MW PP (Regent)                    | Gas (IPP)                    | 34x3.35                 | 108                            | 108                                    | 42      | 75                            | 78      | 78                            | 33      |                                                   |         | Gas Shortage                                    |  |                      |                        |
| 5                                      | Tongi 80 MW GTPP                               | Gas (PDB)                    | 1 x 105                 | 105                            | 105                                    | 60      | 60                            | 60      | 60                            | 45      |                                                   |         | Gas Shortage                                    |  |                      |                        |
| 6                                      | Haripur GTPP                                   | Gas (PDB)                    | 1 x 32                  | 32                             | 20                                     | 0       | 0                             | 0       | 0                             |         |                                                   |         |                                                 |  |                      |                        |
| 7                                      | Haripur 360MW CCPP(HPL)                        | Gas (IPP)                    | 1x235+1x125             | 360                            | 360                                    | 332     | 332                           | 330     | 330                           |         |                                                   |         |                                                 |  |                      |                        |
| 8                                      | Meghnaghat 450 MW CCPP(MPL)                    | Gas (IPP)                    | 2x140+1x170             | 450                            | 450                                    | 450     | 450                           | 450     | 450                           |         |                                                   |         |                                                 |  |                      |                        |
| 9                                      | 210 MW Siddhirgonj TPP                         | Gas (PDB)                    | 1 x 210                 | 210                            | 115                                    | 0       | 0                             | 0       | 0                             |         |                                                   | 115     | Under Overhauling                               |  |                      |                        |
| 10                                     | Haripur 412 MW CCPP                            | Gas (EGCB)                   | 1x273+1x139             | 412                            | 412                                    | 398     | 398                           | 400     | 400                           |         |                                                   |         |                                                 |  |                      |                        |
| 11                                     | Siddhirgonj 2*120 MW GTPP                      | Gas (EGCB)                   | 2 x 105                 | 210                            | 210                                    | 187     | 194                           | 190     | 195                           |         |                                                   |         |                                                 |  |                      |                        |
| 12                                     | Siddhirgonj 335 MW CCPP                        | Gas (EGCB)                   | 1 x 217+1x118           | 335                            | 335                                    | 0       | 0                             | 0       | 0                             | 335     |                                                   |         | Gas Shortage                                    |  |                      |                        |
| 13                                     | Meghnaghat CCPP(Summit)                        | Gas (IPP)                    | 2x110+1x110             | 335                            | 335                                    | 293     | 279                           | 300     | 300                           |         |                                                   |         |                                                 |  |                      |                        |
| 14                                     | Madanganj-55 MW PP (Summit)                    | HFO (IPP)                    | 5x17.06+1x11.3          | 55                             | 55                                     | 0       | 30                            | 0       | 30                            |         |                                                   |         |                                                 |  |                      |                        |
| 15                                     | Gagnagar 102 MW PP (Digital Power)             | HFO (IPP)                    | 12x8.924                | 102                            | 102                                    | 8       | 16                            | 8       | 16                            |         |                                                   |         |                                                 |  |                      |                        |
| 16                                     | Narsingdi 22 MW PP (Doreen)                    | Gas (SIPP, REB)              | 8x2.90                  | 22                             | 22                                     | 15      | 22                            | 22      | 22                            |         |                                                   |         |                                                 |  |                      |                        |
| 17                                     | Summit Power(Madhabdi+Ashulia)                 | Gas (SIPP, REB)              | 6x3.67+7x8.73           | 80                             | 80                                     | 36      | 45                            | 42      | 45                            |         |                                                   |         |                                                 |  |                      |                        |
| 18                                     | Maona 33 MW PP (Summit)                        | Gas (SIPP, REB)              | 4x8.73                  | 33                             | 33                                     | 33      | 33                            | 33      | 33                            |         |                                                   |         |                                                 |  |                      |                        |
| 19                                     | Rupganj 33 MW PP (Summit)                      | Gas (SIPP, REB)              | 4x8.73                  | 33                             | 33                                     | 25      | 22                            | 33      | 33                            |         |                                                   |         |                                                 |  |                      |                        |
| 20                                     | Gazipur 52 MW PP                               | HFO (RPCL)                   | 6x8.90                  | 52                             | 52                                     | 8       | 48                            | 8       | 50                            |         |                                                   |         |                                                 |  |                      |                        |
| 21                                     | Gazipur 100 MW PP                              | HFO (RPCL)                   | 6x18.415                | 105                            | 105                                    | 86      | 86                            | 88      | 88                            |         |                                                   |         |                                                 |  |                      |                        |
| 22                                     | Kodda 150MW PP                                 | HFO (BRPgen)                 | 9x17.06                 | 149                            | 149                                    | 64      | 150                           | 64      | 150                           |         |                                                   |         |                                                 |  |                      |                        |
| 23                                     | Kamalaghat 54 MW PP (Banco Energy)             | HFO (IPP)                    | 3x18.69                 | 54                             | 54                                     | 0       | 17                            | 0       | 17                            |         |                                                   |         |                                                 |  |                      |                        |
| 24                                     | Kodda 300 MW PP Unit-2 (Summit)                | HFO (IPP)                    | 18x17.076               | 300                            | 300                                    | 47      | 145                           | 47      | 145                           |         |                                                   |         |                                                 |  |                      |                        |
| 25                                     | Kodda 149 MW PP Unit-1 (Summit)                | HFO (IPP)                    | 8x18.415+1x8.97         | 149                            | 149                                    | 17      | 131                           | 17      | 149                           |         |                                                   |         |                                                 |  |                      |                        |
| 26                                     | Keraniganj 300 MW PP (APR)                     | HSD (IPP)                    | 25x11.4                 | 300                            | 300                                    | 12      | 233                           | 300     | 300                           |         |                                                   |         |                                                 |  |                      |                        |
| 27                                     | Bramhanaganj 100 MW PP (Aggreko)               | HSD (IPP)                    | 23x0.85+91x.959         | 100                            | 100                                    | 0       | 0                             | 0       | 0                             |         |                                                   |         |                                                 |  |                      |                        |
| 28                                     | Aurahat 100MW PP (Aggreko)                     | HSD (IPP)                    | 23x0.85+91x.959         | 100                            | 100                                    | 85      | 97                            | 100     | 100                           |         |                                                   |         |                                                 |  |                      |                        |
| 29                                     | Nababganj 55 MW PP (Southern power )           | HFO (IPP)                    | 3x19.3                  | 55                             | 55                                     | 35      | 55                            | 35      | 55                            |         |                                                   |         |                                                 |  |                      |                        |
| 30                                     | Manikganj 55 MW PP (Northern)                  | HFO (IPP)                    | 3x19.3                  | 55                             | 55                                     | 35      | 55                            | 35      | 55                            |         |                                                   |         |                                                 |  |                      |                        |
| 31                                     | Meghnaghat 104 MW PP (OPSL)                    | HFO (IPP)                    | 6x18.5                  | 104                            | 104                                    | 17      | 17                            | 17      | 17                            |         |                                                   |         |                                                 |  |                      |                        |
| 32                                     | Manikganj 162MW PP(MPGL)                       | HFO (IPP)                    | 9x18                    | 162                            | 162                                    | 17      | 54                            | 18      | 54                            |         |                                                   |         |                                                 |  |                      |                        |
| 33                                     | Manikgonj 35MW Solar PP (Inspectra Solar Ltd.) | Solar (IPP)                  | 1x35                    | 35                             | 35                                     | 31      | 0                             | 30      | 0                             |         |                                                   |         |                                                 |  |                      |                        |
| 34                                     | Kanchan Purbachal Power Generation Ltd.        | HFO (IPP)                    | 3x19.404                | 55                             | 55                                     | 17      | 34                            | 17      | 35                            |         |                                                   |         |                                                 |  |                      |                        |
| 35                                     | Siddhirganj 100 MW PP(Dutch Bangla)            | HFO (NENP)                   | 12x8.9                  | 100                            | 100                                    | 17      | 26                            | 16      | 32                            |         |                                                   |         |                                                 |  |                      |                        |
| 36                                     | Meghnaghat 100 MW(IEI)                         | HFO (NENP)                   | 12x8.9                  | 100                            | 100                                    | 9       | 21                            | 8       | 25                            |         |                                                   |         |                                                 |  |                      |                        |
| 37                                     | Madanganj 102 PP(Summit)                       | HFO (NENP)                   | 6x17                    | 102                            | 102                                    | 53      | 80                            | 80      | 80                            |         |                                                   |         |                                                 |  |                      |                        |
| 38                                     | Keraniganj 100 MW PP (Powerpac)                | HFO (NENP)                   | 8x13.45                 | 100                            | 20                                     | 0       | 0                             | 0       | 0                             |         |                                                   |         |                                                 |  |                      |                        |
| Dhaka Zone Total                       |                                                |                              |                         |                                | 6104                                   | 5867    | 2739                          | 3515    | 3136                          | 3654    | 413                                               | 375     |                                                 |  |                      |                        |
| 39                                     | Karnaphuli Hydro PP Unit-1,2,3,4, 5            | Hydro (PDB)                  | 2x40, 3x50              | 230                            | 230                                    | 25      | 25                            | 25      | 25                            | 205     |                                                   |         | Low water level                                 |  |                      |                        |
| 40                                     | a) Chattogram TPP-1                            | Gas (PDB)                    | 1 x 210                 | 210                            | 180                                    | 100     | 100                           | 100     | 100                           | 80      |                                                   |         | Gas Shortage                                    |  |                      |                        |
|                                        | b) Chattogram TPP-2                            | Gas (PDB)                    | 1 x 210                 | 210                            | 180                                    | 0       | 0                             | 0       | 0                             |         |                                                   | 180     | Under maint.                                    |  |                      |                        |
| 41                                     | Kaptai 7 MW Solar PP                           | Solar (PDB)                  | 7                       | 7                              | 7                                      | 2       | 0                             | 5       | 0                             |         |                                                   |         |                                                 |  |                      |                        |
| 42                                     | Raczen 25 MW PP                                | HFO (RPCL)                   | 3x8.9                   | 25                             | 25                                     | 8       | 25                            | 8       | 25                            |         |                                                   |         |                                                 |  |                      |                        |
| 43                                     | Teknaf 20MW PP (Solartech)                     | Solar (IPP)                  | 1x20                    | 20                             | 20                                     | 19      | 0                             | 20      | 0                             |         |                                                   |         |                                                 |  |                      |                        |
| 44                                     | Patenga 50MW PP (Baraka)                       | HFO (IPP)                    | 8x6.89                  | 50                             | 50                                     | 6       | 44                            | 6       | 44                            |         |                                                   |         |                                                 |  |                      |                        |
| 45                                     | Sikalbaha 105 MW PP (Baraka Sikabaha)          | HFO (IPP)                    | 6x18.415                | 105                            | 105                                    | 17      | 51                            | 17      | 51                            |         |                                                   |         |                                                 |  |                      |                        |
| 46                                     | Shikalbaha Peaking GT                          | Gas (PDB)                    | 1 x 150                 | 150                            | 150                                    | 0       | 0                             | 0       | 0                             |         |                                                   | 150     | Under maint.                                    |  |                      |                        |
| 47                                     | Sikalbaha 225 MW CAPP                          | Gas (PDB)                    | 1 x 150+1 x 75          | 225                            | 225                                    | 216     | 224                           | 225     | 225                           |         |                                                   |         |                                                 |  |                      |                        |
| 48                                     | Anwara 300 MW PP (United)                      | HFO (IPP)                    | 17x17.076+3x8.04        | 300                            | 300                                    | 69      | 300                           | 69      | 300                           |         |                                                   |         |                                                 |  |                      |                        |
| 49                                     | Juldah 100 MW PP Unit-3 (Acom)                 | HFO (IPP)                    | 8x13.45                 | 100                            | 100                                    | 38      | 90                            | 38      | 90                            |         |                                                   |         |                                                 |  |                      |                        |
| 50                                     | Dohazari -Kalaish 100 MW Peaking               | HFO (PDB)                    | 6x17.0                  | 102                            | 102                                    | 50      | 68                            | 51      | 68                            |         |                                                   |         |                                                 |  |                      |                        |
| 51                                     | Hathazari 100 MW peaking PP                    | HFO (PDB)                    | 11x8.9                  | 98                             | 98                                     | 30      | 60                            | 50      | 64                            |         |                                                   |         |                                                 |  |                      |                        |
| 52                                     | Barabkunda 22 MW PP (Regent)                   | Gas (SIPP, PDB)              | 8x2.90                  | 22                             | 22                                     | 7       | 9                             | 10      | 10                            |         |                                                   |         |                                                 |  |                      |                        |
| *                                      | Malancha, Ctg.EPZ (United)                     | Gas                          | 5x8.73+3x9.34           |                                |                                        | 17      | 42                            | 10      | 30                            |         |                                                   |         |                                                 |  |                      |                        |
| 53                                     | Chattogram 108 MW PP (ECPV)                    | HFO (IPP)                    | 16x7.00                 | 108                            | 108                                    | 0       | 0                             | 0       | 0                             |         |                                                   |         |                                                 |  |                      |                        |
| 54                                     | Sikalbaha 54 MW PP(Jodiac Power)               | HFO (IPP)                    | 3x18.55+1x3.6           | 54                             | 54                                     | 17      | 17                            | 17      | 17                            |         |                                                   |         |                                                 |  |                      |                        |
| 55                                     | Karnaphuli Power Ltd.                          | HFO (IPP)                    | 6x18.41+1x6.4           | 110                            | 110                                    | 54      | 54                            | 54      | 54                            |         |                                                   |         |                                                 |  |                      |                        |
| 56                                     | Juldah unit-2 (Acom)                           | HFO (IPP)                    | 8x13.6                  | 100                            | 100                                    | 38      | 90                            | 38      | 90                            |         |                                                   |         |                                                 |  |                      |                        |
| 57                                     | Juldah 100 MW Unit-1 (Acom)                    | HFO (QRPP)                   | 8x13.45                 | 100                            | 100                                    | 44      | 66                            | 44      | 66                            |         |                                                   |         |                                                 |  |                      |                        |
| 58                                     | Chattogram 116 MW PP (Anima Energy Ltd.)       | HFO (IPP)                    | 6x21.06                 | 116                            | 116                                    | 17      | 34                            | 17      | 34                            |         |                                                   |         |                                                 |  |                      |                        |
| 59                                     | Mirsharai 150 MW                               | HFO (BRPgen)                 | 9x18.5                  | 163                            | 163                                    | 18      | 163                           | 18      | 163                           |         |                                                   |         |                                                 |  |                      |                        |
|                                        | SS Power Unit-1                                | Coal (IPP)                   |                         |                                |                                        | 0       | 0                             | 0       | 0                             |         |                                                   |         |                                                 |  |                      |                        |
|                                        | Cox's Bazar Wind PP                            | (Wind) (IPP)                 |                         |                                |                                        | 2       | 3                             | 0       | 0                             |         |                                                   |         |                                                 |  |                      |                        |
| Chattogram Zone Total                  |                                                |                              |                         |                                | 2605                                   | 2545    | 794                           | 1465    | 822                           | 1456    | 285                                               | 330     |                                                 |  |                      |                        |
| 60                                     | Ashuganj 50 MW PP                              | Gas (APSCL)                  | 14x3.968                | 53                             | 45                                     | 35      | 41                            | 40      | 40                            |         |                                                   |         |                                                 |  |                      |                        |
| 61                                     | Ashuganj 225 MW CAPP                           | Gas (APSCL)                  | 1x142+175               | 221                            | 221                                    | 197     | 154                           | 200     | 200                           |         |                                                   |         |                                                 |  |                      |                        |
| 62                                     | Ashuganj 450 MW CAPP(South)                    | Gas (APSCL)                  | 1x360                   | 360                            | 360                                    | 280     | 270                           | 150     | 320                           |         |                                                   |         |                                                 |  |                      |                        |
| 63                                     | Ashuganj 450 MW CAPP(North)                    | Gas (APSCL)                  | 1x361                   | 360                            | 360                                    | 290     | 305                           | 310     | 320                           |         |                                                   |         |                                                 |  |                      |                        |
| 64                                     | Ashuganj 420 MW CAPP(East)                     | Gas (APSCL)                  | 1x284+1x116             | 400                            | 400                                    | 0       | 0                             | 0       | 0                             |         |                                                   | 400     | Under maint.                                    |  |                      |                        |
| 65                                     | Ashuganj 195MW PP (APSCL-United)               | Gas (IPP)                    | 20*9.73+11*6            | 195                            | 195                                    | 192     | 178                           | 190     | 185                           |         |                                                   |         |                                                 |  |                      |                        |
| 66                                     | Ashuganj 51 MW PP (Midland)                    | Gas (IPP)                    | 6x9.34                  | 51                             | 51                                     | 51      | 51                            | 51      | 51                            |         |                                                   |         |                                                 |  |                      |                        |
| 67                                     | Ashuganj 150MW PP (Midland)                    | HFO (IPP)                    | 23x7.015                | 150                            | 150                                    | 5       | 134                           | 6       | 150                           |         |                                                   |         |                                                 |  |                      |                        |
| 68                                     | Titas 50 MW Peaking PP                         | HFO (PDB)                    | 6x8.92                  | 52                             | 52                                     | 40      | 41                            | 40      | 46                            |         |                                                   |         |                                                 |  |                      |                        |
| 69                                     | Chandpur 150 MW CAPP                           | Gas (PDB)                    | 1x106+1x57              | 163                            | 163                                    | 0       | 0                             | 0       | 0                             |         |                                                   | 163     | Under overhauling                               |  |                      |                        |
| 70                                     | Chandpur 200MW (Desh energy)                   | HFO (IPP)                    | 12x18.415               | 200                            | 200                                    | 52      | 120                           | 51      | 120                           |         |                                                   |         |                                                 |  |                      |                        |
| 71                                     | Feni 22MW PP (Doreen)                          | Gas (SIPP, PDB)              | 8x2.90                  | 22                             | 22                                     | 17      | 18                            | 17      | 17                            |         |                                                   |         |                                                 |  |                      |                        |
| 72                                     | Feni 11 MW PP (Doreen)                         | Gas (SIPP, REB)              | 4x2.90                  | 11                             | 11                                     | 8       | 11                            | 11      | 11                            |         |                                                   |         |                                                 |  |                      |                        |
| 73                                     | Jangalia 33MW PP (Summit)                      | Gas (SIPP, PDB)              | 4x8.73                  | 33                             | 33                                     | 25      | 25                            | 25      | 25                            |         |                                                   |         |                                                 |  |                      |                        |
| 74                                     | Jangalia 52 MW PP (Lakdanavi)                  | HFO (IPP)                    | 6x8.92                  | 52                             | 52                                     | 0       | 0                             | 0       | 50                            |         |                                                   |         |                                                 |  |                      |                        |
| 75                                     | Cumilla 25 MW PP (Summit)                      | Gas (SIPP, REB)              | 3x3.67+2x6.97           | 25                             | 25                                     | 17      | 20                            | 21      | 21                            |         |                                                   |         |                                                 |  |                      |                        |
| 76                                     | Feni 114 MW (Lakdanavi)                        | HFO (IPP)                    | 7*18.415+1*9.78         | 114                            | 114                                    | 34      | 52                            | 52      | 98                            |         |                                                   |         |                                                 |  |                      |                        |
| 77                                     | Chowmuhani 113 MW                              | HFO (IPP)                    | 12*9.78+2*3.1           | 113                            | 113                                    | 9       | 95                            | 26      | 94                            |         |                                                   |         |                                                 |  |                      |                        |
| 78                                     | Bhairab 54 MW PP                               | HFO (IPP)                    | 3x18.2                  | 54                             | 54                                     | 34      | 35                            | 35      | 35                            |         |                                                   |         |                                                 |  |                      |                        |
| 79                                     | Chandpur 115MW PP (Doreen)                     | HFO (IPP)                    | 4x18.516+2x25.428       | 115                            | 115                                    | 34      | 97                            | 18      | 97                            |         |                                                   |         |                                                 |  |                      |                        |
| **                                     | Import (Tirupura)                              | India                        |                         | 160                            | 160                                    | 146     | 150                           | 129     | 152                           |         |                                                   |         |                                                 |  |                      |                        |
| Cumilla Zone Total                     |                                                |                              |                         |                                | 2904                                   | 2896    | 1466                          | 1797    | 1372                          | 2032    | 0                                                 | 563     |                                                 |  |                      |                        |
| 80                                     | RPCL 210MW CCPP                                | Gas (IPP)                    | 4x35+1x70               | 210                            | 202                                    | 31      | 103                           | 45      | 100                           | 99      |                                                   |         | Gas Shortage                                    |  |                      |                        |
| 81                                     | Tangail 22 MW PP (Doreen)                      | Gas (SIPP, PDB)              | 8x2.90                  | 22                             | 22                                     | 19      | 16                            | 19      | 19                            |         |                                                   |         |                                                 |  |                      |                        |
| 82                                     | Jamalpur 115 MW PP (United)                    | HFO (IPP)                    | 12x9.87                 | 115                            | 115                                    | 18      | 85                            | 18      | 84                            |         |                                                   |         |                                                 |  |                      |                        |
| 83                                     | Mymensingh 200 MW PP (United)                  | HFO (IPP)                    | 21x9.780                | 200                            | 200                                    | 67      | 87                            | 68      | 84                            |         |                                                   |         |                                                 |  |                      |                        |
| 84                                     | Sarishabari 3 MW Solar Plant                   | Solar (IPP)                  | 1x3                     | 3                              | 3                                      | 2       | 0                             | 1.6     | 0                             |         |                                                   |         |                                                 |  |                      |                        |
| 85                                     | Sutakhal 50 MW Solar PP                        | Solar (IPP)                  | 1x50                    | 50                             | 47                                     | 0       | 50                            | 0       | 0                             |         |                                                   |         |                                                 |  |                      |                        |

| Sl. No.                                                         | Name of Power Station                         |                 | Nos. of Unit X Capacity (MW) | Installed Capacity (MW) | Derated/ Present Capacity (MW)                              | 02.06.23 (Yesterday)                                               |             | 03.06.23 (Today)                  |            | 02.06.23 (Yesterday)         |                         | Status of Machines under shut-down/ Maintenance |                                                   |       |     |
|-----------------------------------------------------------------|-----------------------------------------------|-----------------|------------------------------|-------------------------|-------------------------------------------------------------|--------------------------------------------------------------------|-------------|-----------------------------------|------------|------------------------------|-------------------------|-------------------------------------------------|---------------------------------------------------|-------|-----|
|                                                                 |                                               |                 |                              |                         |                                                             | Actual Peak Generation (MW)                                        |             | Probable Peak Generation (MW)     |            | Gen. shortfall for :         |                         | Description/ Remarks                            | Probable start-up date                            |       |     |
|                                                                 |                                               |                 |                              |                         |                                                             | Day                                                                | Evening     | Day                               | Evening    | Gas/Coal/Water Limitation MW | Machines shut down (MW) |                                                 |                                                   |       |     |
| 87                                                              | Fenchugonj CAPP Phase-1                       | Gas (PDB)       | 2x32+1x33                    | 97                      | 70                                                          | 43                                                                 | 43          | 43                                | 43         |                              | 27                      | GT-1 & ST-1 Under maint.                        |                                                   |       |     |
| 88                                                              | Fenchugonj CAPP Phase-2                       | Gas (PDB)       | 2x35+1x35                    | 104                     | 90                                                          | 39                                                                 | 38          | 40                                | 40         |                              | 52                      | GT-4 Under maint.                               |                                                   |       |     |
| 89                                                              | Fenchugonj 51 MW PP (Barakatullah)            | Gas (RPP)       | 19x2.90                      | 51                      | 51                                                          | 50                                                                 | 50          | 50                                | 50         |                              |                         |                                                 |                                                   |       |     |
| 90                                                              | Kushiera 163 MW CAPP (KP)                     | Gas (IPP)       | 1x109+1x54                   | 163                     | 163                                                         | 112                                                                | 112         | 112                               | 112        |                              | 54                      | ST Under maint.                                 |                                                   |       |     |
| 91                                                              | Hobiganj 11MW PP Confidence-E                 | Gas (SIPP, REB) | 4x2.90                       | 11                      | 11                                                          | 5                                                                  | 5           | 11                                | 11         |                              |                         |                                                 |                                                   |       |     |
| 92                                                              | Shahjibazar GTTP Unit- 8 & 9                  | Gas (PDB)       | 2x35                         | 70                      | 66                                                          | 54                                                                 | 55          | 60                                | 60         |                              |                         |                                                 |                                                   |       |     |
| 93                                                              | Shajibazar 330 MW CAPP                        | Gas (PDB)       | 2x110+1x110                  | 330                     | 330                                                         | 0                                                                  | 0           | 0                                 | 0          |                              | 330                     | Under maint.                                    |                                                   |       |     |
| 94                                                              | Shahjibazar 86MW PP (Shahjibazar)             | Gas (RPP)       | 32x2.90                      | 86                      | 86                                                          | 79                                                                 | 81          | 84                                | 84         |                              |                         |                                                 |                                                   |       |     |
| 95                                                              | Sylhet 225 MW CAPP                            | Gas (PDB)       | 1x142+1x89                   | 231                     | 231                                                         | 191                                                                | 187         | 190                               | 190        |                              |                         |                                                 |                                                   |       |     |
| 96                                                              | Sylhet 20 MW GTTP                             | Gas (PDB)       | 1 x 20                       | 20                      | 20                                                          | 0                                                                  | 17          | 17                                | 17         |                              |                         |                                                 |                                                   |       |     |
| 97                                                              | Sylhet 10MW PP (Desh)                         | Gas (RPP)       | 6x1.95                       | 10                      | 10                                                          | 10                                                                 | 10          | 10                                | 10         |                              |                         |                                                 |                                                   |       |     |
| 98                                                              | Shahjahanulla 25 MW PP                        | Gas (CIPP, REB) | 3x9.34                       | 25                      | 25                                                          | 16                                                                 | 16          | 16                                | 16         | 9                            |                         | Gas Shortage                                    |                                                   |       |     |
| 99                                                              | Bibiiana-II 341 MW CAPP (Summit)              | Gas (IPP)       | 1x222+1x119                  | 341                     | 341                                                         | 290                                                                | 300         | 300                               | 305        |                              |                         |                                                 |                                                   |       |     |
| 100                                                             | Bibiiana-III 400 MW CAPP                      | Gas (PDB)       | 1x285+1x115                  | 400                     | 400                                                         | 398                                                                | 398         | 400                               | 400        |                              |                         |                                                 |                                                   |       |     |
| 101                                                             | Bibiiana South 383 MW CAPP                    | Gas (PDB)       | 1x252+1x131                  | 383                     | 383                                                         | 354                                                                | 392         | 400                               | 400        |                              |                         |                                                 |                                                   |       |     |
| 102                                                             | Shahjibazar 100 MW GTTP                       | Gas (PDB)       | 1x100                        | 100                     | 100                                                         | 0                                                                  | 0           | 0                                 | 0          |                              | 100                     | Under project work                              |                                                   |       |     |
| 103                                                             | Fenchuganj 44MW (Energyprima)                 | Gas (NENP)      | 12*3.3+5*2                   | 50                      | 50                                                          | 48                                                                 | 49          | 48                                | 48         |                              |                         |                                                 |                                                   |       |     |
| Sylhet Zone Total                                               |                                               |                 |                              |                         |                                                             | 2472                                                               | 2427        | 1689                              | 1753       | 1781                         | 1786                    | 9                                               | 563                                               |       |     |
| 104                                                             | Bheramara GTTP Unit- 3                        | HSD (PDB)       | 1 x 20                       | 20                      | 16                                                          | 0                                                                  | 0           | 0                                 | 0          |                              |                         |                                                 |                                                   |       |     |
| 105                                                             | Bheramara 410 MW CAPP                         | Gas (NWPGL)     | 1 x 278+1 x 132              | 410                     | 410                                                         | 160                                                                | 225         | 200                               | 200        | 185                          |                         | Gas Shortage                                    |                                                   |       |     |
| 106                                                             | Faridpur 50 MW Peaking PP                     | HFO (PDB)       | 8x6.98                       | 54                      | 54                                                          | 11                                                                 | 21          | 22                                | 35         |                              |                         |                                                 |                                                   |       |     |
| 107                                                             | Gopalganj 100 MW Peaking PP                   | HFO (PDB)       | 16x6.98                      | 109                     | 109                                                         | 30                                                                 | 68          | 60                                | 80         |                              |                         |                                                 |                                                   |       |     |
| 108                                                             | Khulna 225 MW CAPP                            | HSD Gas (NWPGL) | 1 x 150+1x75                 | 230                     | 230                                                         | 0                                                                  | 0           | 0                                 | 0          |                              |                         |                                                 |                                                   |       |     |
| 109                                                             | Rupsha 105 MW PP (Orion rupsha)               | HFO (IPP)       | 6x18.445                     | 105                     | 105                                                         | 17                                                                 | 17          | 17                                | 17         |                              |                         |                                                 |                                                   |       |     |
| 110                                                             | Madhumati 100 MW PP                           | HFO (NWPGL)     | 6x18.415                     | 105                     | 105                                                         | 105                                                                | 105         | 105                               | 105        |                              |                         |                                                 |                                                   |       |     |
| 111                                                             | Mongla Orion 100 MW Solar PP                  | Solar (IPP)     |                              | 100                     | 100                                                         | 87                                                                 | 0           | 100                               | 0          |                              |                         |                                                 |                                                   |       |     |
| 112                                                             | Khulna 115 MW PP (KPCL-2)                     | HFO (NENP)      | 7x17                         | 115                     | 115                                                         | 44                                                                 | 80          | 83                                | 83         |                              |                         |                                                 |                                                   |       |     |
| 113                                                             | Noapara 40 MW PP (Khanjahan Ali)              | HFO (NENP)      | 5*8.5                        | 40                      | 40                                                          | 16                                                                 | 40          | 16                                | 40         |                              |                         |                                                 |                                                   |       |     |
| 114                                                             | Maitree Super Thermal 1320 MW PP (U-1)        | Coal (BIFPCL)   | 1x617                        | 617                     | 617                                                         | 318                                                                | 325         | 320                               | 320        |                              |                         |                                                 |                                                   |       |     |
|                                                                 | Khulna 330 MW CAPP                            | Gas/HSD (BPDB)  |                              |                         |                                                             | 0                                                                  | 0           | 0                                 | 0          |                              |                         |                                                 |                                                   |       |     |
| **                                                              | Bheramara (HVDC)                              | India           | 1000                         | 1000                    | 909                                                         | 803                                                                | 927         | 927                               |            |                              |                         |                                                 |                                                   |       |     |
| Khulna Zone Total                                               |                                               |                 |                              |                         |                                                             | 2905                                                               | 2901        | 1697                              | 1684       | 1850                         | 1807                    | 185                                             | 0                                                 |       |     |
| 115                                                             | Barisal 110 MW PP (Summit)                    | HFO (IPP)       | 7 x 17.076                   | 110                     | 110                                                         | 16                                                                 | 16          | 16                                | 16         |                              |                         |                                                 |                                                   |       |     |
| 116                                                             | Bhola 33 MW PP (Venture)                      | Gas (NENP)      | 1x34.50                      | 40                      | 40                                                          | 28                                                                 | 35          | 23                                | 35         |                              |                         |                                                 |                                                   |       |     |
| 117                                                             | Bhola 225 MW CAPP                             | Gas (PDB)       | 2x63+1x68                    | 194                     | 194                                                         | 164                                                                | 170         | 170                               | 170        |                              |                         |                                                 |                                                   |       |     |
| 118                                                             | Payra 1320 MW TPP                             | Coal (BCPCL)    | 2x622                        | 1244                    | 1244                                                        | 410                                                                | 610         | 622                               | 622        |                              |                         |                                                 |                                                   |       |     |
| 119                                                             | Potukhali 150MW PP (UPPL)                     | HFO (IPP)       | 8x18.415+1x9.78              | 150                     | 150                                                         | 17                                                                 | 150         | 17                                | 150        |                              |                         |                                                 |                                                   |       |     |
| 120                                                             | Barisal Electric 307 MW                       | Coal (IPP)      | 1x307                        | 307                     | 307                                                         | 150                                                                | 150         | 150                               | 150        |                              |                         |                                                 |                                                   |       |     |
| 121                                                             | Bhola 220MW CAPP (Nutan Bidyut BD Ltd)        | Gas/HSD (IPP)   | 2x75+1x70                    | 220                     | 220                                                         | 0                                                                  | 0           | 0                                 | 0          |                              | 220                     | Under maint.                                    |                                                   |       |     |
| Barishal Zone Total                                             |                                               |                 |                              |                         |                                                             | 2265                                                               | 2265        | 785                               | 1131       | 998                          | 1143                    | 0                                               | 220                                               |       |     |
| 122                                                             | a) Baghabari 71 MW GTTP                       | Gas (PDB)       | 1 x 71                       | 71                      | 71                                                          | 0                                                                  | 0           | 0                                 | 0          | 71                           |                         | Gas Shortage                                    |                                                   |       |     |
|                                                                 | b) Baghabari 100 MW GTTP                      | Gas (PDB)       | 1 x 100                      | 100                     | 100                                                         | 0                                                                  | 0           | 0                                 | 0          | 100                          |                         | Under maint.                                    |                                                   |       |     |
| 123                                                             | Baghabari 50 MW Peaking PP                    | HFO (PDB)       | 6x8.9                        | 52                      | 52                                                          | 0                                                                  | 28          | 25                                | 30         |                              |                         |                                                 |                                                   |       |     |
| 124                                                             | Baghabari 200 MW PP (Paramount)               | HSD (IPP)       | 135x1.6                      | 200                     | 200                                                         | 0                                                                  | 0           | 0                                 | 0          |                              |                         |                                                 |                                                   |       |     |
| 125                                                             | Bera 70 MW Peaking PP                         | HFO (PDB)       | 9x8.29                       | 71                      | 71                                                          | 13                                                                 | 13          | 0                                 | 0          |                              |                         |                                                 |                                                   |       |     |
| 126                                                             | Chapainawabganj 100 MW Peaking PP             | HFO (PDB)       | 12x8.924                     | 104                     | 104                                                         | 32                                                                 | 84          | 80                                | 90         |                              |                         |                                                 |                                                   |       |     |
| 127                                                             | Katakhali 50 MW Peaking PP                    | HFO (PDB)       | 6x8.7                        | 50                      | 50                                                          | 30                                                                 | 37          | 40                                | 40         |                              |                         |                                                 |                                                   |       |     |
| 128                                                             | Katakhali 50 MW PP (Northern)                 | HFO (QRPP)      | 6x8.9                        | 50                      | 50                                                          | 25                                                                 | 25          | 25                                | 25         |                              |                         |                                                 |                                                   |       |     |
| 129                                                             | Santahar 50 MW Peaking PP                     | HFO (PDB)       | 6x8.7                        | 50                      | 50                                                          | 0                                                                  | 30          | 35                                | 35         |                              |                         |                                                 |                                                   |       |     |
| 130                                                             | Sirajgonj 225MW CAPP Unit-1                   | Gas (NWPGL)     | 1x150+1x75                   | 210                     | 210                                                         | 155                                                                | 199         | 160                               | 160        |                              |                         |                                                 |                                                   |       |     |
| 131                                                             | Sirajgonj 225MW CAPP Unit-2                   | Gas (NWPGL)     | 1x150 + 1x75                 | 220                     | 220                                                         | 0                                                                  | 0           | 0                                 | 0          | 220                          |                         | Gas Shortage                                    |                                                   |       |     |
| 132                                                             | Sirajgonj 225MW CAPP Unit-3                   | Gas (NWPGL)     | 1x141+1x79                   | 220                     | 220                                                         | 143                                                                | 176         | 170                               | 170        | 44                           |                         | Gas Shortage                                    |                                                   |       |     |
| 133                                                             | Sirajgonj 400 MW CAPP Unit-4                  | Gas (IPP)       | 1x282+1x132                  | 414                     | 414                                                         | 414                                                                | 415         | 400                               | 400        |                              |                         |                                                 |                                                   |       |     |
| 134                                                             | Bogra 22 MW PP (GBB)                          | Gas (RPP)       | 6x4.0                        | 22                      | 22                                                          | 13                                                                 | 19          | 22                                | 22         |                              |                         |                                                 |                                                   |       |     |
| 135                                                             | Ullapara 11 MW PP (Summit)                    | Gas (SIPP, REB) | 4x2.90                       | 11                      | 11                                                          | 8                                                                  | 8           | 8                                 | 8          |                              |                         |                                                 |                                                   |       |     |
| 136                                                             | Natore 52 MW PP (Rajlanka)                    | HFO (IPP)       | 6x8.92                       | 52                      | 52                                                          | 0                                                                  | 34          | 0                                 | 52         |                              |                         |                                                 |                                                   |       |     |
| 137                                                             | Bagura 113 MW (Confidence) U-1                | HFO (IPP)       | 6*18.55                      | 113                     | 113                                                         | 35                                                                 | 55          | 35                                | 57         |                              |                         |                                                 |                                                   |       |     |
| 138                                                             | Bagura 113 MW PP (Confidence) U-2             | HFO (IPP)       | 6x18.55                      | 113                     | 113                                                         | 35                                                                 | 50          | 35                                | 50         |                              |                         |                                                 |                                                   |       |     |
| 139                                                             | Ammura 30 MW PP (Sinha)                       | HFO (NENP)      | 7x7.79                       | 50                      | 28                                                          | 28                                                                 | 28          | 21                                | 28         |                              |                         |                                                 |                                                   |       |     |
| 140                                                             | Sirajgonj 6.55 MW Solar                       | Solar (NWPGL)   | 1x6                          | 6                       | 6                                                           | 4                                                                  | 0           | 6                                 | 0          |                              |                         |                                                 |                                                   |       |     |
| **                                                              | Adani Power Jharkhanda Ltd                    | Coal (Import)   | 1x748                        | 748                     | 748                                                         | 1067                                                               | 1053        | 748                               | 748        |                              |                         |                                                 |                                                   |       |     |
| Rajshahi Zone Total                                             |                                               |                 |                              |                         |                                                             | 2927                                                               | 2905        | 2002                              | 2254       | 1810                         | 1915                    | 335                                             | 100                                               |       |     |
| 141                                                             | a) Barapukuria TPP Unit-1                     | Coal (PDB)      | 1 x 125                      | 125                     | 85                                                          | 76                                                                 | 75          | 75                                | 75         | 10                           |                         | Coal Shortage                                   |                                                   |       |     |
|                                                                 | b) Barapukuria TPP Unit-2                     | Coal (PDB)      | 1 x 125                      | 125                     | 85                                                          | 0                                                                  | 0           | 0                                 | 0          | 85                           |                         | Under Overhauling                               |                                                   |       |     |
| 142                                                             | Barapukuria 275 MW TPP Unit-3                 | Coal (PDB)      | 1 x 274                      | 274                     | 274                                                         | 230                                                                | 230         | 230                               | 230        |                              |                         | Coal Shortage                                   |                                                   |       |     |
| 143                                                             | Rangpur 20 MW GTTP                            | HSD (PDB)       | 1 x 20                       | 20                      | 20                                                          | 0                                                                  | 0           | 0                                 | 0          |                              |                         |                                                 |                                                   |       |     |
| 144                                                             | Rangpur 113 MW PP (Confidence)                | HFO (IPP)       | 7*16x 2*3                    | 113                     | 113                                                         | 33                                                                 | 56          | 35                                | 55         |                              |                         |                                                 |                                                   |       |     |
| 145                                                             | Saidpur 20 MW GTTP                            | HSD (PDB)       | 1 x 20                       | 20                      | 20                                                          | 0                                                                  | 0           | 0                                 | 0          |                              |                         |                                                 |                                                   |       |     |
| 146                                                             | Majpara, Tatalia 8 MW Solar PP (Sympa Power)  | Solar (IPP)     | 1 x 8                        | 8                       | 8                                                           | 7                                                                  | 0           | 8                                 | 0          |                              |                         |                                                 |                                                   |       |     |
| 147                                                             | Thakurgaon 115MW PP (Energypac)               | HFO (IPP)       | 6*20                         | 115                     | 115                                                         | 35                                                                 | 114         | 34                                | 115        |                              |                         |                                                 |                                                   |       |     |
| 148                                                             | Lalmohith 30 MW Solar (Intraco)               | Solar (IPP)     | 1*30                         | 30                      | 30                                                          | 22                                                                 | 0           | 30                                | 0          |                              |                         |                                                 |                                                   |       |     |
| 149                                                             | Teesta Solar Limited                          | Solar (IPP)     | 1 x 200                      | 200                     | 200                                                         | 189                                                                | 0           | 130                               | 0          |                              |                         |                                                 |                                                   |       |     |
| Rangpur Zone Total                                              |                                               |                 |                              |                         |                                                             | 1030                                                               | 950         | 592                               | 475        | 542                          | 475                     | 10                                              | 85                                                |       |     |
| Sub-total: Plants in operation                                  |                                               |                 |                              |                         |                                                             | 23834                                                              | 23370       | 11960.0                           | 14377      | 12525                        | 14567                   | 1336                                            | 2236                                              |       |     |
| (B) Plants under long term maintenance/ contract expired        |                                               |                 |                              |                         |                                                             |                                                                    |             |                                   |            |                              |                         |                                                 |                                                   |       |     |
| 150                                                             | Jamalpur 95 MW PP(Powerpac)                   | HFO (IPP)       | 12x8.924                     | 95                      | 0                                                           | 0                                                                  | 0           | 0                                 | 0          |                              |                         |                                                 |                                                   |       |     |
| 151                                                             | Katpotti 52 MW PP (Sinha)                     | HFO (IPP)       | 7x7.90                       | 51                      | 0                                                           | 0                                                                  | 0           | 0                                 | 0          |                              |                         |                                                 |                                                   |       |     |
| 152                                                             | Bosilia 108MW PP(ULCL)                        | HFO (IPP)       | 12x8.775+1x3.5               | 108                     | 0                                                           | 0                                                                  | 0           | 0                                 | 0          |                              |                         |                                                 |                                                   |       |     |
| 153                                                             | Aspiganj 55 MW PP (Precision)                 | Gas (RPP)       | 15*4                         | 55                      | 0                                                           | 0                                                                  | 0           | 0                                 | 0          |                              |                         |                                                 |                                                   |       |     |
| Sub-total: Plants under long term maintenance/ contract expired |                                               |                 |                              |                         |                                                             | 309                                                                | 0           | 0                                 | 0          | 0                            | 0                       | 0                                               | 0                                                 |       |     |
| Gross Total                                                     |                                               |                 |                              |                         |                                                             | 24143                                                              | 23370       | 11960                             | 14377      | 12525                        | 14567                   | 1336                                            | 2236                                              |       |     |
| (C) Actual data of 02.06.23 (Yesterday) Friday :                |                                               |                 |                              |                         |                                                             |                                                                    |             |                                   |            |                              |                         |                                                 |                                                   |       |     |
| 01.                                                             | Max. Demand at eve. peak (Generation end)     | :               | 14770 MW, at =               | 21:00 hrs               | 12.                                                         | Zone wise Demand and Load-shed at Evening Peak (Sub-station end) : |             |                                   |            |                              |                         |                                                 |                                                   |       |     |
| 02.                                                             | Max. Demand at eve. peak (Sub-station end)    | :               | 14210 MW, at =               | 21:00 hrs               | Zone                                                        | Demand MW                                                          | Supply MW   | Load Shed MW                      | Zone       | Demand MW                    | Supply MW               | Load Shed MW                                    |                                                   |       |     |
| 03.                                                             | Highest Generation (Generation end)           | :               | 14377 MW, at =               | 21:00 hrs               |                                                             |                                                                    |             |                                   |            |                              |                         |                                                 |                                                   |       |     |
| 04.                                                             | Minimum Generation (Generation end)           | :               | 11153 MW, at =               | 9:00 hrs                | Dhaka                                                       | 5050                                                               | 5050        | 0                                 | Mymensingh | 1221                         | 1171                    | 50                                              |                                                   |       |     |
| 05.                                                             | Day-peak Generation (Generation end)          | :               | 11960 MW, at =               | 12:00 hrs               | Chattoogram                                                 | 1425                                                               | 1425        | 0                                 | Sylhet     | 560                          | 560                     | 0                                               |                                                   |       |     |
| 06.                                                             | Evening-peak Generation (Generation end)      | :               | 14377 MW, at =               | 21:00 hrs               | Khulna                                                      | 1663                                                               | 1533        | 130                               | Barisal    | 466                          | 466                     | 0                                               |                                                   |       |     |
| 07.                                                             | Evening Peak Load-shed (Sub-station end)      | :               | 375 MW, at =                 | 21:00 hrs               | Rajshahi                                                    | 1507                                                               | 1472        | 35                                | Rangpur    | 953                          | 903                     | 50                                              |                                                   |       |     |
| 08.                                                             | Minimum Generation Forecast up to 8:00 hrs.   | :               | 11234 MW, at =               | 5:00 hrs                | Cumilla                                                     | 1366                                                               | 1256        | 110                               |            |                              |                         |                                                 |                                                   |       |     |
| 09.                                                             | Generation shortfall at evening peak due to : | :               |                              |                         | Total                                                       |                                                                    |             |                                   |            |                              |                         |                                                 | 14210                                             | 13835 | 375 |
|                                                                 | a) Gas/LF limitation                          | :               | 1121 MW                      |                         | 13.                                                         |                                                                    |             |                                   |            |                              |                         |                                                 |                                                   |       |     |
|                                                                 | c) Coal supply Limitation                     | :               | 10 MW                        |                         | Fuel cost : a) Gas = 184909652 Taka b) Oil = 740073657 Taka |                                                                    |             |                                   |            |                              |                         |                                                 | (c) Coal = 132253080 Taka Total = 1057235788 Taka |       |     |
|                                                                 | b) Low water level in Kaptai lake             | :               | 205 MW                       |                         |                                                             |                                                                    |             |                                   |            |                              |                         |                                                 |                                                   |       |     |
|                                                                 | c) Plants under shut down/ maintenance        | :               | 2236 MW                      |                         | 14.                                                         |                                                                    |             |                                   |            |                              |                         |                                                 |                                                   |       |     |
| 10.                                                             | Total Energy (Generation + India Import)      | :               | 294.47 MKWh                  |                         | Maximum Temperature in Dhaka was : 37.5° C                  |                                                                    |             |                                   |            |                              |                         |                                                 |                                                   |       |     |
|                                                                 | By Gas = 158.114 MKWh                         |                 | By Oil = 53.483 MKWh         |                         | 15.                                                         |                                                                    |             |                                   |            |                              |                         |                                                 |                                                   |       |     |
|                                                                 | By Coal = 54.496 MKWh                         |                 | By Hydro = 0.307 MKWh        |                         | Export through East-West interconnections :                 |                                                                    |             |                                   |            |                              |                         |                                                 |                                                   |       |     |
|                                                                 | By Solar= 3.218 MKWh                          |                 |                              |                         | At evening peak-hour : 11960 MW, at 21:00 hrs               |                                                                    |             |                                   |            |                              |                         |                                                 |                                                   |       |     |
|                                                                 |                                               |                 |                              |                         | Maximum : 840 MW, at 19:30 hrs                              |                                                                    |             |                                   |            |                              |                         |                                                 |                                                   |       |     |
|                                                                 |                                               |                 |                              |                         | Energy : 0 MKWh                                             |                                                                    |             |                                   |            |                              |                         |                                                 |                                                   |       |     |
| 11.                                                             | Total Gas Supplied                            | :               | 1200.86 MMCFD                |                         |                                                             |                                                                    |             |                                   |            |                              |                         |                                                 |                                                   |       |     |
| (D) Forecast of 03.06.23 (Today) Saturday :                     |                                               |                 |                              |                         |                                                             |                                                                    |             |                                   |            |                              |                         |                                                 |                                                   |       |     |
| 01.                                                             | Maximum Demand                                | :               | 15500 MW (Generation end)    | 04.                     | Maximum Load-shed                                           | :                                                                  | 860 MW      | At evening peak (Sub-station end) |            |                              |                         |                                                 |                                                   |       |     |
| 02.                                                             | Maximum Generation                            | :               | 14567 MW (Generation end)    | 05.                     | Total Generation                                            | :                                                                  | 317.47 MKWh |                                   |            |                              |                         |                                                 |                                                   |       |     |
| 03.                                                             | Reserve / Shortage                            | :               | -933 MW (Generation end)     | 06.                     | Probable Max. Temperature in Dhaka :                        | :                                                                  | 37.5° C     |                                   |            |                              |                         |                                                 |                                                   |       |     |

\* Captive Power \*\* Imported Power  
#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)  
Deputy Secretary, Generation