

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month June, 2023					Day : Saturday					Date : 10.06.23				
Probable Maximum Demand : 14000 MW					Probable Maximum Generation : 15281 MW					Rule Curve = 78.34 ft.				
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 72.46 ft Today = 72.55 ft.									
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	09.06.23 (Yesterday)		10.06.23 (Today)		09.06.23 (Yesterday)		10.06.23 (Today)			
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Status of Machines under shut-down/ Maintenance			
					Day	Evening	Day	Evening	Gas/Coal/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date		
(A) Plants in operation:														
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work		
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	110	110	110	110	70		Gas Shortage		
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180					
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0					
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108		Gas Shortage		
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage		
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0					
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	280	350	330	330					
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450					
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling		
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	370	402	400	400					
11	Siddhirganj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	187	163	100	100					
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	1	218	218	218					
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	281	275	280	280					
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	15	0	25					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	50	50	74					
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	15	10	19	19					
17	Summit Power(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	45	47	48	48					
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	25	25	25					
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	32	33	33	33					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	8	8	50					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	105	70	105	105					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	32	32	82	150					
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	35	0	35					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	47	15	45	145					
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	102	17	149					
26	Keraniganj 300 MW PP (APSC)	HSD (IPP)	25x12.4	300	300	0	0	300	300					
27	Bramhanaganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0					
28	Aurahat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100					
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	35	35	55					
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	55	35	55					
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	72	72	72					
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	108	35	162					
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	7	0	30	0					
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	35	17	35					
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	58	10	75	75					
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	52	83	50	100					
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	17	17	17					
38	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	20	0	0	0	11					
Dhaka Zone Total					6104	5867	2369	3005	3266	3908	283	375		
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	0	25	25	25	205		Low water level		
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	114	113	120	120	67		Gas Shortage		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.		
41	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0					
42	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	0	8	25					
43	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	8	0	20	0					
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	22	50	50					
45	Sikalbaha 105 MW PP (Baraka Sikabaha)	HFO (IPP)	6x18.415	105	105	17	51	51	51					
46	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Under maint.		
47	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	222	226	225	225					
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	70	205	70	300					
49	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	63	25	63					
50	Dohazari-Kalash 100 MW Peaking	HFO (PDB)	6x17.0	102	102	34	34	51	51					
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	33	55	73					
52	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	9	11	11	11					
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			35	42	10	25					
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0					
54	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17					
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	34	51	51	74					
56	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	63	25	63					
57	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	33	33	33	33					
58	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	68	34	68					
59	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	18	163	72	163					
	SS Power Unit-1	Coal (IPP)				0	0	0	0					
	Cox's Bazar Wind PP	(Wind) (IPP)				1	5	5	0					
Chattogram Zone Total					2605	2545	697	1225	963	1437	272	330		
60	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	42	43	40	40					
61	Ashuganj 225 MW CAPP	Gas (APSCCL)	1x142+1x75	221	221	179	207	200	200					
62	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	275	275	300	300					
63	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	285	280	300	310					
64	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	248	295	270	295	105		Gas Shortage		
65	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*116	195	195	8	8	8	8	187		Gas Shortage		
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51					
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	6	150	12	150					
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	37	46	45	45					
69	Chandpur 150 MW CAPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163		Under overhauling		
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	100	51	100					
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	20	20					
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11					
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	32	33	33	33					
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	25	52	26	52					
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	14	20	20					
76	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	0	17	114					
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	95	9	98					
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	17	17	35					
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	36	115	72	95					
**	Import (Tijura)	India		160	160	122	140	129	152					
Cumilla Zone Total					2904	2896	1474	1951	1631	2129	292	163		
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	33	102	30	102	100		Gas Shortage		
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	0	18	18					
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	18	85	18	86					
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	68	87	68	86					
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0					
85	Sutiakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	13	0	50	0					
86	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	12	0	12	12					
Mymensingh Zone Total					622	614	162	274	198	304	100	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	09.06.23 (Yesterday)		10.06.23 (Today)		09.06.23 (Yesterday)		Status of Machines under shut-down/ Maintenance			
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)				
						Day	Evening	Day	Evening			Description/ Remarks	Probable start-up date		
87	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 & ST-1 Under maint.			
88	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	40	39	40	40		51	GT-4 Under maint.			
89	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	44	50	50	50						
90	Kushiara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	80	112	112	112		54	ST Under maint.			
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11						
92	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	59	56	56	56						
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.			
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	72	74	76	76						
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	181	180	195	195						
96	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	0	0	0						
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10						
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16						
99	Bibiiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	265	300	300	310						
100	Bibiyanali 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	334	365	400	400						
101	Bibiyan South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	260	260	50	200						
102	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work			
103	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.4+5*2	50	50	50	47	50	50						
Sylhet Zone Total						2472	2427	1465	1563	1409	1569	0	562		
104	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0						
105	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	190	265	230	250		145	Gas Shortage			
106	Fairpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	15	0	20	30						
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	23	0	60	70						
108	Khulna 225 MW CCPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	205	120	170	205						
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	53	0	54	70						
110	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	50	0	50	85						
111	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	39	0	100	0						
112	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	16	0	16	49						
113	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	8	0	8	40						
114	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	375	376	370	370						
	Khulna 330 MW CCPP	Gas/HSD				235	0	0	220						
**	Bheramara (HVDC)	India		1000	1000	910	766	929	929						
Khulna Zone Total						2905	2901	2119	1527	2007	2318	145	0		
115	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.075	110	110	16	32	16	48						
116	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	22	33	21	33						
117	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	172	156	170	170						
118	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	0	0	0	0		1244	Coal Shortage			
119	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	17	17	150						
120	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	250	225	307	307						
121	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	40	110	110	110		110	Under maint.			
Barishal Zone Total						2265	2265	517	573	641	818	1244	110		
122	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage			
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.			
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	27	0	28	28						
124	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0						
125	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	30	30						
126	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	40	26	40	90						
127	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	22	0	36	36						
128	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	34	0	25	34						
129	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	28	35	35						
130	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	160	202	180	190						
131	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	0	0	0	0		220	Gas Shortage			
132	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	169	176	150	170		44	Gas Shortage			
133	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	285	426	380	400						
134	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	19	22	22	22						
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8						
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	0	52						
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	113	35	56						
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	40	35	57						
139	Amthura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	28	0	28	28						
140	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	1	0	6	0						
**	Adani Power Jharkhanda Ltd	Coal (Import)	1x748	748	748	1082	1052	1060	1060						
Rajshahi Zone Total						2927	2905	1945	2093	2098	2296	335	100		
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	64	72	72	72						
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling			
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	230	250	230	250						
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	16						
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	35	56	35	49						
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
146	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	4	0	8	0						
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	110	35	115						
148	Lalmohithat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	0	0	30	0						
149	Treesta Solar Limited	Solar (IPP)	1 x 200	200	200	8	0	130	0						
Rangpur Zone Total						1030	950	341	488	540	502	0	85		
Sub-total: Plants in operation						23834	23370	11089.0	12699	12753	15281	2671	1725		
(B) Plants under long term maintenance/ contract expired															
150	Jamulpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0						
151	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0						
152	Bosilia 108MW PP(ULC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0						
153	Ashugani 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	0	0	0	0						
Sub-total: Plants under long term maintenance/ contract expired						305	0	0	0	0	0	0	0		
Gross Total						24143	23370	11089	12699	12753	15281	2671	1725		
(C) Actual data of 09.06.23 (Yesterday) Friday :															
01.	Max. Demand at eve. peak (Generation end)	:	12699	MW,	at =	21:00	hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	12098	MW,	at =	21:00	hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	12699	MW,	at =	21:00	hrs	MW	MW	MW	MW	MW	MW	MW	MW
04.	Minimum Generation (Generation end)	:	11089	MW,	at =	9:00	hrs	Dhaka	4103	4103	0	Mymensingh	968	968	0
05.	Day-peak Generation (Generation end)	:	11089	MW,	at =	9:00	hrs	Chattogram	1186	1186	0	Sylhet	567	567	0
06.	Evening-peak Generation (Generation end)	:	12699	MW,	at =	21:00	hrs	Khulna	1372	1372	0	Barishal	408	408	0
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW,	at =	21:00	hrs	Rajshahi	1343	1343	0	Rangpur	897	897	0
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10176	MW,	at =	5:00	hrs	Cumilla	1254	1254	0				
09.	Generation shortfall at evening peak due to :	:						Total		12098	12098	0			
a)	Gas/LF limitation	:	2466	MW				Fuel cost :		(a) Gas = 161034963 Taka	(c) Coal = 40001798 Taka				
d)	Coal supply Limitation	:	0	MW						(b) Oil = 718755762 Taka	Total = 919792523 Taka				
b)	Low water level in Kaptai lake	:	205	MW											
c)	Plants under shut down/ maintenance	:	1725	MW											
10.	Total Energy (Generation + India Import)	:	275.60	MKWh											
	By Gas =	146.127	MKWh	By Oil =	57.479	MKWh									
	By Coal =	45.742	MKWh	By Hydro =	0.332	MKWh									
	By Solar=	1.214	MKWh												
11.	Total Gas Supplied	:	1200.35	MMCFD											
(D) Forecast of 10.06.23 (Today) Saturday :															
01.	Maximum Demand	:	14000	MW	(Generation end)			04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	15281	MW	(Generation end)			05.	Total Generation	:	303.83	MKWh			
03.	Reserve / Shortage	:	1281	MW	(Generation end)			06.	Probable Max. Temperature in Dhaka ;	:	32.1° C				