

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month June, 2023					Day : Sunday				Date : 11.06.23					
Probable Maximum Demand : 14800 MW					Probable Maximum Generation : 15051 MW				Rule Curve = 78.60 ft.					
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 72.55 ft. Today = 72.65 ft.									
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	10.06.23 (Yesterday)		11.06.23 (Today)		10.06.23 (Yesterday)		11.06.23 (Today)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Water Limitation MW		Machines shut down (MW)		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening						
(A) Plants in operation:														
1	Ghorasal Repowered CAPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260		Under project work	
2	a) Ghorasal Repowered CAPP Unit-4	Gas (PDB)	1 x 210	210	180	110	110	110	110	70			Gas Shortage	
3	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180					
3	Ghorasal 365 MW CAPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0					
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108			Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105			Gas Shortage	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0					
7	Haripur 360MW CAPP(HPL)	Gas (IPP)	1x235+1x125	360	360	321	342	330	340					
8	Meghnaghat 450 MW CAPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450					
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115		Under Overhauling	
10	Haripur 412 MW CAPP	Gas (EGCB)	1x273+1x139	412	412	398	398	400	400					
11	Siddhirganj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	193	160	100	160					
12	Siddhirganj 335 MW CAPP	Gas (EGCB)	1 x 217+1x118	335	335	215	220	300	330					
13	Meghnaghat CAPP(Summit)	Gas (IPP)	2x110+1x110	335	335	294	278	280	300					
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	15	0	15					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	74	91	50	91					
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	15	15	15					
17	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	46	47	48	48					
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	33	33	33					
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	32	32	33	33					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	50	8	50					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	105	105	105	105					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	82	150	82	150					
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	35	0	35					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	47	148	45	150					
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	149	17	149					
26	Keraniganj 300 MW PP (APSC)	HSD (IPP)	25x11.4	300	300	229	0	300	300					
27	Bramhanaganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0					
28	Aurahat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	94	0	100	100					
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	35	35	35					
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	35	55					
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	72	93	72	72					
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	35	108	35	108					
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	31	0	30	0					
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	34	17	35					
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	75	75	75	75					
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	61	93	50	93					
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	17	17	17	17					
38	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	20	0	56	0	56					
Dhaka Zone Total					6104	5867	3300	3574	3352	4090	283	375		
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	30	30	25	30	200			Low water level	
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	100	100	180			Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180		Under maint.	
41	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	0	0	5	0	0					
42	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	25	8	25					
43	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	2	0	20	0					
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	50	50	50					
45	Sikalbaha 105 MW PP (Baraka Sikabaha)	HFO (IPP)	6x18.415	105	105	17	51	51	51					
46	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150		Under maint.	
47	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	226	227	225	225					
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	69	282	70	282					
49	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	63	25	63					
50	Dohazari-Kalash 100 MW Peaking	HFO (PDB)	6x17.0	102	102	17	51	51	51					
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	17	31	30	31					
52	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	14	14	11	14					
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			6	21	10	20					
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0					
54	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17					
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	34	51	50	51					
56	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	50	25	50					
57	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	33	33	33	33					
58	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	68	34	68					
59	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	36	163	72	163					
	SS Power Unit-1	Coal (IPP)				0	0	0	0					
	Cox's Bazar Wind PP	(Wind) (IPP)				15	5	5	0					
Chattogram Zone Total					2605	2545	608	1232	917	1324	380	330		
60	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	29	42	40	42					
61	Ashuganj 225 MW CAPP	Gas (APSCCL)	1x142+175	221	221	190	208	200	210					
62	Ashuganj 450 MW CAPP(South)	Gas (APSCCL)	1x360	360	360	270	250	250	250					
63	Ashuganj 450 MW CAPP(North)	Gas (APSCCL)	1x361	360	360	275	280	300	300					
64	Ashuganj 420 MW CAPP(East)	Gas (APSCCL)	1x284+1x116	400	400	262	238	240	250	162			Gas Shortage	
65	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+11*6	195	195	0	0	0	0	195			Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51					
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	12	150	12	150					
68	Titaf 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	36	37	40	40					
69	Chandpur 150 MW CAPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163		Under overhauling	
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	51	103	51	100					
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	20	20					
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	11	11	11					
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	30	33	33	33					
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	41	26	43					
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	20	20	20					
76	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	17	17	17					
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	97	9	97					
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17					
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	75	97	72	97					
**	Importo (Tripura)	India		160	160	126	132	129	152					
Cumilla Zone Total					2904	2896	1498	1844	1538	1900	357	163		
80	RPCL 210MW CAPP	Gas (IPP)	4x35+1x70	210	202	32	87	50	87	115			Gas Shortage	
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	18	19					
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	19	85	18	85					
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	68	88	68	86					
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0					
85	Sutiakhal 50 MW Solar PP	Solar (IPP)	1x50	50	48	0	50	0	0					
86	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	12	12	12	12					
Mymensingh Zone Total					622	614	200	291	218	289	115	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	10.06.23 (Yesterday)		11.06.23 (Today)		10.06.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gas/Coal/Water Limitation MW	Machines shut down (MW)		
						Day	Evening	Day	Evening			Description/ Remarks	Probable start-up date
87	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 & ST-1 Under maint.	
88	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	39	30	30	30		60	GT-4 Under maint.	
89	Fenchugonj 51 MW PP (Barakattallah)	Gas (RPP)	19x2.90	51	51	47	50	50	50				
90	Kushiara 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	112	112		54	ST Under maint.	
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
92	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	28	60	56	60				
93	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	73	74	76	76				
95	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	180	181	180	181				
96	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	0	0	0				
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16				
99	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	315	270	280	280				
100	Bibiyana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	404	241	240	240				
101	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	30	325	350	380				
102	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
103	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	48	47	50	50				
Sylhet Zone Total						2472	2427	1356	1470	1504	1539	0	571
104	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
105	Bheramara 410 MW CAPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	305	260	230	260	150		Gas Shortage	
106	Fairdipor 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	12	25	20	25				
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	4	61	60	60				
108	Khulna 225 MW CAPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	205	157	170	205				
109	Rupsha 103 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	45	72	54	72				
110	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	50	105	50	105				
111	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	41	0	100	0				
112	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	32	16	32				
113	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	24	40	8	40				
114	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	369	376	370	376				
	Khulna 330 MW CAPP	Gas/HSD (BPDB)				0	0	0	220				
**	Bheramara (HVDC)	India		1000	1000	912	803	929	929				
Khulna Zone Total						2905	2901	1967	1931	2007	2324	150	0
115	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.075	110	110	16	32	16	32				
116	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	20	27	21	30				
117	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	173	169	170	170				
118	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	0	0	0	0	1244		Coal Shortage	
119	Potukhalhi 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	150	17	150				
120	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	307	307	307	307				
121	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	110	111	110	110		109	Under maint.	
Barishal Zone Total						2265	2265	643	796	641	799	1244	109
122	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Under maint.	
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	28	28	28				
124	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
125	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	35	30	35				
126	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	75	40	80				
127	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	33	33	33				
128	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	8	25	34				
129	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	35	35	35				
130	Sirajgonj 225MW CAPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	150	205	180	205				
131	Sirajgonj 225MW CAPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage	
132	Sirajgonj 225MW CAPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	130	196	150	196	24		Gas Shortage	
133	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	394	387	380	387				
134	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	20	21	22	22				
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8				
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	34	0	43				
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	95	35	55				
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	50	35	50				
139	Amthura 30 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	28	28	28				
140	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	5	0	6	0				
**	Adani Power Jharkhanda Ltd	Coal (Import)	1x748	748	748	1058	1051	1060	1060				
Rajshahi Zone Total						2927	2905	1765	2289	2095	2299	315	100
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	72	70	70	70			Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	230	230	230	230			Coal Shortage	
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	16				
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	34	56	35	56				
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	3	0	8	0				
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	35	114	35	115				
148	Lalmohithat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	7	0	30	0				
149	Treesta Solar Limited	Solar (IPP)	1 x 200	200	200	80	0	130	0				
Rangpur Zone Total						1030	950	461	470	538	487	0	85
Sub-total: Plants in operation						23834	23370	11798.0	13897	12810	15051	2844	1733
(B) Plants under long term maintenance/ contract expired													
150	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
151	Katpodi 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
152	Bosilia 108MW PP(ULC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
153	Aspugan 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	0	0	0	0				
Sub-total: Plants under long term maintenance/ contract expired						309	0	0	0	0	0	0	0
Gross Total						24143	23370	11798	13897	12810	15051	2844	1733
(C) Actual data of 10.06.23 (Yesterday) Saturday :													
01.	Max. Demand at eve. peak (Generation end)	:	13950	MW,	at =	21:00	hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :					
02.	Max. Demand at eve. peak (Sub-station end)	:	13246	MW,	at =	21:00	hrs	Zone	Demand	Supply	Load Shed	Demand	Supply
03.	Highest Generation (Generation end)	:	13897	MW,	at =	21:00	hrs	MW	MW	MW	MW	MW	MW
04.	Minimum Generation (Generation end)	:	10176	MW,	at =	7:00	hrs	Dhaka	4790	4765	25	Mymensingh	1125
05.	Day-peak Generation (Generation end)	:	11798	MW,	at =	12:00	hrs	Chattogram	1235	1235	0	Sylhet	500
06.	Evening-peak Generation (Generation end)	:	13897	MW,	at =	21:00	hrs	Khulna	1636	1636	0	Barishal	397
07.	Evening Peak Load-shed (Sub-station end)	:	51	MW,	at =	21:00	hrs	Rajshahi	1471	1445	26	Rangpur	923
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10875	MW,	at =	5:00	hrs	Cumilla	1169	1169	0		
09.	Generation shortfall at evening peak due to :	:											
a)	Gas/LF limitation	:	2644	MW									
b)	Coal supply Limitation	:	0	MW									
c)	Low water level in Kaptai lake	:	200	MW									
d)	Plants under shut down/ maintenance	:	1733	MW									
10.	Total Energy (Generation + India Import)	:	286.64	MKWh									
	By Gas =	159.270	MKWh	By Oil =	52.851	MKWh							
	By Coal =	47.714	MKWh	By Hydro =	0.371	MKWh							
	By Solar =	1.700	MKWh										
11.	Total Gas Supplied	:	1223.76	MMCFD									
(D) Forecast of 11.06.23 (Today) Sunday :													
01.	Maximum Demand	:	14800	MW	(Generation end)			04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)
02.	Maximum Generation	:	15051	MW	(Generation end)			05.	Total Generation	:	305.26	MKWh	
03.	Reserve / Shortage	:	251	MW	(Generation end)			06.	Probable Max. Temperature in Dhaka :	:	32.1° C		

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)