

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month June, 2023					Day : Tuesday				Date : 13.06.23					
Probable Maximum Demand : 14200 MW					Probable Maximum Generation : 15476 MW									
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 73.09 ft		Today = 73.26 ft		Rule Curve = 79.14 ft					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	12.06.23 (Yesterday)		13.06.23 (Today)		12.06.23 (Yesterday)		12.06.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for:		Machines shut down (MW)		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Gas/Coal/Water Limitation MW					
(A) Plants in operation:														
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260		Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	110	100	110	110	80			Gas Shortage	
3	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	170	160	180	180					
4	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0					
5	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108			Gas Shortage	
6	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105			Gas Shortage	
7	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0					
8	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	327	351	330	340					
9	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450					
10	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115		Under Overhauling	
11	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	404	386	400	400					
12	Siddhirganj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	191	203	200	200					
13	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	327	333	330	330					
14	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	293	273	280	300					
15	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	0	30					
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	91	91	92	92					
17	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	19	19	19					
18	Sumit Power(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	37	41	48	48					
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	0	33	33	33					
20	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	30	31	33	33					
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	42	8	50					
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	35	105	105	105					
23	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	32	133	32	82					
24	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	35	0	35					
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	47	148	45	145					
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	134	17	149					
27	Keraniganj 300 MW PP (APSC)	HSD (IPP)	25x11.4	300	300	0	0	300	300					
28	Bramhanaganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0					
29	Aurahat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100					
30	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	35	35	55					
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	55	35	55					
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	72	91	72	92					
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	35	90	35	108					
34	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	7	0	30	0					
35	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	28	17	35					
36	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	59	82	68	92					
37	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	70	83	73	93					
38	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	80	83	17					
39	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	20	48	33	16	48					
Dhaka Zone Total					6104	5867	2945	3660	3576	4126	293	375		
40	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	60	60	60	60	170			Low water level	
41	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	110	108	120	120	72			Gas Shortage	
42	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180		Under maint.	
43	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0					
44	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	25	8	25					
45	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	11	0	20	0					
46	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	50	50	50					
47	Sikalbaha 105 MW PP (Baraka Sikabaha)	HFO (IPP)	6x18.415	105	105	17	51	51	51					
48	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150		Under maint.	
49	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	219	226	225	225					
50	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	69	257	70	282					
51	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	63	25	63					
52	Dohazari-Kalash 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	51	51					
53	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	24	32	30	40					
54	Barabakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	12	12	11	14					
55	* Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	18	10	15					
56	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0					
57	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17					
58	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	38	34	50	51					
59	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	50	25	50					
60	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	33	33	33	33					
61	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	68	34	68					
62	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	36	108	72	163					
63	SS Power Unit-1	Coal (IPP)				0	0	0	0					
64	Cox's Bazar Wind PP	(Wind) (IPP)				3	0	5	0					
Chattogram Zone Total					2605	2545	736	1263	972	1378	242	330		
65	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	37	44	44	42					
66	Ashuganj 225 MW CAPP	Gas (APSCCL)	1x142+175	221	221	0	0	125	150		221		Under maint.	
67	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	275	305	280	280					
68	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	310	305	300	300					
69	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	350	300	350	350	100			Gas Shortage	
70	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*116	195	195	36	45	8	45	150			Gas Shortage	
71	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	43	51	51					
72	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	12	12	12	150					
73	Titaf 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	31	40	40					
74	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163		Under overhauling	
75	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	17	51	100					
76	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	21	20	20					
77	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	0	11	11					
78	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	33	33	33					
79	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	25	26	43					
80	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	21	20	20					
81	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	34	100	114					
82	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	95	9	97					
83	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17					
84	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	54	73	72	97					
85	** Imphott (Tripura)	India		160	160	160	148	135	152					
Cumilla Zone Total					2904	2896	1419	1569	1704	2112	250	384		
86	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	28	35	50	87	167			Gas Shortage	
87	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	17	18	19					
88	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	19	75	18	85					
89	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	68	88	68	86					
90	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	0	0	1.6	0					
91	Sutiakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	1								

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	12.06.23 (Yesterday)		13.06.23 (Today)		12.06.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gas/Coal/Water Limitation MW	Machines shut down (MW)		
						Day	Evening	Day	Evening			Description/ Remarks	Probable start-up date
87	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 & ST-1 Under maint.	
88	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	30	30	30		60	GT-4 Under maint.	
89	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	44	50	50	50				
90	Kushara 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	112	112		54	ST Under maint.	
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	5	11	11				
92	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	58	61	60	60				
93	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	72	73	76	76				
95	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	126	125	125	125		106	ST under maint.	
96	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	0	0	0				
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10				
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	16	16	16				
99	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	305	265	300	300				
100	Bibiyana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	365	352	400	400				
101	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	390	395	350	380				
102	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
103	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12'3.4+5'2	50	50	47	50	50	50				
Sylhet Zone Total						2472	2427	1620	1587	1633	1663	0	677
104	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
105	Bheramara 410 MW CAPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	215	175	200	225	235		Gas Shortage	
106	Fairpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	28	20	25				
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	70	0	72				
108	Khulna 225 MW CAPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	100	170	170	205				
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	35	73	54	72				
110	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	50	85	50	105				
111	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	82	0	100	0				
112	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	16	32	16	32				
113	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	8	24	8	40				
114	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	372	373	370	376	244		Coal Shortage	
	Khulna 330 MW CAPP	Gas/HSD (BPDB)				0	0	0	220				
**	Bheramara (HVDC)	India		1000	1000	903	906	928	928				
Khulna Zone Total						2905	2901	1781	1936	1916	2300	479	0
115	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.075	110	110	16	32	16	32				
116	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	20	26	21	30				
117	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	167	173	170	170				
118	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	0	0	0	0	1244		Coal Shortage	
119	Potukhalhi 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	54	17	150				
120	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	290	250	307	307				
121	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	109	110	110	110		110	Under maint.	
Barishal Zone Total						2265	2265	619	645	641	799	1244	110
122	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Under maint.	
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	28	28				
124	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
125	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	7	30	35				
126	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	82	40	80				
127	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	36	33	33				
128	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	34	25	34				
129	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	35	35	35				
130	Sirajgonj 225MW CAPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	150	148	150	150	62		Gas Shortage	
131	Sirajgonj 225MW CAPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage	
132	Sirajgonj 225MW CAPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	140	155	178	196	65		Gas Shortage	
133	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	334	357	380	387	57		Gas Shortage	
134	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	20	21	22	22				
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	0	8	8	8				
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	43	0	43				
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6'18.55	113	113	0	109	35	80				
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6'18.55	113	113	0	108	35	110				
139	Amthura 30 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	8	28	28				
140	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	0	0	6	0				
**	Adani Power Jharkhanda Ltd	Coal (Import)	1x748	748	748	1052	1057	1060	1060				
Rajshahi Zone Total						2927	2905	1696	2208	2093	2329	475	100
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	72	72	70	70			Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	230	230	230	230			Coal Shortage	
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	16				
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	35	54	35	49				
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	2	0	8	0				
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6'20	115	115	36	114	35	115				
148	Lalmohith 30 MW Solar (Intraco)	Solar (IPP)	1'30	30	30	12	0	30	0				
149	Treesta Solar Limited	Solar (IPP)	1 x 200	200	200	8	0	130	0				
Rangpur Zone Total						1030	950	395	470	538	480	0	85
Sub-total: Plants in operation						23834	23370	11364.0	13565	13291	15476	3150	2061
(B) Plants under long term maintenance/ contract expired													
150	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
151	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
152	Bosilia 108MW PP(ULC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
153	Aspogan 55 MW PP (Precision)	Gas (RPP)	15'4	55	0	0	0	0	0				
Sub-total: Plants under long term maintenance/ contract expired						309	0	0	0	0	0	0	0
Gross Total						24143	23370	11364	13565	13291	15476	3150	2061
(C) Actual data of 12.06.23 (Yesterday) Monday :													
01.	Max. Demand at eve. peak (Generation end)	:	13850	MW, at =	19:30 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	13116	MW, at =	19:30 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	13565	MW, at =	19:30 hrs	Dhaka	4752	4652	100	Mymensingh	1058	938	120
04.	Minimum Generation (Generation end)	:	10606	MW, at =	8:00 hrs	Chattogram	1364	1364	0	Sylhet	527	492	35
05.	Day-peak Generation (Generation end)	:	11364	MW, at =	11:00 hrs	Khulna	1650	1650	0	Barishal	331	331	0
06.	Evening-peak Generation (Generation end)	:	13565	MW, at =	19:30 hrs	Rajshahi	1398	1398	0	Rangpur	925	925	0
07.	Evening Peak Load-shed (Sub-station end)	:	272	MW, at =	19:30 hrs	Cumilla	1111	1094	17				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10690	MW, at =	5:00 hrs					Total	13116	12844	272
09.	Generation shortfall at evening peak due to :	:				13. Fuel cost : (a) Gas = 177278751 Taka (c) Coal = 38264271 Taka (b) Oil = 619004840 Taka Total = 834547863 Taka							
a)	Gas/LF limitation	:	2980	MW									
d)	Coal supply Limitation	:	0	MW									
b)	Low water level in Kaptai lake	:	170	MW									
c)	Plants under shut down/ maintenance	:	2061	MW									
10.	Total Energy (Generation + India Import)	:	282.77	MKWh		14. Maximum Temperature in Dhaka was : 31.9° C							
	By Gas = 161.545 MKWH			By Oil = 46.539 MKWh		15. Export through East-West interconnections :							
	By Coal = 47.427 MKWH			By Hydro = 0.710 MKWh		At evening peak-hour : 11364 MW, at 19:30 hrs							
	By Solar = 1.779 MKWH					Maximum : 630 MW, at 21:00 hrs							
11.	Total Gas Supplied	:	1218.59	MMCFD		Energy : 0 MKWh							
(D) Forecast of 13.06.23 (Today) Tuesday :													
01.	Maximum Demand	:	14200	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	15476	MW	(Generation end)	05.	Total Generation	:	296.01	MKWh			
03.	Reserve / Shortage	:	1276	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	31.9° C					