

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month June, 2023					Day : Wednesday					Date : 14.06.23				
Probable Maximum Demand : 14200 MW					Probable Maximum Generation : 15213 MW					Rule Curve = 79.41 ft.				
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 73.26 ft					Today = 73.24 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	13.06.23 (Yesterday)		14.06.23 (Today)		13.06.23 (Yesterday)		14.06.23 (Today)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Water Limitation MW		Machines shut down (MW)			
					Day	Evening	Day	Evening						
(A) Plants in operation:														
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260		Under project work	
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	100	100	100	100	80			Gas Shortage	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	170	160	180	180					
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0					
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108			Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105			Gas Shortage	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0					
7	Haripur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	360	327	336	320	330					
8	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450					
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115		Under Overhauling	
10	Haripur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	412	395	400	400	400					
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	185	195	200	200					
12	Siddhirgonj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	320	38	320	320					
13	Meghnaghat CCGP(Summit)	Gas (IPP)	2x110+1x110	335	335	305	290	300	300					
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	0	30					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	74	82	92	92					
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	16	19	19	19					
17	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	44	44	48	48					
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33					
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	29	30	24	30					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	48	8	50					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	35	105	105	105					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	64	32	82					
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	35	0	35					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	47	148	45	145					
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	133	17	149					
26	Keraniganj 300 MW PP (APSC)	HSD (IPP)	25x12.4	300	300	200	270	300	300					
27	Bramhanaganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0					
28	Aurahat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	96	96	100	100					
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	35	35	55					
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	35	55					
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	72	92	53	92					
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	35	90	35	90					
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	33	0	30	0					
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	34	17	35					
35	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	73	78	68	92					
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	66	73	66	93					
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	97	97	96	97					
38	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	20	45	43	44	48					
Dhaka Zone Total					6104	5867	3355	3688	3572	4155	293	375		
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	55	55	50	55	175			Low water level	
40	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	111	109	110	110	71			Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180		Under maint.	
41	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	3	0	5	0					
42	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	25	8	25					
43	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	13	0	20	0					
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	5	48	50	50					
45	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	83	34	105					
46	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150		Under maint.	
47	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	215	223	225	225					
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	69	285	70	285					
49	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	50	25	50					
50	Dohazari-Kalash 100 MW Peaking	HFO (PDB)	6x17.0	102	102	50	51	51	51					
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	16	16	30	40					
52	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	12	0	11	14					
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	31	10	20					
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0					
54	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17					
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	28	23	17	34					
56	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	38	25	50					
57	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	33	33	33	33					
58	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	68	34	68					
59	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	36	163	72	163					
	SS Power Unit-1	Coal (IPP)				0	0	0	0					
	Cox's Bazar Wind PP	(Wind) (IPP)				6	10	13	10					
Chattogram Zone Total					2605	2545	763	1328	910	1405	246	330		
60	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	37	43	44	42					
61	Ashuganj 225 MW CCGP	Gas (APSCCL)	1x142+175	221	221	82	111	110	110		110		ST under maint.	
62	Ashuganj 450 MW CCGP(South)	Gas (APSCCL)	1x360	360	360	260	260	260	280					
63	Ashuganj 450 MW CCGP(North)	Gas (APSCCL)	1x361	360	360	310	275	300	300					
64	Ashuganj 420 MW CCGP(East)	Gas (APSCCL)	1x284+1x116	400	400	218	240	240	240	160			Gas Shortage	
65	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*116	195	195	8	8	45	187				Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51					
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	5	105	5	150					
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	30	36	40	40					
69	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163		Under maint.	
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	21	17	17					
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	20	20	20					
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11					
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	0	33	33					
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	43	26	43					
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	21	20	20					
76	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	97	114	100	114					
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	115	9	115					
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17					
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	50	96	72	97					
**	Impoctr (Tripura)	India		160	160	170	158	135	152					
Cumilla Zone Total					2904	2896	1452	1745	1518	1897	347	273		
80	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	26	48	50	50	154			Gas Shortage	
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	19	19					
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	19	85	19	85					
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	71	88	68	86					
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0					
85	Sutiakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	23	0	50	0					
86	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	12	12	12	12					
Mymensingh Zone Total					622	614	171	252	220	252	154	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	13.06.23 (Yesterday)		14.06.23 (Today)		13.06.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)		
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	42	43	43	43		27	GT-1 & ST-1 Under maint.	
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	31	30	30		59	GT-4 Under maint.	
89	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	44	47	50	50				
90	Kushiera 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	112	112		54	ST Under maint.	
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	8	11	11				
92	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	54	56	60	60				
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	69	72	72	76				
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	121	125	125	125		54	ST Under maint.	
96	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	0	0	0				
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	22	16	22				
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	315	310	310	320				
100	Bibiana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	388	390	400	400				
101	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	373	398	350	380				
102	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
103	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.4+5*2	50	50	45	42	45	45				
Sylhet Zone Total						2472	2427	1616	1666	1634	1684	0	624
104	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
105	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	160	135	180	180		275	Gas Shortage	
106	Fandipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	24	15	25				
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	6	45	25	72				
108	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	196	208	200	208				
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	73	54	54	54				
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	50	85	50	85				
111	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	79	0	100	0				
112	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	16	63	16	66				
113	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	8	40	8	40				
114	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	381	374	370	376		243	Coal Shortage	
115	Khulna 330 MW CCPP	Gas/HSD (BFDCL)				225	237	220	220				
**	Bheramara (HSDCL)	India		1000	1000	910	874	931	931				
Khulna Zone Total						2905	2901	2104	2139	2169	2257	518	0
115	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	32	48	16	48				
116	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	24	30	21	30				
117	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	155	173	170	170				
118	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	0	0	0	0		1244	Coal Shortage	
119	Potukhaili 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	150	17	150				
120	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	307	307	307	307				
121	Bhola 220MW CCPP (Nutan Bidyt BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	109	112	110	110		108	Under maint.	
Barishal Zone Total						2265	2285	644	820	641	815	1244	108
122	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage	
122	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.	
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	7	0	28				
124	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	191	0	200				
125	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	28	35	30	35				
126	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	75	40	80				
127	Katakhail 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	28	35	35	35				
128	Katakhail 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	34	34	25	34				
129	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	35	35	35	35				
130	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	150	103	150	150		107	Gas Shortage	
131	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0		220	Gas Shortage	
132	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	149	141	178	196		79	Gas Shortage	
133	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	393	367	380	414		47	Gas Shortage	
134	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	17	22	22	22				
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8				
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	43	0	43				
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	95	35	95				
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	95	35	95				
139	Aminura 30 MW PP (Sinha)	HFO (NENP)	7x7.79	50	28	28	28	28	28				
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6	0				
**	Adani Power Jharkhanda Ltd	Coal (Import)	1x748	748	748	756	0	550	748				
Rajshahi Zone Total						2927	2905	1700	1314	1557	2246	524	100
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	69	71	70	70			Coal Shortage	
141	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	230	230	230	230			Coal Shortage	
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	16				
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	34	71	35	71				
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Majpara, Tatulia 9 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0				
147	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6*20	115	115	36	115	35	115				
148	Lalmohanhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	15	0	30	0				
149	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	35	0	130	0				
Rangpur Zone Total						1030	950	425	487	538	502	0	85
Sub-total: Plants in operation						23834	23370	12230.0	13439	12759	15213	3326	1895
(B) Plants under long term maintenance/ contract expired													
150	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
151	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
152	Bosilia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
153	Ashuganj 45 MW PP (Precision)	Gas (RPP)	15*4	35	0	0	0	0	0				
Sub-total: Plants under long term maintenance/ contract expired						309	0	0	0	0	0	0	0
Gross Total						24143	23370	12230	13439	12759	15213	3326	1895
(C) Actual data of 13.06.23 (Yesterday) Tuesday :													
01.	Max. Demand at eve. peak (Generation end)	:	14400	MW,	at =	21:00 hrs	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	13589	MW,	at =	21:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply
03.	Highest Generation (Generation end)	:	13439	MW,	at =	21:00 hrs		MW	MW	MW		MW	MW
04.	Minimum Generation (Generation end)	:	10690	MW,	at =	8:00 hrs	Dhaka	5235	5055	180	Mymensingh	1107	997
05.	Day-peak Generation (Generation end)	:	12230	MW,	at =	12:00 hrs	Chattogram	1342	1172	170	Sylhet	576	556
06.	Evening-peak Generation (Generation end)	:	13439	MW,	at =	21:00 hrs	Khulna	1451	1351	100	Barishal	350	350
07.	Evening Peak Load-shed (Sub-station end)	:	918	MW,	at =	21:00 hrs	Rajshahi	1345	1205	140	Rangpur	839	689
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10443	MW,	at =	5:00 hrs	Cumilla	1344	1296	48			150
09.	Generation shortfall at evening peak due to :	:					Total						
	a) Gas/LF limitation	:	3151	MW			Total = 13589						
	d) Coal supply Limitation	:	0	MW			Total = 12671						
	b) Low water level in Kaptai lake	:	175	MW			Total = 1056179515						
	c) Plants under shut down/ maintenance	:	1895	MW			Total = 1056179515						
10.	Total Energy (Generation + India Import)	:	286.97	MW			Total = 1056179515						
	By Gas = 156.617 MKWH	By Oil =	63.979	MW			Total = 1056179515						
	By Coal = 38.689 MKWH	By Hydro =	0.743	MW			Total = 1056179515						
	By Solar= 1.994 MKWH						Total = 1056179515						
11.	Total Gas Supplied	:	1226.58	MMCFD			Total = 1056179515						
(D) Forecast of 14.06.23 (Today) Wednesday :													
01.	Maximum Demand	:	14200	MW	(Generation end)		04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)	
02.	Maximum Generation	:	15213	MW	(Generation end)		05.	Total Generation	:	303.22	MW		
03.	Reserve / Shortage	:	1013	MW	(Generation end)		06.	Probable Max. Temperature in Dhaka ;	:	35.1° C			