

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month June, 2023					Day : Friday					Date : 16.06.23				
Probable Maximum Demand : 14000 MW					Probable Maximum Generation : 14693 MW									
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 73.02 ft		Today = 72.95 ft		Rule Curve = 79.95 ft					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	15.06.23 (Yesterday)		16.06.23 (Today)		15.06.23 (Yesterday)		16.06.23 (Today)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Water Limitation MW		Machines shut down (MW)		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening						
(A) Plants in operation:														
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260		Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	100	100	100	100	80			Gas Shortage	
3	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	170	170	170	170					
4	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0					
5	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108			Gas Shortage	
6	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105			Gas Shortage	
7	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0					
8	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	324	323	330	330					
9	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450					
10	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115		Under Overhauling	
11	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	405	403	0	400					
12	Siddhirganj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	185	189	190	190					
13	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	317	325	320	320					
14	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	301	308	305	305					
15	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	0	30					
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	74	91	74	91					
17	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	15	15	19	19					
18	Sumit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	44	24	44	44					
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	33	33	33					
20	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	30	30	30	30					
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	24	8	24					
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	35	105	35	105					
23	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	115	16	115					
24	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	35	0	35					
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	48	155	48	148					
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	135	17	149					
27	Keraniganj 300 MW PP (APSC)	HSD (IPP)	25x12.4	300	300	299	109	300	300					
28	Bramhanaganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0					
29	Aurahat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	99	0	100	100					
30	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	55	35	55					
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	35	55					
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	71	91	53	92					
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	35	90	35	90					
34	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	25	0	30	0					
35	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	35	17	35					
36	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	75	88	75	90					
37	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	67	74	74	82					
38	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	97	86	96	97					
39	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	20	31	0	0	0					
Dhaka Zone Total					6104	5867	3465	3728	3039	4084	293	375		
40	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	25	25	50	50	205			Low water level	
41	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	114	110	110	110	70			Gas Shortage	
42	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180		Under maint.	
43	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	0	0	5	0					
44	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	25	8	25					
45	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	5	0	20	0					
46	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	14	50	6	50					
47	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	51	105	51					
48	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150		Under maint.	
49	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	222	225	225	225					
50	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	70	285	88	300					
51	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	25	25	25					
52	Dohazari-Kalash 100 MW Peaking	HFO (PDB)	6x17.0	102	102	34	51	51	51					
53	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	24	32	30	40					
54	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	11	11	11					
55	* Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	28	25	25					
56	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0					
57	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17					
58	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	34	17	34					
59	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	25	25	25					
60	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	23	23	23	23					
61	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	51	107	51	107					
62	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	36	163	36	163					
63	SS Power Unit-1	Coal (IPP)				0	0	0	0					
64	Cox's Bazar Wind PP	(Wind) (IPP)				3	11	13	10					
Chattogram Zone Total					2605	2545	724	1298	941	1342	275	330		
65	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	37	38	40	40					
66	Ashuganj 225 MW CAPP	Gas (APSCCL)	1x142+175	221	221	107	99	115	115		122		ST under maint.	
67	Ashuganj 450 MW CAPP(South)	Gas (APSCCL)	1x360	360	360	260	260	260	260					
68	Ashuganj 450 MW CAPP(North)	Gas (APSCCL)	1x361	360	360	330	310	310	310					
69	Ashuganj 420 MW CAPP(East)	Gas (APSCCL)	1x284+1x116	400	400	230	230	230	230	170			Gas Shortage	
70	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*116	195	195	8	8	8	8	187			Gas Shortage	
71	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51					
72	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	5	135	12	150					
73	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	25	29	40	40					
74	Chandpur 150 MW CAPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163		Under maint.	
75	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	17	17	17					
76	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	20	20					
77	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11					
78	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	25	33	33					
79	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	8	0	0					
80	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	12	20	20	20					
81	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	17	0	17					
82	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	96	9	95					
83	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	35	17	35					
84	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	36	95	36	115					
85	** Impocti (Tripura)	India		160	160	158	162	135	152					
Cumilla Zone Total					2904	2896	1383	1666	1364	1719	357	285		
86	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	24	5	30	50	197			Gas Shortage	
87	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	10	19	19	19					
88	Jamailpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	19	85	65	85					
89	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	68	40	18	86					
90	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0					
91	Sutiakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	36	0	50	0					
92	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	12	12	12	12					
Mymensingh Zone Total					622	614	171	161	196	252	197	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	15.06.23 (Yesterday)		16.06.23 (Today)		15.06.23 (Yesterday)		Status of Machines under shut-down/ Maintenance			
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :					
						Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)			Description/ Remarks	Probable start-up date
87	Fenchugonj CAPP Phase-1	Gas	2x32+1x33	97	70	42	42	43	43			28	GT-1 & ST-1 Under maint.		
88	Fenchugonj CAPP Phase-2	Gas	2x35+1x35	104	90	31	30	30	30			60	GT-4 Under maint.		
89	Fenchugonj 51 MW PP (Barakatullah)	Gas	(RPP)	19x2.90	51	51	50	47	50	50					
90	Kushiera 163 MW CAPP (KP)	Gas	(IPP)	1x109+1x54	163	163	112	112	112	112			54	ST Under maint.	
91	Hobigang 11MW PP Confidence-E	Gas	(SIPP, REB)	4x2.90	11	11	11	11	11	11					
92	Shahjibazar GTTP Unit- 8 & 9	Gas	(PDB)	2x35	70	66	50	48	60	60					
93	Shahjibazar 330 MW CAPP	Gas	(PDB)	2x110+1x110	330	330	0	0	0	0			330	Under maint.	
94	Shahjibazar 86MW PP (Shahjibazar)	Gas	(RPP)	32x2.90	86	86	72	76	72	76					
95	Sylhet 225 MW CAPP	Gas	(PDB)	1x142+1x89	231	231	128	127	129	129			54	ST Under maint.	
96	Sylhet 20 MW GTTP	Gas	(PDB)	1 x 20	20	20	0	0	0	0					
97	Sylhet 10MW PP (Desh)	Gas	(RPP)	6x1.95	10	10	10	10	10	10					
98	Shahjahanulla 25 MW PP	Gas	(CIPP, REB)	3x9.34	25	25	0	24	16	16					
99	Bibiana-II 341 MW CAPP (Summit)	Gas	(IPP)	1x222+1x119	341	341	310	295	300	320					
100	Bibiana-III 400 MW CAPP	Gas	(PDB)	1x285+1x115	400	400	0	366	280	280					
101	Bibiyana South 383 MW CAPP	Gas	(PDB)	1x252+1x131	383	383	385	388	400	400					
102	Shahjibazar 100 MW GTTP	Gas	(PDB)	1x100	100	100	0	0	0	0			100	Under project work	
103	Fenchugonj 44MW (Energyprima)	Gas	(NENP)	12*3.4+5*2	50	50	50	49	49	49					
Sylhet Zone Total						2472	2427	1251	1625	1562	1586	0	626		
104	Bheramara GTTP Unit- 3	HSD	(PDB)	1 x 20	20	16	0	0	0	0					
105	Bheramara 410 MW CAPP	Gas	(NWPGL)	1 x 278+1 x 132	410	410	150	160	185	185			250	Gas Shortage	
106	Fandipur 50 MW Peaking PP	HFO	(PDB)	8x6.98	54	54	16	24	15	25					
107	Gopalganj 100 MW Peaking PP	HFO	(PDB)	16x6.98	109	109	24	70	36	72					
108	Khulna 225 MW CAPP	HSD/ Gas	(NWPGL)	1 x 150+1x75	230	230	194	145	100	200					
109	Rupsha 105 MW PP (Orion rupsha)	HFO	(IPP)	6x18.445	105	105	54	54	54	73					
110	Madhumati 100 MW PP	HFO	(NWPGL)	6x18.415	105	105	50	85	50	85					
111	Mongla Orion 100 MW Solar PP	Solar	(IPP)	100	100	72	0	100	0						
112	Khulna 115 MW PP (KPCL-2)	HFO	(NENP)	7x17	115	115	44	93	46	92					
113	Noapara 40 MW PP (Khanjahan Ali)	HFO	(NENP)	5*8.5	40	40	8	32	8	32					
114	Maitree Super Thermal 1320 MW PP (U-1)	Coal	(BIFPCL)	1x617	617	617	376	376	370	375			241	Coal Shortage	
	Khulna 330 MW CAPP	Gas/HSD	(BFDCL)				83	351	330	330					
**	Bheramara (HSDC)	India		1000	1000	912	912	930	930						
Khulna Zone Total						2905	2901	1983	2302	2224	2399	491	0		
115	Barisal 110 MW PP (Summit)	HFO	(IPP)	7 x 17.076	110	110	32	48	16	48					
116	Bhola 33 MW PP (Venture)	Gas	(NENP)	1x34.50	40	40	19	32	21	35					
117	Bhola 225 MW CAPP	Gas	(PDB)	2x63+1x68	194	194	169	175	175	175					
118	Payra 1320 MW TPP	Coal	(BCPCL)	2x622	1244	1244	0	0	0	0			1244	Coal Shortage	
119	Potukhali 150MW PP (UPPL)	HFO	(IPP)	8x18.415+1x9.78	150	150	17	150	17	150					
120	Barisal Electric 307 MW	Coal	(IPP)	1x307	307	307	200	200	200	200					
121	Bhola 220MW CAPP (Nutan Bidyt BD Ltd)	Gas/HSD	(IPP)	2x75+1x70	220	220	34	111	110	110			109	Under maint.	
Barishal Zone Total						2265	2285	471	716	539	718	1244	109		
122	a) Baghabari 71 MW GTTP	Gas	(PDB)	1 x 71	71	71	0	0	0	0			71	Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas	(PDB)	1 x 100	100	100	0	0	0	0			100	Under maint.	
123	Baghabari 50 MW Peaking PP	HFO	(PDB)	6x8.9	52	52	0	28	0	25					
124	Baghabari 200 MW PP (Paramount)	HSD	(IPP)	135x1.6	200	200	103	0	0	200					
125	Bera 70 MW Peaking PP	HFO	(PDB)	9x8.29	71	71	21	28	30	35					
126	Chapainawabganj 100 MW Peaking PP	HFO	(PDB)	12x8.924	104	104	0	80	40	80					
127	Katakhali 50 MW Peaking PP	HFO	(PDB)	6x8.7	50	50	23	35	35	35					
128	Katakhali 50 MW PP (Northern)	HFO	(QRPP)	6x8.9	50	50	34	34	34	34					
129	Santahar 50 MW Peaking PP	HFO	(PDB)	6x8.7	50	50	0	35	35	35					
130	Sirajgonj 225MW CAPP Unit-1	Gas	(NWPGL)	1x150+1x75	210	210	174	173	180	180			37	Gas Shortage	
131	Sirajgonj 225MW CAPP Unit-2	Gas	(NWPGL)	1x150 + 1x75	220	220	0	0	0	0			220	Gas Shortage	
132	Sirajgonj 225MW CAPP Unit-3	Gas	(NWPGL)	1x141+1x79	220	220	146	147	135	145			73	Gas Shortage	
133	Sirajgonj 400 MW CAPP Unit-4	Gas	(IPP)	1x282+1x132	414	414	407	404	414	414					
134	Bogra 22 MW PP (GGB)	Gas	(RPP)	6x4.0	22	22	14	19	22	22					
135	Ullapara 11 MW PP (Summit)	Gas	(SIPP, REB)	4x2.90	11	11	8	8	8	8					
136	Natore 52 MW PP (Rajlanka)	HFO	(IPP)	6x8.92	52	52	0	43	0	43					
137	Bagura 113 MW (Confidence) U-1	HFO	(IPP)	6*18.55	113	113	35	55	35	55					
138	Bagura 113 MW PP (Confidence) U-2	HFO	(IPP)	6x18.55	113	113	35	50	35	50					
139	Aminura 30 MW PP (Sinhaj)	HFO	(NENP)	7x7.79	50	28	21	28	28	28					
140	Sirajgonj 6.55 MW Solar	Solar	(NWPGL)	1x6	6	6	4	0	6	0					
**	Adani Power Jharkhand Ltd	Coal	(Import)	1x748	748	748	746	746	748	748					
Rajshahi Zone Total						2927	2905	1771	1913	1785	2137	401	100		
141	a) Barapukuria TPP Unit-1	Coal	(PDB)	1 x 125	125	85	69	69	70	70					
	b) Barapukuria TPP Unit-2	Coal	(PDB)	1 x 125	125	85	0	0	0	0			85	Under Overhauling	
142	Barapukuria 275 MW TPP Unit-3	Coal	(PDB)	1 x 274	274	274	230	230	200	200					
143	Rangpur 20 MW GTTP	HSD	(PDB)	1 x 20	20	20	0	0	0	16					
144	Rangpur 113 MW PP (Confidence)	HFO	(IPP)	7*16x 2*3	113	113	28	40	35	55					
145	Saidpur 20 MW GTTP	HSD	(PDB)	1 x 20	20	20	0	0	0	0					
146	Majpara, Talaila 9 MW Solar PP (Sympa Power)	Solar	(IPP)	1 x 8	8	8	1	0	8	0					
147	Thakurgaon 19MW PP (Energypac)	HFO	(IPP)	6*20	115	115	35	115	35	115					
148	Lalmohanpur 30 MW Solar (Intraco)	Solar	(IPP)	1*30	30	30	0	0	30	0					
149	Teesta Solar Limited	Solar	(IPP)	1 x 200	200	200	105	0	130	0					
Rangpur Zone Total						1030	950	468	454	508	456	0	85		
Sub-total: Plants in operation						23834	23370	11687.0	13863	12158	14693	3258	1910		
(B) Plants under long term maintenance/ contract expired															
150	Jamulpur 95 MW PP (Powerpac)	HFO	(IPP)	12x8.924	95	0	0	0	0	0					
151	Katpotti 52 MW PP (Sinha)	HFO	(IPP)	7x7.90	51	0	0	0	0	0					
152	Bosilia 108MW PP (CLC)	HFO	(IPP)	12x8.775+1x3.5	108	0	0	0	0	0					
153	Ashuganj 45 MW PP (Fracion)	Gas	(RPP)	15*4	35	0	0	0	0	0					
Sub-total: Plants under long term maintenance/ contract expired						309	0	0	0	0	0	0	0		
Gross Total						24143	23370	11687	13863	12158	14693	3258	1910		
(C) Actual data of 15.06.23 (Yesterday) Thursday :															
01.	Max. Demand at eve. peak (Generation end)	:	14125	MW,	at =	21:00	hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	13518	MW,	at =	21:00	hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	13863	MW,	at =	21:00	hrs	Dhaka	5340	5320	20	Mymensingh	486	486	0
04.	Minimum Generation (Generation end)	:	10723	MW,	at =	9:00	hrs	Chattogram	1336	1336	0	Sylhet	447	447	0
05.	Day-peak Generation (Generation end)	:	11687	MW,	at =	12:00	hrs	Khulna	1908	1889	19	Barishal	447	447	0
06.	Evening-peak Generation (Generation end)	:	13863	MW,	at =	21:00	hrs	Rajshahi	1539	1539	0	Rangpur	584	584	0
07.	Evening Peak Load-shed (Sub-station end)	:	250	MW,	at =	21:00	hrs	Cumilla	1431	1220	211				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10686	MW,	at =	5:00	hrs								
09.	Generation shortfall at evening peak due to :	:													
a)	Gas/LF limitation	:	3053	MW				13.	Fuel cost :	(a) Gas = 172234464	(c) Coal = 38646334	Taka			
d)	Coal supply Limitation	:	0	MW						(b) Oil = 805235854	Total = 1016116652	Taka			
b)	Low water level in Kaptai lake	:	205	MW											
c)	Plants under shut down/ maintenance	:	1910	MW				14.	Maximum Temperature in Dhaka was :		34.1° C				
10.	Total Energy (Generation + India Import)	:	283.63	MKWh											