

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month June, 2023					Day : Saturday				Date : 17.06.23					
Probable Maximum Demand : 14500 MW					Probable Maximum Generation : 14928 MW									
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 72.95 ft				Today = 72.91 ft					
					Rule Curve = 80.22 ft									
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	16.06.23 (Yesterday)		17.06.23 (Today)		16.06.23 (Yesterday)		17.06.23 (Today)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Water Limitation MW		Machines shut down (MW)		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening						
(A) Plants in operation:														
1	Ghorasal Repowered CCP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260		Under project work	
a)	Ghorasal Repowered CCP Unit-4	Gas (PDB)	1 x 210	210	180	100	100	120	120	80			Gas Shortage	
b)	Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	170	180	180	180					
3	Ghorasal 365 MW CCP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0					
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108			Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105			Gas Shortage	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0					
7	Haripur 360MW CCP(HPL)	Gas (IPP)	1x235+1x125	360	360	323	346	330	330					
8	Meghnaghat 450 MW CCP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450					
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115		Under Overhauling	
10	Haripur 412 MW CCP	Gas (EGCB)	1x273+1x139	412	412	0	402	400	400					
11	Siddhirganj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	188	200	190	190					
12	Siddhirganj 335 MW CCP	Gas (EGCB)	1 x 217+1x118	335	335	317	337	320	320					
13	Meghnaghat CCP(Summit)	Gas (IPP)	2x110+1x110	335	335	283	310	305	305					
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	15	0	25					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	74	66	74	91					
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	19	19					
17	Summit Power(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	41	20	47	47					
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	25	33	33					
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	30	0	30	30					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	24	8	24					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	35	17	105	105					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	32	16	115					
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	35	0	35					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	52	64	48	148					
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	31	17	149					
26	Keraniganj 300 MW PP (APSC)	HSD (IPP)	25x8.4	300	300	302	0	300	300					
27	Bramhanaganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0					
28	Aurahat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	96	0	100	100					
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	35	35	55					
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	35	55					
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	73	0	53	92					
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	35	90	35	90					
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	20	0	30	0					
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	3	17	35					
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	75	10	75	90					
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	74	83	74	82					
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	92	22	96	97					
38	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	20	0	0	0	0					
Dhaka Zone Total					6104	5867	2973	2952	3542	4112	293	375		
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	30	30	55	55	200			Low water level	
a)	Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	111	110	110	110	70			Gas Shortage	
b)	Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180		Under maint.	
41	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	2	0	5	0					
42	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	25	8	25					
43	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	0	0	20	0					
44	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	6	6	50					
45	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	105	17	17	51					
46	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150		Under maint.	
47	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	224	226	225	225					
48	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	88	302	88	300					
49	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	25	25	25					
50	Dohazari-Kalash 100 MW Peaking	HFO (PDB)	6x17.0	102	102	49	34	17	34					
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	16	24	24	32					
52	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	12	10	11	11					
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			22	42	6	20					
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0					
54	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17					
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	34	17	34					
56	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	25	25	25					
57	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	23	23	23	23					
58	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	51	107	51	107					
59	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	36	163	36	163					
	SS Power Unit-1	Coal (IPP)				0	0	0	0					
	Cox's Bazar Wind PP	(Wind) (IPP)				9	6	13	10					
Chattogram Zone Total					2605	2545	876	1226	799	1317	270	330		
60	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	37	44	40	40					
61	Ashuganj 225 MW CAPP	Gas (APSCCL)	1x142+175	221	221	104	139	115	115					
62	Ashuganj 450 MW CAPP(South)	Gas (APSCCL)	1x360	360	360	260	300	260	260					
63	Ashuganj 450 MW CAPP(North)	Gas (APSCCL)	1x361	360	360	305	310	310	310					
64	Ashuganj 420 MW CAPP(East)	Gas (APSCCL)	1x284+1x116	400	400	235	300	230	230	100			Gas Shortage	
65	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+11*6	195	195	8	8	8	8	187			Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	46	51	51					
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	12	43	5	150					
68	Titaf 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	23	29	40	40					
69	Chandpur 150 MW CAPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163		Under maint.	
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	17	17	17					
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	19	20	20					
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11					
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	0	33	33					
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	0	0	0					
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	17	0	20	20					
76	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	17	114					
77	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	95	9	95					
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17					
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	36	115	36	115					
**	Import (Tripura)	India		160	160	150	72	135	152					
Cumilla Zone Total					2904	2896	1334	1565	1374	1798	287	163		
80	RPCL 210MW CAPP	Gas (IPP)	4x35+1x70	210	202	26	39	30	50	163			Gas Shortage	
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	0	19	19					
82	Jamailpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	69	85	18	85					
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	18	28	68	86					
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0					
85	Sutiakehi 50 MW Solar PP	Solar (IPP)	1x50	50	50	29	0	50	0					
86	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	12	2	12	12					
Mymensingh Zone Total					622	614	174	154	199	252	163	0		

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	16.06.23 (Yesterday)		17.06.23 (Today)		16.06.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening				
87	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	42	42	43	43		28	GT-1 & ST-1 Under maint.
88	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	41	41	40	40		49	GT-4 Under maint.
89	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	45	50	50	50			
90	Kushiera 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	112	112		54	ST Under maint.
91	Hobgaj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	5	11	11			
92	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	50	50	60	60			
93	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	72	75	72	76			
95	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	127	127	100	200		54	ST Under maint.
96	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	0	0	0			
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10			
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16			
99	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	320	300	320			
100	Bibiana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	317	364	300	350			
101	Bibiana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	394	400	400	400			
102	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work
103	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12'3.3x5'2	50	50	49	49	49	49			
Sylhet Zone Total					2472	2427	1586	1661	1563	1737	0	615
104	Bheramara 410 MW CAPP	HSD (PDB)	1 x 20	20	16	0	0	0	0			
105	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	295	290	300	300		120	Gas Shortage
106	Fendipur 50 MW Peaking PP	HFO (PDB)	8x6.38	54	54	14	0	15	25			
107	Coxalganj 100 MW Peaking PP	HFO (PDB)	16x6.38	109	109	25	0	36	72			
108	Khulna 225 MW CAPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	15	40	100	200			
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	54	27	73	73			
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	50	50	50	85			
111	Mongla Orion 100 MW Solar PP	Solar (IPP)	100	100	100	53	0	100	0			
112	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	44	32	66	92			
113	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	0	32	8	32			
114	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	372	377	370	370		240	Coal Shortage
**	Khulna 330 MW CAPP	Gas/HSD (BFDCL)	1000	1000	914	863	930	930	930			
Khulna Zone Total					2905	2901	2090	1966	2298	2429	360	0
115	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	32	40	16	48			
116	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	18	29	25	29			
117	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	173	174	175	175			
118	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	0	0	0	0		1244	Coal Shortage
119	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	19	17	150			
120	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	200	200	200	200			
121	Bhola 220MW CAPP (Nutan Bidyt BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	107	107	110	110		113	Under maint.
Barishal Zone Total					2265	2285	547	569	543	712	1244	113
122	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage
122	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	35	0	25			
124	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	30	0	0	200			
125	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	28	0	30	35			
126	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	0	40	80			
127	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	35	35			
128	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	25	0	34	34			
129	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	35	35	35	35			
130	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	194	180	200	190			
131	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0		220	Gas Shortage
132	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	136	140	140	135		80	Gas Shortage
133	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	418	416	414	414			
134	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	13	21	0	0			
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8			
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	0	43			
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6'x18.55	113	113	35	50	35	55			
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	50	35	50			
139	Aminura 50 MW PP (Sinha)	HFO (NENP)	7x7.79	50	28	0	0	28	28			
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	0	0	6	0			
**	Adani Power Jharkhand Ltd	Coal (Import)	1x748	748	748	752	579	748	748			
Rajshahi Zone Total					2927	2905	1709	1514	1788	2115	371	100
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	66	66	70	70			Coal Shortage
141	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	200	200	200			Coal Shortage
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	16			
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	34	56	35	55			
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
146	Majpara, Talaila 9 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	3	0	8	0			
147	Thakurgaon 19MW PP (Energypac)	HFO (IPP)	6'20	115	115	35	45	35	115			
148	Lalmohan 30 MW Solar (Intraco)	Solar (IPP)	1'30	30	30	17	0	30	0			
149	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	136	0	130	0			
Rangpur Zone Total					1030	950	491	367	508	456	0	85
Sub-total: Plants in operation					23834	23370	11780.0	11974	12614	14928	2988	1781
(B) Plants under long term maintenance/ contract expired												
150	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			
151	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			
152	Bosilia 108MW PP(ELC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			
153	Ashuganj 45 MW PP (Fracion)	Gas (RPP)	15'4	35	0	0	0	0	0			
Sub-total: Plants under long term maintenance/ contract expired					309	0	0	0	0	0	0	0
Gross Total					24143	23370	11780	11974	12614	14928	2988	1781
(C) Actual data of 16.06.23 (Yesterday) Friday :												
01.	Max. Demand at eve. peak (Generation end)	:	11974 MW, at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	11512 MW, at =	21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	12522 MW, at =	23:00 hrs	Dhaka	3794	3794	0	Mymensingh	695	695	0
04.	Minimum Generation (Generation end)	:	10686 MW, at =	6:00 hrs	Chattogram	1261	1261	0	Sylhet	369	369	0
05.	Day-peak Generation (Generation end)	:	11780 MW, at =	12:00 hrs	Khulna	1857	1857	0	Barishal	467	467	0
06.	Evening-peak Generation (Generation end)	:	11974 MW, at =	21:00 hrs	Rajshahi	1378	1378	0	Rangpur	740	740	0
07.	Evening Peak Load-shed (Sub-station end)	:	0 MW, at =	21:00 hrs	Cumilla	951	951	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10806 MW, at =	5:00 hrs					Total	11512	11512	0
09.	Generation shortfall at evening peak due to :	:			13.	Fuel cost :	(a) Gas = 171800754 Taka	(c) Coal = 34582597 Taka				
a) Gas/LF limitation	:	2788 MW					(b) Oil = 626322435 Taka	Total = 832705786 Taka				
d) Coal supply Limitation	:	0 MW										
b) Low water level in Kaptai lake	:	200 MW										
c) Plants under shut down/ maintenance	:	1781 MW			14.	Maximum Temperature in Dhaka was :	35.5° C					
10.	Total Energy (Generation + India Import)	:	272.68 MKWh		15.	Export through East-West interconnections :						
	By Gas = 153.690 MKWh	By Oil = 53.754 MKWh				At evening peak-hour	:	11780 MW, at	21:00 hrs			
	By Coal = 37.334 MKWh	By Hydro = 0.671 MKWh				Maximum	:	74 MW, at	21:00 hrs			
	By Solar = 2.182 MKWh					Energy	:	0 MKWh				
11.	Total Gas Supplied	:	1217.10 MMCFD									
(D) Forecast of 17.06.23 (Today) Saturday :												
01.	Maximum Demand	:	14500 MW (Generation end)		04.	Maximum Load-shed	:	0 MW	At evening peak (Sub-station end)			
02.	Maximum Generation	:	14928 MW (Generation end)		05.	Total Generation	:	315.75 MKWh				
03.	Reserve / Shortage	:	428 MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	35.5° C					

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation