

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month June, 2023					Day : Sunday					Date : 18.06.23				
Probable Maximum Demand : 14500 MW					Probable Maximum Generation : 15074 MW									
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 72.91 ft		Today = 73.17 ft		18.06.23		Rule Curve = 80.49 ft			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	17.06.23 (Yesterday)		18.06.23 (Today)		17.06.23 (Yesterday)		18.06.23 (Today)		Status of Machines under shut-down/ Maintenance	Probable start-up date
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Machines shut down (MW)			
					Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation MW		Description/ Remarks			
(A) Plants in operation:														
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work		
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	120	120	120	120	60		Gas Shortage		
3	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180					
4	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0					
5	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108		Gas Shortage		
6	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage		
7	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0					
8	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	320	348	330	330					
9	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	420	450	450					
10	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling		
11	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	401	385	400	400					
12	Siddhirganj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	190	203	200	200					
13	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	317	333	330	330					
14	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	279	310	305	305					
15	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	4	15	15	30					
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	49	42	74	92					
17	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	13	0	19	19					
18	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	35	30	47	47					
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33					
20	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	28	16	30	30					
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	4	8	24					
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	105	50	105	105					
23	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	48	16	16	115					
24	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	35	0	35					
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	47	15	48	148					
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	33	17	149					
27	Keraniganj 300 MW PP (APSC)	HSD (IPP)	25x8.4	300	300	25	0	300	300					
28	Bramhanaganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0					
29	Aurahat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	25	0	100	100					
30	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	20	35	55					
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	17	35	55					
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	72	70	53	92					
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	35	65	35	90					
34	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	29	0	30	0					
35	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	18	17	35					
36	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	70	9	75	90					
37	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	66	92	74	92					
38	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	78	34	96	97					
39	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	20	0	0	0	0					
Dhaka Zone Total					6104	5867	3114	2913	3577	4148	273	375		
40	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	30	30	30	30	200		Low water level		
41	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	109	110	110	110	70		Gas Shortage		
42	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.		
43	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	0	0	5	0					
44	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	1	25	8	25					
45	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	13	0	20	0					
46	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	47	6	50					
47	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	17	17	51					
48	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Under maint.		
49	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	228	228	225	225					
50	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	88	280	88	300					
51	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	25	25	25					
52	Dohazari-Kalash 100 MW Peaking	HFO (PDB)	6x17.0	102	102	34	34	34	34					
53	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	32	33	24	32					
54	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	12	11	11					
55	* Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	35	6	20					
56	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0					
57	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17					
58	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	34	17	34					
59	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	25	25	25					
60	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	23	23	23	23					
61	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	51	107	51	107					
62	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	18	54	36	163					
63	SS Power Unit-1	Coal (IPP)				0	0	0	0					
64	Cox's Bazar Wind PP	(Wind) (IPP)				16	2	13	10					
Chattogram Zone Total					2605	2545	752	1138	791	1292	270	330		
65	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	33	45	40	40					
66	Ashuganj 225 MW CAPP	Gas (APSCCL)	1x142+175	221	221	124	49	185	185					
67	Ashuganj 450 MW CAPP(South)	Gas (APSCCL)	1x360	360	360	275	290	275	275					
68	Ashuganj 450 MW CAPP(North)	Gas (APSCCL)	1x361	360	360	285	295	310	310					
69	Ashuganj 420 MW CAPP(East)	Gas (APSCCL)	1x284+1x116	400	400	240	270	260	260	130		Gas Shortage		
70	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*116	195	195	8	8	8	8	187		Gas Shortage		
71	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51					
72	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	3	50	5	150					
73	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	26	41	40	40					
74	Chandpur 150 MW CAPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163		Under maint.		
75	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	17	17	17					
76	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	19	20	20					
77	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11					
78	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	25	33	33					
79	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	0	0	0					
80	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	0	20	20					
81	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	34	17	114					
82	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	46	97	9	95					
83	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17					
84	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	35	115	36	115					
85	** Impocti (Tripura)	India		160	160	166	158	135	152					
Cumilla Zone Total					2904	2896	1417	1592	1489	1913	317	163		
86	RPCL 210MW CAPP	Gas (IPP)	4x35+1x70	210	202	33	49	30	50	153		Gas Shortage		
87	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	19	19					
88	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	18	85	19	85					
89	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	68	32	68	86					
90	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0					
91	Sutiakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	11	0	50	0					
92	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	12	0	12	12					
Mymensing Zone Total					622	614	144	166	200	252	153	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	17.06.23 (Yesterday)		18.06.23 (Today)		17.06.23 (Yesterday)		Status of Machines under shut-down/ Maintenance		
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :				
						Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)			
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	42	42	43	43		28	GT-1 & ST-1 Under maint.		
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	40	40		48	GT-4 Under maint.		
89	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	47	47	50	50					
90	Kushiera 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	112	112		54	ST Under maint.		
91	Hobigaj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11					
92	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	50	50	60	60					
93	Shajbazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.		
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	72	73	72	76					
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	21	100	190	200					
96	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	0	0	0					
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10					
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16					
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	300	0	300					
100	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	310	260	340	350					
101	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	400	400	400	400					
102	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work		
103	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12'3.3x5'2	50	50	50	49	49	49					
Sylhet Zone Total						2472	2427	1470	1509	1393	1717	0	560	
104	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0					
105	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	340	330	250	330		80	Gas Shortage		
106	Fendipur 50 MW Peaking PP	HFO (PDB)	8x6.38	54	54	0	24	15	25					
107	Gogalganj 100 MW Peaking PP	HFO (PDB)	16x6.38	109	109	0	0	36	72					
108	Khulna 225 MW CCPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	145	120	100	200					
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	53	35	73	73					
110	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	32	45	50	85					
111	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	45	0	100	0					
112	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	35	16	66	92					
113	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	8	8	16	32					
114	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	372	378	370	370		239	Coal Shortage		
115	Khulna 330 MW CCPP	Gas/HSD (BPOB)		1000	1000	348	206	250	250					
**	Bheramara (HSDC)	India		1000	1000	913	814	928	928					
Khulna Zone Total						2905	2901	2291	1976	2254	2457	319	0	
115	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	32	32	16	48					
116	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	16	27	25	29					
117	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	175	177	175	175					
118	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	0	0	0	0		1244	Coal Shortage		
119	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	23	17	150					
120	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	295	158	200	200					
121	Bhola 220MW CCPP (Nutan Bidyt BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	110	110	110	110		110	Under maint.		
Barishal Zone Total						2265	2285	645	527	543	712	1244	110	
122	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage		
122	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.		
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	7	0	25					
124	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	200					
125	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	14	0	30	35					
126	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	49	40	80					
127	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	36	0	35	35					
128	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	25	8	34	34					
129	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	35	35	35					
130	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	205	175	200	190					
131	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150+1x75	220	220	0	0	0	0		220	Gas Shortage		
132	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	165	133	140	135		87	Gas Shortage		
133	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	422	421	414	414					
134	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	0	0	0	0					
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	0	8	8					
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	0	43					
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6'18.55	113	113	35	55	35	55					
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	44	35	50					
139	Aminura 30 MW PP(Sinhia)	HFO (NENP)	7x7.79	50	28	0	0	28	28					
140	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	5	0	6	0					
**	Adani Power Jharkhanda Ltd	Coal (Import)	1x748	748	748	739	721	760	760					
Rajshahi Zone Total						2927	2905	1689	1556	1800	2127	378	100	
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	64	64	70	70			Coal Shortage		
141	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling		
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	200	200	200			Coal Shortage		
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	16					
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	34	70	35	55					
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
146	Majpara, Tatulia 9 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	4	0	8	0					
147	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6'20	115	115	5	75	35	115					
148	Lalmohanhat 30 MW Solar (Intraco)	Solar (IPP)	1'30	30	30	29	0	30	0					
149	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	187	0	130	0					
Rangpur Zone Total						1030	950	523	409	508	456	0	85	
Sub-total: Plants in operation						23834	23370	12045.0	11886	12555	15074	2954	1723	
(B) Plants under long term maintenance/ contract expired														
150	Jamulpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0					
151	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0					
152	Bosilia 108MW PP (CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0					
153	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	35	0	0	0	0	0					
Sub-total: Plants under long term maintenance/ contract expired						309	0	0	0	0	0	0	0	
Gross Total						24143	23370	12045	11886	12555	15074	2954	1723	
(C) Actual data of 17.06.23 (Yesterday) Saturday :														
01.	Max. Demand at eve. peak (Generation end)	:	11886	MW,	at =	21:00 hrs	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	11499	MW,	at =	21:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	12410	MW,	at =	22:00 hrs	MW	MW	MW	MW	MW	MW	MW	MW
04.	Minimum Generation (Generation end)	:	10806	MW,	at =	6:00 hrs	Dhaka	3903	3903	0	Mymensingh	717	717	0
05.	Day-peak Generation (Generation end)	:	12045	MW,	at =	12:00 hrs	Chattogram	1237	1237	0	Sylhet	381	381	0
06.	Evening-peak Generation (Generation end)	:	11886	MW,	at =	21:00 hrs	Khulna	1580	1580	0	Barishal	454	454	0
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW,	at =	21:00 hrs	Rajshahi	1231	1231	0	Rangpur	784	784	0
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10534	MW,	at =	5:00 hrs	Cumilla	1212	1212	0				
09.	Generation shortfall at evening peak due to :	:					Total							
a)	Gas/LF limitation	:	2754	MW			Total							
d)	Coal supply Limitation	:	0	MW			Total =							
b)	Low water level in Kaptai lake	:	200	MW			Total =							
c)	Plants under shut down/ maintenance	:	1723	MW			Total =							
10.	Total Energy (Generation + India Import)	:	281.69	MKWh			Total =							
	By Gas = 161.252 MKWH						Total =							
	By Coal = 38.592 MKWH						Total =							
	By Solar= 2.031 MKWH						Total =							
11.	Total Gas Supplied	:	1220.93	MMCFD			Total =							
(D) Forecast of 18.06.23 (Today) Sunday :														
01.	Maximum Demand	:	14500	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)			
02.	Maximum Generation	:	15074	MW	(Generation end)	05.	Total Generation	:	329.13	MKWh				
03.	Reserve / Shortage	:	574	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	35.6° C					