

POWER GRID COMPANY OF BANGLADESH LTD.
NATIONAL LOAD DESPATCH CENTER
DAILY REPORT

Till now the maximum generation is :-		15648.0		21:00	Hrs on 18-Apr-23	Reporting Date : 20-Jun-23	
The Summary of Yesterday's		19-Jun-23		Generation & Demand		Today's Actual Min Gen. & Probable Gen. & Demand	
Day Peak Generation	11449.0 MW	Hour :	12:00	Min. Gen. at	6:00	10500	
Evening Peak Generation	13456.0 MW	Hour :	19:30	Available Max Generation		14664	
E.P. Demand (at gen end)	13540.0 MW	Hour :	19:30	Max Demand (Evening)		14200	
Maximum Generation	13456.0 MW	Hour :	19:30	Reserve(Generation end)		444	
Total Gen. (MW)	285.5	System Load Factor	88.41%	Load Shed		0	

Export from East grid to West grid > Maximum		1010	MW	at	22:00	Energy
Import from West grid to East grid > Maximum						Energy
Actual :	Water Level of Kaptai Lake at 6:00 A.M on 75.02	FL(MSL)		Rule curve :	81.03	FL(MSL)

Gas Consumed :	Total =	1225.02	MMCFD.	Oil Consumed (POB) :		HSD :
						FO :
Cost of the Consumed Fuel (POB+PVI) :	Gas :	Tk179,240,008		Oil :	Tk611,410,823	Total :
	Coal :	Tk39,307,704				Tk829,958,534

Load Shedding & Other Information						
Area	Yesterday		Estimated Demand (S/S end)	Today	Estimated Shedding (S/S end)	Rates of Shedding (On Estimated Demand)
	MW		MW		MW	
Dhaka	20	0.00	6384		0	0%
Chittagong Area	0	0.00	1400		0	0%
Khulna Area	0	0.00	1962		0	0%
Raishahi Area	0	0.00	1706		0	0%
Cumilla Area	10	0.00	1404		0	0%
Mymensingh Area	50	0.00	1044		0	0%
Sylhet Area	0	0.00	585		0	0%
Barisal Area	0	0.00	488		0	0%
Rangpur Area	0	0.00	954		0	0%
Total	80		14627		0	

Information of the Generating Units under shut down.	
Planned Shut-Down	Forced Shut-Down
	1) Barapokhara ST Unit-2 2) Ghorasal-3,7 3) Bhola Nulon Bidist GT 4) Baghabari/71, 100 MW 5) Razzan unit-2 6) Siddhirganj 210 MW 7) Shahbaz 330 MW

Outage Time	Restore Time	Additional Information of Machines, lines, Interruption / Forced Load shed etc.	Remark
08:17	18:44	Chandrachona 132/33kV S/S TR-01(406T) LT Project Work S/D Due to Blastwall finishing, chipping and painting by CCCE.	
08:18	18:43	Chandrachona 132/33kV S/S TR-01(406T) HT Project Work S/D Due to Blastwall finishing, chipping and painting by CCCE.	
08:24		khulna 225 MW CAPP ST Tripped due to drum level low.	
	08:38	Purbasadipur 132/33kV S/S T-3 Transformer (422T) HT is restored.	
08:55	10:10	Siraiganj 132/33kV S/S T4-(445) HT Forced S/D Due to Red hot bolt replace at 132 kv bus DS	14.0MW load interrup.
09:06	11:59	Gollamari 132/33kV S/S T1-2 LT Project Work S/D Due to NLDC control, testing.	
09:07	11:58	Gollamari 132/33kV S/S T1-2 HT Scheduled S/D Due to NLDC control, testing.	
09:18		Boq-Sherpur 132/33kV S/S Transformer-1 (404T) HT is restored.	
09:19		Boq-Sherpur 132/33kV S/S Transformer-2 (414T) HT is restored.	
09:42		Jamalpur 132/33kV S/S T-3 LT Scheduled S/D Due to 132 kv T-3 transformer replacement work	
09:42		Jamalpur 132/33kV S/S T-3 HT Scheduled S/D Due to 132 kv T-3 transformer replacement work	
	10:37	Hathazari 230/132/33kV S/S MT-04 LT is restored.	
	10:37	Hathazari 230/132/33kV S/S MT-04 HT is restored.	
10:40	15:50	Sreepur 230/132/33kV S/S 230/132 kv T-1 LT Project Work S/D Due to Transformer maintenance	
10:40	15:50	Sreepur 230/132/33kV S/S 230/132 kv T-1 HT Project Work S/D Due to Transformer maintenance	
	11:15	Ruppur 132/11kV S/S TR-02 LT is restored.	
11:15	16:07	Chattak-Sylhet 132 kv Ckt-2 Scheduled S/D from Chhatk 132/33kV end. and from Sylhet 132/33kV end Due to SPMD Maintenance	
11:30		Ruppur 132/11kV S/S TR-02 LT Tripped showing Overcurrent relays Due to Over current, R-phase=5 KA	
12:00		Day Peak Gen. 11450 MW	
12:04	13:22	Gollamari 132/33kV S/S T1-1 LT Project Work S/D Due to NLDC Control & Signal Testing.	
12:05	13:21	Gollamari 132/33kV S/S T1-1 HT Project Work S/D Due to NLDC Control & Signal Testing.	
12:11	12:58	Naogaon 132/33kV S/S T-2 LT Forced S/D Due to Red hot Maintenance.	18.0MW load interrup.
12:12	12:57	Naogaon 132/33kV S/S T-2 HT Forced S/D Due to Red hot Maintenance.	
12:12		Khulna 225MW ST was sync.	
12:16	12:36	Brahmanbaria-Shahibazar 132 kv Ckt-2 Tripped from Shahibazar 132/33kV end showing Distance relays Due to Badweatther and from Brahmanbaria 132/33kV end showing Distance, relays Due to Fault	
12:40		Jashore 132/33kV S/S T-3 LT Forced S/D Due to T3 transformer air Compressor gas leakage maintenance	
13:02	15:52	Raishahi 132/33kV S/S 132 kv PPP 50 Mw Forced S/D	
13:14		Ishurdi 132/33kV T2 transformer tripped. Interruption 57MW.	
	13:18	Sonargaon 132/33kV S/S T1-2 HT is restored.	
13:39	15:03	Gollamari 132/33kV S/S E07 Gollamari-Gopalganj Line - 2 Project Work S/D Due to NLDC Control Signal Testing	
13:48	16:47	Ishurdi 132/33kV S/S 132/33 kv T-2 HT Forced S/D Due to NESCO 33kv live DS open problem.	50.0MW load interrup.
13:49	17:02	Brahmanbaria 132/33kV S/S 403T LT Forced S/D Due to For Shut down of mechanically stucked 33 kv Ghatura feeder.	
13:49	13:56	Brahmanbaria 132/33kV S/S 402T LT Forced S/D Due to For Shut down of mechanically stucked 33 kv Ghatura feeder.	30.0MW load interrup.
14:06	14:51	Baerhat 132/33kV S/S Transformer-2 (413 T) LT Forced S/D	7.0MW load interrup.
14:08	14:50	Baerhat 132/33kV S/S Transformer-2 (413 T) HT Forced S/D Due to 33kv bus shutdown.	7.0MW load interrup.
	15:04	Gopalganj 132/33kV S/S Gallamari-1 is restored.	
15:08	16:19	Gollamari-Khulna (S) 132kV Ckt-2 Project Work S/D from Gollamari 132/33kV end Due to NLDC control signal testing and from Khulna(S) 230/132kV end.	
16:07	17:22	Chattak-Sylhet 132 kv Ckt-1 Scheduled S/D from Sylhet 132/33kV end Due to SD Request by AE, Sylhet SS direction by NLDC (299724) and from Chhatk 132/33kV end Due to svi-chhatk ckt-1 is S/D.	
16:19	17:22	Mahashangarh 132/33kV S/S 406T MTR 1 LT Forced S/D	10.0MW load interrup.
16:20	17:21	Mahashangarh 132/33kV S/S 406T MTR 1 HT Forced S/D	
17:31		Bhola CAPP ST was forced shutdown	
18:40		Meghna Old-New 230kv bus-1 first time charged	
19:30		Evening Peak generation = 13,456MW	
21:43	22:42	Shahadpur 132/33kV S/S T-2(415T) HT Forced S/D Due to Red hot maintenance	
21:50		Fenchuzari 230/132/33kV S/S TR-02 HT Tripped showing MCGG relays Due to Cable earth fault due to distribution feeder	17.0MW load interrup.
03:45	03:54	Jamalpur United (20MW)- Sherpur 132kV Ckt-2 Tripped from Sherpur 132/33kV end showing Micom P443 relays.	
05:19		From NLDC, Siddhirganj GT 2x120 MW Unit-1 tripped	
06:00		Minimum Generation :10600 MW	
07:03		Palashbari 132/33kV S/S TR-2(404T) LT Forced S/D Due to 33 kv CT Y phase red hot maintenance	
07:03		Palashbari 132/33kV S/S TR-2(404T) HT Forced S/D Due to 33 kv CT Y phase red hot maintenance	
07:42		Madaripur 132/33kV S/S T1-405T HT Scheduled S/D Due to 33kv Ishibchor feeder source side red hot maintenance	
07:55		Bhandaria 132/33kV S/S Transformer-2 LT Scheduled S/D Due to Red hot maintenance	18.0MW load interrup.

Sub Divisional Engineer
Network Operation Division

Executive Engineer
Network Operation Division

Superintendent Engineer
Load Despatch Circle