

**Bangladesh Power Generation Board
DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation
Tel: 9564667, 9551095

Month June, 2023		Day: Wednesday				Date: 21.06.23						
Probable Maximum Demand :		14200 MW		Probable Maximum Generation :		14460 MW						
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 75.02 ft		Today = 75.20 ft		Rule Curve = 81.30 ft						
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	20.06.23 (Yesterday)		21.06.23 (Today)		20.06.23 (Yesterday) Gen. shortfall for : Gas/Coal/oil/Water Limitation MW	21.06.23 (Today) Machines shut down (MW)	Status of Machines under shut-down/ Maintenance Description/ Remarks	Probable start-up date
					Actual Peak Generation (MW)		Probable Peak Generation (MW)					
					Day	Evening	Day	Evening				
(A) Plants in operation:												
1	Ghorasal Repowered CAPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CAPP Unit-4	Gas (PDB)	1 x 210	210	180	120	120	120	120	60	Gas Shortage	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	170	170	180	180			
3	Ghorasal 365 MW CAPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0			
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	3x3.35	108	108	0	0	0	0	108	Gas Shortage	
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Haripur 360MW CAPP(HPL)	Gas (IPP)	1x235+1x125	360	360	328	292	340	340			
8	Meghnaghat 450 MW CAPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450			
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Haripur 412 MW CAPP	Gas (EGCB)	1x273+1x139	412	412	402	406	390	400			
11	Siddhirganj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	96	197	200	200			
12	Siddhirganj 335 MW CAPP	Gas (EGCB)	1 x 217+1x118	335	335	323	329	330	330			
13	Meghnaghat CAPP(Summit)	Gas (IPP)	2x110+1x110	335	335	270	300	305	305			
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	25	15	30			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	58	91	74	92			
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	10	22	22			
17	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, PDB)	8x3.67+7x8.73	80	80	46	42	42	42			
18	Maona 33 MW PP(Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33			
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, PDB)	4x8.73	33	33	22	24	24	24			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	25	8	25			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	52	34	52			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	48	16	64			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	35	0	35			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	47	148	48	148			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	132	17	149			
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	110	158	300	300			
27	Aurahi 100MW PP (Aggriko)	HSD (IPP)	23x0.85+91x.959	100	100	100	100	100	100			
28	Nabaganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	55	35	35	55			
29	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	35	55			
30	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	72	91	73	92			
31	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	35	90	35	90			
32	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	29	0	30	0			
33	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	34	17	35			
34	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	75	92	75	90			
35	Meghnaghat 100 MW(IEEL)	HFO (NENP)	12x8.9	100	100	67	75	67	75			
36	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	80	85	80	95			
37	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	100	75	0	0	0			
Dhaka Zone Total			6004	5822	3096	3744	3495	4028	273	375		
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	60	65	65	165		Low water level	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	110	110	110	70		Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	2	0	5	0			
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	25	8	25			
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	20	0	20	0			
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	50	6	50			
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	51	17	51			
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
46	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	219	223	225	225			
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	88	279	88	300			
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	25	25	25			
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	34	34	34	34			
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	16	32	32	40			
51	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	12	12	12	12			
*	Malancha, Clq EPZ (United)	Gas	5x8.73+3x9.34			2	23	3	25			
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0			
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17			
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	34	17	34			
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	21	21	21	21			
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	23	23	23	23			
57	Chattogram 116 MW PP (Anlima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	34	68	34	68			
58	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	18	54	18	163			
	SS Power Unit-1	Coal (IPP)				0	0	0	0			
	Cox's Bazar Wind PP	(Wind) (IPP)				3	5	13	10			
Chattogram Zone Total			2605	2545	744	1151	793	1298	235	330		
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	33	46	46	46			
60	Ashuganj 225 MW CAPP	Gas (APSCCL)	1x142+1*75	221	221	197	171	170	170			
61	Ashuganj 450 MW CAPP(South)	Gas (APSCCL)	1x360	360	360	260	260	260	260			
62	Ashuganj 450 MW CAPP(North)	Gas (APSCCL)	1x361	360	360	280	285	300	300			
63	Ashuganj 420 MW CAPP(East)	Gas (APSCCL)	1x284+1x116	400	400	240	240	240	240	160	Gas Shortage	
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	0	0	0	195	195	Gas Shortage	
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	43	51	51			
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	5	128	5	150			
67	Tilas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	13	31	40	40			
68	Chandpur 150 MW CAPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under maint.	
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	34	51	34	50			
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	20	20	20			
71	Feni 11 MW PP (Doreen)	Gas (SIPP, PDB)	4x2.90	11	11	11	11	11	11			
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	25	25	25			
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	0	0	0			
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, PDB)	3x3.67+2x6.97	25	25	15	15	15	20			
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	16	114	114	114			
76	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	98	9	95			
77	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	9	17	17			
78	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	36	73	36	115			
**	limpoort (Tirpura)	India		160	160	150	152	129	152			
Cumilla Zone Total			2904	2896	1411	1772	1522	1876	355	163		
79	RPCL 210MW CAPP	Gas (IPP)	4x35+1x70	210	202	25	52	30	55	150	Gas Shortage	
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	17	19	19			
81	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	19	85	19	85			
82	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	67	87	68	86			
83	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0			
84	Sutakhalai 50 MW Solar PP	Solar (IPP)	1x50	50	50	30	0	50	0			
85	Tangail 22 MW PP(RPCL)	HFO (IPP)	4x6.7	22	22	12	12	12	12			
Mymensingh Zone Total			622	614	171	253	200	257	150	0		

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	20.06.23 (Yesterday)		21.06.23 (Today)		20.06.23 (Yesterday)		Status of Machines under shut-down/ Maintenance									
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date								
					Day	Evening	Day	Evening	Gas/Coal/Water Limitation MW	Machines shut down (MW)										
86	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43	27	GT-1 & ST-1 Under maint.									
87	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	41	42	42	42	48	GT-4 Under maint.									
88	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	47	50	50	50											
89	Kushliara 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	112	112	54	ST Under maint.									
90	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	5	5	5											
91	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	61	60	60											
92	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	330	Under maint.									
93	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	3x2.90	86	86	81	81	81	81											
94	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	211	0	0	130											
95	Sylhet 20 MW GTPP	Gas (PDB)	1x 20	20	20	0	0	0	0											
96	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10											
97	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16											
98	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	300	300	300											
99	Bibyana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	241	240	240	240											
100	Bibyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	400	398	400	400											
101	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0	100	Under project work									
102	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.4*5*2	50	50	45	50	50	50											
Sylhet Zone Total					2472	2427	1602	1408	1415	1545	0	559								
103	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0											
104	Bheramara 410 MW CAPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	205	225	240	240	185	Gas Shortage									
105	Fairdipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	25	15	25											
106	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	67	36	80											
107	Khulina 225 MW CAPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	225	230	205	220	200	220											
108	Rupsha 105 MW PP (Oron rupsha)	HFO (IPP)	6x18.445	105	105	70	54	73	73											
109	Madhumatoli 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	15	50	15	50											
110	Mongla Orin 100 MW Solar PP	Solar (IPP)	100	100	98	0	100	0												
111	Khulina 115 MW PP (KPC-2)	HFO (NENP)	7x17	115	115	61	81	49	98											
112	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	16	40	16	32											
113	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	376	375	320	320	242	Coal Shortage									
114	Khulina 330 MW CAPP (GT)	Gas/HSD	1x220	220	220	250	354	206	206											
**	Bheramara (HVDC)	India	1000	1000	912	788	930	930												
Khulina Zone Total					3125	3121	2208	2279	2200	2274	427	0								
115	Barsal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	48	16	48											
116	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	18	27	25	29											
117	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	130	130	130	130											
118	Payra 1320 MW TAPP	Coal (BCPCL)	2x622	1244	1244	0	0	0	0	1244	Coal Shortage									
119	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	150	17	150											
120	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	150	150	150	150											
121	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	111	108	110	110	112	Under maint.									
Barishal Zone Total					2265	2265	442	613	448	617	1244	112								
122	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage									
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Under maint.									
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	35	0	35											
124	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	200											
125	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	28	30	35											
126	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	83	40	80											
127	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	35	35											
128	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	0											
129	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	35	35	35											
130	Sirajgonj 225MW CAPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	142	205	190	190											
131	Sirajgonj 225MW CAPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	0	0	0	0	220	Gas Shortage									
132	Sirajgonj 225MW CAPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	130	156	165	160	64	Gas Shortage									
133	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	415	420	414	414											
134	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	0	0	0	0											
135	Ulapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	5	8	8											
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	43	0	43											
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	55	35	55											
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	50	35	50											
139	Amnura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	0	0											
140	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	1	0	6	0											
**	Adani Power Jharkhanda Ltd	Coal (Import)	1x748	748	748	1058	765	760	760											
Rajshahi Zone Total					2927	2905	1821	1912	1753	2100	355	100								
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	71	70	70	70		Coal Shortage									
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overhauling									
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	230	230	230	230		Coal Shortage									
143	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0											
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	34	49	35	50											
145	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0											
146	Meghna Talila 6 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 6	6	6	0	0	8	0											
147	Teaagun 119MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	115	35	115											
148	Lalmohith 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	7	0	30	0											
149	Teesa Solar Limited	Solar (IPP)	1 x 200	200	200	113	0	130	0											
Rangpur Zone Total					1030	950	455	464	538	465	0	85								
Sub-total: Plants in operation					23954	23545	11950.0	13596	12364	14460	3039	1724								
(B) Plants under long term maintenance/ contract expired																				
150	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0											
151	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0											
152	Bosilia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0											
153	Kapraonj 45 MW PP (Francisco)	Gas (RPP)	15*4	45	0	0	0	0	0											
Sub-Total: Plants under long term maintenance/ contract expired					309	0	0	0	0	0	0	0								
Gross Total					24263	23545	11950	13596	12364	14460	3039	1724								
(C) Actual data of 20.06.23 (Yesterday) Tuesday :																				
01.	Max. Demand at eve. peak (Generation end)	: 13596 MW, at = 21:00 hrs	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :																	
02.	Max. Demand at eve. peak (Sub-station end)	: 12956 MW, at = 21:00 hrs	Zone		Supply			Load Shed			Zone		Demand		Supply		Load Shed			
03.	Highest Generation (Generation end)	: 13596 MW, at = 21:00 hrs	Dhaka		Chattoagram			Khulina			Rajshahi		Cumilla		Total		Total			
04.	Minimum Generation (Generation end)	: 10600 MW, at = 6:00 hrs	4737		1368			1629			1424		1226		12956		12956			
05.	Day-peak Generation (Generation end)	: 11950 MW, at = 12:00 hrs	0		0			0			0		0		0		0			
06.	Evening-peak Generation (Generation end)	: 13596 MW, at = 21:00 hrs	0		0			0			0		0		0		0			
07.	Evening Peak Load-shed (Sub-station end)	: 0 MW, at = 21:00 hrs	0		0			0			0		0		0		0			
08.	Minimum Generation Forecast up to 8:00 hrs.	: 10667 MW, at = 5:00 hrs	0		0			0			0		0		0		0			
09.	Generation shortfall at evening peak due to :	:	Total = 12956										12956		0					
a)	Gas/LF limitation	: 2874 MW	Fuel cost : (a) Gas = 175216940 Taka (c) Coal = 39116688 Taka										889837431 Taka							
d)	Coal supply Limitation	: 0 MW	(b) Oil = 675503803 Taka																	
b)	Low water level in Kaptai lake	: 165 MW	Maximum Temperature in Dhaka was : 35.0° C																	
c)	Plants under shut down/ maintenance	: 1724 MW	Export through East-West interconnections :																	
10.	Total Energy (Generation + India Import)	: 284.48 MMKWh	By Gas = 157.722 MMKWh		By Oil = 55.201 MMKWh		By Coal = 43.376 MMKWh		By Hydro = 1.476 MMKWh		By Solar = 1.542 MMKWh		At evening peak-hour : 11950 MW, at 21:00 hrs		Maximum : 1010 MW, at 22:00 hrs		Energy : 0 MMKWh			
11.	Total Gas Supplied	: 1202.91 MMCFD																		
(D) Forecast of 21.06.23 (Today) Wednesday :																				
01.	Maximum Demand	: 14200 MW (Generation end)	04. Maximum Load-shed : 0 MW At evening peak (Sub-station end)																	
02.	Maximum Generation	: 14460 MW (Generation end)	05. Total Generation : 297.11 MMKWh																	
03.	Reserve / Shortage	: 260 MW (Generation end)	06. Probable Max. Temperature in Dhaka : 35.0° C																	

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation