

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9554567, 9551095

Month June, 2023				Day : Friday				Date : 23.06.23				
Probable Maximum Demand : 13800 MW				Probable Maximum Generation : 14615 MW								
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 75.22 ft		Today = 75.25 ft		23.06.23 (Today)		Rule Curve = 81.84 ft.		
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Dered/ Present Capacity (MW)	22.06.23 (Yesterday)		23.06.23 (Today)		22.06.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)	Probable Peak Generation (MW)	Probable Peak Generation (MW)	Gen. shortfall for :				
								Day	Evening	Day		Evening
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	120	110	170	170	70	Gas Shortage	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	170	100	100			
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0			
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108	Gas Shortage	
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage	
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	327	327	340	340			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450			
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	395	403	390	400			
11	Siddhirganj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	194	193	200	200			
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	322	326	330	330			
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	305	308	305	305			
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	30	15	30			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	50	50	74	92			
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	17	14	22			
17	Summit Power, Madhabdi-Ashulia	Gas (SIPP, REB)	8x3.67+7x8.73	80	80	45	43	45	45			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	24	24	24	24			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	25	8	25			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	70	34	70			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	64	16	64			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	35	0	35			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	47	148	48	148			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	132	17	149			
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	102	305	300	300			
27	Aurahat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	96	100	100	100			
28	Nabaganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	55	35	55			
29	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	35	55			
30	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	72	72	73	92			
31	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	35	90	35	90			
32	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	20	0	30	0			
33	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	34	17	35			
34	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	65	45	75	90			
35	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	66	9	67	75			
36	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	38	51	80	95			
37	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	0	0	0			
Dhaka Zone Total				6004	5822	3111	3774	3460	4019	283	375	
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	65	68	60	60	162	Low water level	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	110	106	110	110	74	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	5	0	5	0			
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	25	8	25			
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	15	0	20	0			
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	19	46	19	50			
44	Sikalbaha 105 MW PP (Baraka Sikabaha)	HFO (IPP)	6x18.415	105	105	17	51	17	51			
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	223	225	225	225			
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	88	298	88	300			
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	25	25	25			
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	34	34	34	34			
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	16	23	32	40			
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	13	13	13	13			
*	Malancha, Clp EPZ (United)	Gas	5x8.73+3x9.34			2	22	10	25			
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0			
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17			
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	34	17	34			
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	12	12	21	21			
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRP)	8x13.45	100	100	23	23	23	23			
57	Chattogram 116 MW PP (Anilima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	51	34	68			
58	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	0	0	0	0			
	SS Power Unit-1	Coal (IPP)				0	0	0	0			
	Cox's Bazar Wind PP	(Wind) (IPP)				13	3	18	10			
Chattogram Zone Total				2605	2545	739	1076	796	1131	236	330	
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	20	20	20	20			
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	177	174	200	200			
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	220	220	260	260			
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	280	280	300	300			
63	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	240	240	260	260	160	Gas Shortage	
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*116	195	195	0	0	0	0	195	Gas Shortage	
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51			
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	6	140	5	150			
67	Tilas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	19	37	40	40			
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under maint.	
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	51	105	50	100			
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	20	20			
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11			
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	32	25	32			
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	42	43	43	43			
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	6	6	15	20			
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	95	114	114	114			
76	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	115	9	95			
77	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	35	35			
78	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	36	115	36	115			
**	Imphort (Tripura)	India		160	160	166	150	129	152			
Cumilla Zone Total				2904	2896	1491	1890	1623	2018	355	163	
79	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	26	46	30	55	156	Gas Shortage	
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	19	19			
81	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	28	85	19	85			
82	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	68	88	68	86			
83	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	0	0	1.6	0			
84	Sutiekhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	18	0	50	0			
85	Tangail 22 MW PP(RPCL)	HFO (IPP)	4x6.7	22	22	0	5	12	12			
Mymensing Zone Total				622	614	159	243	200	257	156	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	22.06.23 (Yesterday)		23.06.23 (Today)		22.06.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)	Probable Peak Generation (MW)	Gen. shortfall for : Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date		
												Day	Evening
86	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43	27	GT-1 & ST-1 Under maint.		
87	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	41	40	42	42	50	GT-4 Under maint.		
88	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	50	47	50	50				
89	Kushnara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	112	112	54	ST Under maint.		
90	Hobiganj 11MW PP Confidence-E	Gas (SI/PP, REB)	4x2.90	11	11	5	5	11	11				
91	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	58	60	60	60				
92	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	330	Under maint.		
93	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	78	81	81	81				
94	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	132	135	135	135				
95	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0	20	Under maint.		
96	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
97	Shahjahanulla 25 MW PP	Gas (CI/PP, REB)	3x9.34	25	25	16	16	16	16				
98	Bibiya-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	320	300	300				
99	Bibiya-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	353	365	300	350				
100	Bibiya South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	390	360	400	400				
101	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0	100	Under project work		
102	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.4+5*2	50	50	44	50	50	50				
Sylhet Zone Total						2472	2427	1622	1644	1610	581		
103	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
104	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	180	145	205	205	265	Gas Shortage		
105	Fairdipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	14	18	20	25				
106	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	23	81	36	80				
107	Khulna 225 MW CCPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	224	223	226	226				
108	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	54	54	54	54				
109	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	15	50	15	50				
110	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	22	0	100	0				
111	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	32	80	49	98				
112	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	32	16	32				
113	Maitree Super Thermal 1320 MW PP (U-I)	Coal (BIFPCL)	1x617	617	617	307	324	320	320	293	Coal Shortage		
114	Khulna 330 MW CCPP (GT)	Gas/HSD (BPDB)	1x220	220	220	315	315	314	315				
**	Bheramara (HVDC)	India		1000	1000	911	806	930	930				
Khulna Zone Total						3125	3121	2097	2128	2285	558	0	
115	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	32	48	16	48				
116	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	19	27	25	29				
117	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	130	130	130	130				
118	Payra 1320 MW TTP	Coal (BCPCL)	2x622	1244	1244	0	0	0	0	1244	Coal Shortage		
119	Potukhalhi 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	150	17	150				
120	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	150	150	150	150				
121	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	110	110	110	110	110	Under maint.		
Barishal Zone Total						2265	2265	458	615	448	617	1244	
122	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage		
123	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Under maint.		
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	35	21	35	35				
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	3	204	0	200				
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	28	30	35				
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	93	40	93				
128	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	35	35	35				
129	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	0				
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	35	35	35				
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	173	167	190	190				
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	0	0	0	0	220	Gas Shortage		
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	150	147	160	160	73	Gas Shortage		
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	420	418	414	414				
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	0	0	0	0				
136	Ullapara 11 MW PP (Summit)	Gas (SI/PP, REB)	4x2.90	11	11	8	8	8	8				
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	43	0	43				
138	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	55	35	55				
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	50	35	50				
140	Aminura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	0	0				
141	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	3	0	6	0				
**	Adani Power Jharkhanda Ltd	Coal (Import)	1x748	748	748	762	756	760	760				
Rajshahi Zone Total						2927	2905	1624	2060	1783	2113	364	
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	70	68	70	70		Coal Shortage		
143	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overhauling		
144	Barapukuria 275 MW TTP Unit-3	Coal (PDB)	1 x 274	274	274	230	230	230	230		Coal Shortage		
145	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	35	49	35	50				
147	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
148	Majmaera, Talsia 9 MW Solar PP (Syma Power)	Solar (IPP)	1 x 8	8	8	3	0	8	0				
149	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6*20	115	115	19	115	35	115				
150	Lalmoharhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	18	0	30	0				
151	Treesta Solar Limited	Solar (IPP)	1 x 200	200	200	43	0	130	0				
Rangpur Zone Total						1030	950	418	462	538	465	0	
Sub-total: Plants in operation						23954	23545	11719.0	13892	12743	14615	3196	
(B) Plants under long term maintenance/ contract expired													
152	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
153	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
154	Bosolia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
155	Ashuvinay 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	0	0	0	0				
Sub-total: Plants under long term maintenance/ contract expired						309	0	0	0	0	0	0	
Gross Total						24263	23545	11719	13892	12743	14615	3196	
(C) Actual data of 22.06.23 (Yesterday) Thursday :													
01.	Max. Demand at eve. peak (Generation end)	:	14250 MW, at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :								
02.	Max. Demand at eve. peak (Sub-station end)	:	13637 MW, at =	21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW	
03.	Highest Generation (Generation end)	:	13892 MW, at =	21:00 hrs	Dhaka	5111	5061	50	Mymensingh	1045	1005	40	
04.	Minimum Generation (Generation end)	:	10954 MW, at =	9:00 hrs	Chattogram	1311	1311	0	Sylhet	520	478	42	
05.	Day-peak Generation (Generation end)	:	11719 MW, at =	12:00 hrs	Khulna	1616	1426	190	Barishal	410	410	0	
06.	Evening-peak Generation (Generation end)	:	13892 MW, at =	21:00 hrs	Rajshahi	1363	1363	0	Rangpur	858	858	0	
07.	Evening Peak Load-shed (Sub-station end)	:	342 MW, at =	21:00 hrs	Cumilla	1403	1383	20					
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10590 MW, at =	5:00 hrs					Total	13637	13295	342	
09.	Generation shortfall at evening peak due to :	:											
	a) Gas/LF limitation	:	3034 MW										
	b) Coal supply Limitation	:	0 MW										
	c) Low water level in Kaptai lake	:	162 MW										
	d) Plants under shut down/ maintenance	:	1744 MW										
10.	Total Energy (Generation + India Import)	:	284.30 MCKWh										
	By Gas = 160.102 MCKWh		By Oil = 59.622 MCKWh										
	By Coal = 36.230 MCKWh		By Hydro = 1.485 MCKWh										
	By Solar = 1.612 MCKWh												
11.	Total Gas Supplied	:	1235.92 MMCFD										
(D) Forecast of 23.06.23 (Today) Friday :													
01.	Maximum Demand	:	13800 MW (Generation end)		04.	Maximum Load-shed	:	0 MW	At evening peak (Sub-station end)				
02.	Maximum Generation	:	14615 MW (Generation end)		05.	Total Generation	:	282.42 MCKWh					
03.	Reserve / Shortage	:	815 MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	:	33.6° C					