

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9554567, 9551095

Month June, 2023				Day : Saturday				Date : 24.06.23				
Probable Maximum Demand : 14500 MW				Probable Maximum Generation : 14837 MW								
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 75.25 ft		Today = 75.31 ft		24.06.23 (Today)		Rule Curve = 82.11 ft.		
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Dered/ Present Capacity (MW)	23.06.23 (Yesterday)		24.06.23 (Today)		23.06.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW			
					Day	Evening	Day	Evening	Machines shut down (MW)	Description/ Remarks		Probable start-up date
(A) Plants in operation:												
1	Ghorasal Repowered CCP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCP Unit-4	Gas (PDB)	1 x 210	210	180	140	160	160	160	20	Gas Shortage	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	100	100	100	100			
3	Ghorasal 365 MW CCP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0			
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	32	32	32	76	Gas Shortage	
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage	
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Haripur 360MW CCP(HPL)	Gas (IPP)	1x235+1x125	360	360	327	342	340	340			
8	Meghnaghat 450 MW CCP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450			
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Haripur 412 MW CCP	Gas (EGCB)	1x273+1x139	412	412	398	390	400	400			
11	Siddhirganj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	187	191	200	200			
12	Siddhirganj 335 MW CCP	Gas (EGCB)	1 x 217+1x118	335	335	322	323	330	330			
13	Meghnaghat CCP(Summit)	Gas (IPP)	2x110+1x110	335	335	300	313	305	305			
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	15	15	30			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	42	91	74	92			
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	14	14	14	22			
17	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	8x3.67+7x8.73	80	80	25	45	45	45			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	23	24	24	24			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	24	8	25			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	105	34	105			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	64	16	64			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	35	0	35			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	47	148	48	148			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	123	17	149			
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	300	300			
27	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	60	0	100	100			
28	Nabaganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	55	35	55			
29	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	35	55			
30	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	54	72	73	92			
31	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	35	90	35	90			
32	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	32	0	30	0			
33	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	34	17	35			
34	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	41	50	75	90			
35	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	0	42	67	75			
36	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	51	51	80	95			
37	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	100	75	0	0	0			
Dhaka Zone Total				6004	5822	2808	3471	3492	4076	201	375	
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	60	60	60	60	170	Low water level	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	110	108	110	110	72	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	3	0	5	0			
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	25	8	25			
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	5	0	20	0			
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	6	19	50			
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	51	17	51			
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
46	Sikalbaha 225 MW CCP	Gas (PDB)	1 x 150+1 x 75	225	225	219	224	225	225			
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	88	290	88	300			
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	25	25	25			
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	34	34	34	34			
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	16	32	32	40			
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	10	12	13	13			
*	Malancha, Clp EPZ (United)	Gas	5x8.73+3x9.34			20	42	10	25			
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0			
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17			
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	34	17	34			
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	12	12	21	21			
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRP)	8x13.45	100	100	23	23	23	23			
57	Chattogram 116 MW PP (Anilma Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	51	34	68			
58	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	0	0	0	0			
	SS Power Unit-1	Coal (IPP)				0	0	0	0			
	Cox's Bazar Wind PP	(Wind) (IPP)				14	4	18	10			
Chattogram Zone Total				2605	2545	721	1050	796	1131	242	330	
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	20	20	20	20			
60	Ashuganj 225 MW CCP	Gas (APSCL)	1x142+1*75	221	221	165	210	200	200			
61	Ashuganj 450 MW CCP(South)	Gas (APSCL)	1x360	360	360	200	310	310	310			
62	Ashuganj 450 MW CCP(North)	Gas (APSCL)	1x361	360	360	265	335	300	330			
63	Ashuganj 420 MW CCP(East)	Gas (APSCL)	1x284+1x116	400	400	390	401	300	300			
64	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	0	0	0	0	195	Gas Shortage	
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51			
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	5	145	5	150			
67	Tilas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	28	30	40	40			
68	Chandpur 150 MW CCP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under maint.	
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	51	100	50	100			
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	20	20			
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	11	11			
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	0	32	25	32			
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	4	42	43	43			
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	6	12	15	20			
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	112	70	114	114			
76	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	57	9	113			
77	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	17	35	35			
78	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	30	101	36	115			
**	Impoget (Tripura)	India		160	160	158	158	129	152			
Cumilla Zone Total				2904	2896	1559	2121	1713	2156	195	163	
79	RPCL 210MW CCP	Gas (IPP)	4x35+1x70	210	202	26	49	30	55	153	Gas Shortage	
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	19	19			
81	Jamailpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	19	85	19	85			
82	Myensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	68	87	68	86			
83	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
84	Sutiaikhat 50 MW Solar PP	Solar (IPP)	1x50	50	50	51	0	50	0			
85	Tangail 22 MW PP(PPLCL)	HFO (IPP)	4x6.7	22	22	12	12	12	12			
Myensingh Zone Total				622	614	197	252	200	257	153	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	23.06.23 (Yesterday)		24.06.23 (Today)		23.06.23 (Yesterday)		Status of Machines under shut-down/ Maintenance		
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Machines shut down (MW)	Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening					
86	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 & ST-1 Under maint.		
87	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	40	40	42	42		50	GT-4 Under maint.		
88	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	47	47	50	50					
89	Kushlira 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	113	112	112		54	ST Under maint.		
90	Hobiganj 11MW PP Confidence-E	Gas (SI/PP, REB)	4x2.90	11	11	5	5	11	11					
91	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	60	60	60					
92	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.		
93	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	82	86	81	81					
94	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	137	136	135	135					
95	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	0	0	0		20	Under maint.		
96	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10					
97	Shahjahanulla 25 MW PP	Gas (CI/PP, REB)	3x9.34	25	25	16	8	16	16					
98	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	310	300	300	300					
99	Bibiya-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	404	333	350	360					
100	Bibiya South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	379	376	400	400					
101	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work		
102	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.4+5*2	50	50	44	46	50	50					
Sylhet Zone Total						2472	2427	1689	1603	1660	1670	0	581	
103	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0					
104	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	195	280	220	220	130		Gas Shortage		
105	Fairdipor 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	9	21	20	25					
106	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	34	75	36	80					
107	Khulna 225 MW CCPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	120	220	226	226					
108	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	54	53	54	54					
109	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	15	50	15	50					
110	Mongla Orion 100 MW Solar PP	Solar (IPP)	100	100	29	0	100	0						
111	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	32	96	49	98					
112	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	8	16	32					
113	Maitree Super Thermal 1320 MW PP (U-I)	Coal (BIFPCL)	1x617	617	617	323	297	320	320	320		Coal Shortage		
114	Khulna 330 MW CCPP (GT)	Gas/HSD (BPDB)	1x220	220	220	314	314	314	315					
**	Bheramara (HVDC)	India		1000	1000	912	912	929	929					
Khulna Zone Total						3125	3121	2037	2326	2299	2349	450	0	
115	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	32	48	16	48					
116	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	17	26	25	29					
117	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	130	130	130	130					
118	Payra 1320 MW TTP	Coal (BCPCL)	2x622	1244	1244	0	0	0	0	1244		Coal Shortage		
119	Potulakhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	150	17	150					
120	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	150	150	150	150					
121	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	111	110	110	110		110	Under maint.		
Barishal Zone Total						2265	2265	457	614	448	617	1244	110	
122	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage		
123	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Under maint.		
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	38	35	38					
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	200					
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	21	28	30	35					
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	76	40	93					
128	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	28	35	35					
129	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	0					
129	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	35	35	35					
130	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	150	180	190	190					
131	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage		
132	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	150	189	160	160					
133	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	326	414	414	414					
134	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	0	0	0	0					
135	Ullapara 11 MW PP (Summit)	Gas (SI/PP, REB)	4x2.90	11	11	8	8	8	8					
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	16	0	43					
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	55	35	55					
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	50	35	50					
139	Aminura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	0	0					
140	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	3	0	6	0					
**	Adani Power Jharkhanda Ltd	Coal (Import)	1x748	748	748	761	764	760	760					
Rajshahi Zone Total						2927	2905	1489	1881	1783	2116	291	100	
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	69	67	70	70			Coal Shortage		
142	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling		
143	Barapukuria 275 MW TTP Unit-3	Coal (PDB)	1 x 274	274	274	200	200	230	230			Coal Shortage		
144	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	34	34	35	50					
146	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
147	Majma, Talsia 9 MW Solar PP (Syma Power)	Solar (IPP)	1 x 9	9	9	0	0	8	0					
148	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6*20	115	115	35	114	35	115					
149	Lalmohith 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	34	0	30	0					
149	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	190	0	130	0					
Rangpur Zone Total						1030	950	562	415	538	465	0	85	
Sub-total: Plants in operation						23954	23545	11519.0	13733	12929	14837	2776	1744	
(B) Plants under long term maintenance/ contract expired														
150	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0					
151	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0					
152	Bosilia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0					
153	Ashuvin 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	0	0	0	0					
Sub-Total: Plants under long term maintenance/ contract expired						309	0	0	0	0	0	0	0	
Gross Total						24263	23545	11519	13733	12929	14837	2776	1744	
(C) Actual data of 23.06.23 (Yesterday) Friday :														
01.	Max. Demand at eve. peak (Generation end)	:	13860 MW, at =	21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :								
02.	Max. Demand at eve. peak (Sub-station end)	:	13116 MW, at =	21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW		
03.	Highest Generation (Generation end)	:	13733 MW, at =	21:00 hrs	Dhaka	4690	4672	18	Mymensingh	1074	971	103		
04.	Minimum Generation (Generation end)	:	10590 MW, at =	8:00 hrs	Chattogram	1288	1288	0	Sylhet	505	505	0		
05.	Day-peak Generation (Generation end)	:	11519 MW, at =	12:00 hrs	Khulna	1560	1560	0	Barishal	403	403	0		
06.	Evening-peak Generation (Generation end)	:	13733 MW, at =	21:00 hrs	Rajshahi	1416	1416	0	Rangpur	892	892	0		
07.	Evening Peak Load-shed (Sub-station end)	:	121 MW, at =	21:00 hrs	Cumilla	1289	1289	0						
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10901 MW, at =	5:00 hrs										
09.	Generation shortfall at evening peak due to :	:												
	a) Gas/LF limitation	:	2606 MW											
	d) Coal supply Limitation	:	0 MW											
	b) Low water level in Kaptai lake	:	170 MW											
	c) Plants under shut down/ maintenance	:	1744 MW											
10.	Total Energy (Generation + India Import)	:	273.62 MMKWh											
	By Gas = 153.750 MMKWh		By Oil = 54.407 MMKWh											
	By Coal = 35.901 MMKWh		By Hydro = 1.405 MMKWh											
	By Solar= 2.733 MMKWh													
11.	Total Gas Supplied	:	1243.70 MMCFD											
(D) Forecast of 24.06.23 (Today) Saturday :														
01.	Maximum Demand	:	14500 MW (Generation end)		04.	Maximum Load-shed	:	0 MW	At evening peak (Sub-station end)					
02.	Maximum Generation	:	14837 MW (Generation end)		05.	Total Generation	:	288.91 MMKWh						
03.	Reserve / Shortage	:	337 MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	:	35.5° C						

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation