

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9554567, 9551095

Month June, 2023		Day : Sunday		Date : 25.06.23										
Probable Maximum Demand : 14800 MW		Probable Maximum Generation : 14080 MW												
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 75.31 ft	Today = 75.32 ft	Rule Curve = 82.30 ft										
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Dered/ Present Capacity (MW)	24.06.23 (Yesterday)		25.06.23 (Today)		24.06.23 (Yesterday)		25.06.23 (Today)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Machines shut down (MW)		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW					
(A) Plants in operation:														
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0			260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	110	200	180	180					
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	0	0	0			115	Under maint.	
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0					
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	67	60	70	41			Gas Shortage	
5	Tong 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105			Gas Shortage	
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0					
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	332	332	330	330					
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450					
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0			115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	391	391	400	400					
11	Siddhirganj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	191	195	200	200					
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	322	328	330	330					
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	306	305	305	305					
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	25	15	25					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	42	75	74	75					
16	Narsinghdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	16	14	16					
17	Summit Power, Madhabdi-Ashulia	Gas (SIPP, REB)	8x3.67+7x8.73	80	80	44	44	45	45					
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33					
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	15	24	24	24					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	25	8	25					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	105	34	105					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	64	16	64					
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	35	0	35					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	47	153	48	150					
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	133	17	133					
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	155	300	300	300					
27	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	75	33	20	20					
28	Nabaganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	35	35	55					
29	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	35	55					
30	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	54	72	70	72					
31	Manikganj 162MW PP(MPL)	HFO (IPP)	9x18	162	162	35	90	35	90					
32	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	33	0	30	0					
33	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	34	17	35					
34	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	41	50	40	40					
35	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	33	33	30	33					
36	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	2	32	30	32					
37	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	100	75	0	0	0					
Dhaka Zone Total			6004	5822	3036	3734	3225	3727	146	490				
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	65	65	60	65	165			Low water level	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	110	107	110	110	73			Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0			180	Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	3	0	5	0					
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	25	8	25					
42	Teknaf 20MW PP (Solutech)	Solar (IPP)	1x20	20	20	0	0	20	0					
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	50	19	50					
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	51	17	51					
45	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0			150	Under maint.	
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	223	224	225	225					
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	88	280	88	280					
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	25	12	12					
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	16	17	17	17					
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	24	24	20	24					
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	10	12	12	12					
*	Malancha, Clp EPZ (United)	Gas	5x8.73+3x9.34			2	30	10	20					
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0					
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17					
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	34	17	34					
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	12	12	12	12					
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRP)	8x13.45	100	100	23	23	23	23					
57	Chattogram 116 MW PP (Anilima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	51	34	51					
58	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	0	0	0	0					
SS	Power Unit-1	Coal (IPP)				0	0	0	0					
	Cox's Bazar Wind PP	(Wind) (IPP)				18	3	18	10					
Chattogram Zone Total			2605	2545	693	1050	744	1038	238	330				
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	20	45	20	45					
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	208	208	200	210					
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	270	300	300	300					
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	275	305	300	330					
63	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	350	270	270	270					
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	0	0	0	0	195			Gas Shortage	
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51					
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	6	138	5	150					
67	Tilas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	14	28	30	35					
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0			163	Under maint.	
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	52	103	50	100					
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	20	20	20					
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	11	11					
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	32	32	25	32					
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	25	0	8					
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	12	12	12	12					
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	96	95	95	95					
76	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	86	9	86					
77	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	31	35	35					
78	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	59	115	36	115					
**	limpori (Tripura)	India		160	160	150	140	129	152					
Cumilla Zone Total			2904	2896	1648	2012	1998	2057	195	163				
79	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	28	44	30	50	158			Gas Shortage	
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	18	18	18					
81	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	19	85	19	85					
82	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	68	88	68	86					
83	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0					
84	Sutiekhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	0	0	0	0					
85	Tangail 22 MW PP(RPCL)	HFO (IPP)	4x6.7	22	22	12	12	12	12					
Mymensingh Zone Total			622	614	198	247	199	251	158	0				

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	24.06.23 (Yesterday)		25.06.23 (Today)		24.06.23 (Yesterday)		Status of Machines under shut-down/ Maintenance					
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Description/ Remarks	Probable start-up date				
					Day	Evening	Day	Evening	Machines shut down (MW)							
86	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43	27	GT-1 & ST-1 Under maint.					
87	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	41	41	42	42	49	GT-4 Under maint.					
88	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	47	50	50	50							
89	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	112	112	54	ST Under maint.					
90	Hobiganj 11MW PP Confidence-E	Gas (SI/PP, REB)	4x2.90	11	11	5	8	11	11							
91	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	60	60	60							
92	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	330	Under maint.					
93	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	84	86	81	86							
94	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	20	109	180	200							
95	Sylhet 20 MW GTPP	Gas (PDB)	1x 20	20	20	0	0	0	0	20	Under maint.					
96	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10							
97	Shahjahanulla 25 MW PP	Gas (CI/PP, REB)	3x9.34	25	25	0	16	16	16							
98	Bibiya-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	315	300	320							
99	Bibiya-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	391	404	350	400							
100	Bibiya South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	350	380	400	400							
101	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0	100	Under project work					
102	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.4+5*2	50	50	46	50	50	50							
Sylhet Zone Total					2472	2427	1509	1684	1705	0	580					
103	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0							
104	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	195	165	160	170	245	Gas Shortage					
105	Fairdipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	9	26	20	26							
106	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	30	75	35	75							
107	Khulna 225 MW CCPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	168	206	200	210							
108	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	53	54	54	54							
109	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	15	50	15	50							
110	Mongla Orion 100 MW Solar PP	Solar (IPP)	100	100	65	0	100	0								
111	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	32	88	49	88							
112	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	24	16	24							
113	Maitree Super Thermal 1320 MW PP (U-I)	Coal (BIFPCL)	1x617	617	617	305	310	300	310	307	Coal Shortage					
114	Khulna 330 MW CCPP (GT)	Gas/HSD (BFDB)	1x220	220	220	350	200	150	200							
**	Bheramara (HVDC)	India	1000	1000	912	807	929	929								
Khulna Zone Total					3125	3121	2134	2005	2029	552	0					
115	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	32	48	16	48							
116	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	15	14	25	29							
117	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	130	130	130	130							
118	Payra 1320 MW TTP	Coal (BCPCL)	2x622	1244	1244	0	0	0	0	1244	Coal Shortage					
119	Potukhalhi 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	150	17	150							
120	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	180	300	150	150							
121	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	110	110	110	110	110	Under maint.					
Barishal Zone Total					2265	2265	484	752	448	617	1244	110				
122	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage					
123	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Under maint.					
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	35	35	35							
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	208	0	200							
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	14	28	30	30							
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	92	40	92							
128	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	36							
129	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	8	0	0							
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	35	35	35							
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	155	166	160	170							
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	0	0	0	0	220	Gas Shortage					
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	160	150	150	150	70	Gas Shortage					
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	414	414	414							
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	0	0	0	0							
136	Ullapara 11 MW PP (Summit)	Gas (SI/PP, REB)	4x2.90	11	11	0	8	8	8							
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	0	0							
138	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	55	35	55							
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	50	35	50							
140	Aminura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	0	0							
141	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	5	0	6	0							
**	Adani Power Jharkhanda Ltd	Coal (Import)	1x748	748	748	756	756	760	760							
Rajshahi Zone Total					2927	2905	1574	2005	1708	2035	361	100				
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	71	68	70	70		Coal Shortage					
143	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overhauling					
144	Barapukuria 275 MW TTP Unit-3	Coal (PDB)	1 x 274	274	274	200	200	200	200		Coal Shortage					
145	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0							
146	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	34	34	35	34							
147	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0							
148	Majma, Tatalia 8 MW Solar PP (Syma Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0							
149	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6*20	115	115	35	115	35	115							
150	Lalmohith 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	33	0	30	0							
151	Teesa Solar Limited	Solar (IPP)	1 x 200	200	200	202	0	130	0							
Rangpur Zone Total					1030	950	582	417	508	419	0	85				
Sub-total: Plants in operation					23954	23545	11858.0	13906	12164	14080	2894	1858				
(B) Plants under long term maintenance/ contract expired																
152	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0							
153	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0							
154	Bosalia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	118	0	0	0	0	0							
155	Kishoreganj 55 MW PP (Franchise)	Gas (RPP)	15*4	35	0	0	0	0	0							
Sub-Total: Plants under long term maintenance/ contract expired					309	0	0	0	0	0	0	0				
Gross Total					24263	23545	11858	13906	12164	14080	2894	1858				
(C) Actual data of 24.06.23 (Yesterday) Saturday :																
01.	Max. Demand at eve. peak (Generation end)	:	14500 MW, at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :											
02.	Max. Demand at eve. peak (Sub-station end)	:	13788 MW, at =	21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW				
03.	Highest Generation (Generation end)	:	13906 MW, at =	21:00 hrs	Dhaka	5065	5004	61	Mymensingh	1144	1000	144				
04.	Minimum Generation (Generation end)	:	10714 MW, at =	9:00 hrs	Chattogram	1255	1255	0	Sylhet	555	555	0				
05.	Day-peak Generation (Generation end)	:	11858 MW, at =	12:00 hrs	Khulna	1657	1561	96	Barishal	412	377	35				
06.	Evening-peak Generation (Generation end)	:	13906 MW, at =	21:00 hrs	Rajshahi	1406	1354	52	Rangpur	979	896	83				
07.	Evening Peak Load-shed (Sub-station end)	:	567 MW, at =	21:00 hrs	Cumilla	1315	1219	96								
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10908 MW, at =	5:00 hrs					Total	13788	13221	567				
09.	Generation shortfall at evening peak due to :	:														
	a) Gas/LF limitation	:	2729 MW													
	d) Coal supply Limitation	:	0 MW													
	b) Low water level in Kaptai lake	:	165 MW													
	c) Plants under shut down/ maintenance	:	1858 MW													
10.	Total Energy (Generation + India Import)	:	286.51 MCKWh													
	By Gas =	164.949 MCKWh	By Oil =	54.820 MCKWh												
	By Coal =	37.284 MCKWh	By Hydro =	1.514 MCKWh												
	By Solar =	2.749 MCKWh														
11.	Total Gas Supplied	:	1234.90 MMCFD													
(D) Forecast of 25.06.23 (Today) Sunday :																
01.	Maximum Demand	:	14800 MW (Generation end)		04.	Maximum Load-shed	:	680 MW At evening peak (Sub-station end)								
02.	Maximum Generation	:	14080 MW (Generation end)		05.	Total Generation	:	304.93 MCKWh								
03.	Reserve / Shortage	:	-720 MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	:	34.1° C								

#Remarks: Highest Generation 15648 MW on 1