

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9554667, 9551095

Month June, 2023		Day : Monday		Date : 26.06.23								
Probable Maximum Demand : 14600 MW		Probable Maximum Generation : 14061 MW										
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 75.32 ft	Today = 75.27 ft	Rule Curve = 82.65 ft								
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Dered/ Present Capacity (MW)	25.06.23 (Yesterday)		26.06.23 (Today)		25.06.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)		
(A) Plants in operation:												
1	Ghorasal Repowered CAPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CAPP Unit-4	Gas (PDB)	1 x 210	210	180	160	210	210	210			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	115	Under maint.	
3	Ghorasal 365 MW CAPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0			
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	69	78	60	78	30	Gas Shortage	
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage	
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Haripur 360MW CAPP(HPL)	Gas (IPP)	1x235+1x125	360	360	327	344	330	340			
8	Meghnaghat 450 MW CAPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450			
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Haripur 412 MW CAPP	Gas (EGCB)	1x273+1x139	412	412	392	393	390	393			
11	Siddhirganj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	189	195	200	200			
12	Siddhirganj 335 MW CAPP	Gas (EGCB)	1 x 217+1x118	335	335	319	326	330	330			
13	Meghnaghat CAPP(Summit)	Gas (IPP)	2x110+1x110	335	335	305	301	305	305			
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	24	15	25			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	42	74	74	75			
16	Narsinghdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	17	15	14	15			
17	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	8x3.67+7x8.73	80	80	44	45	45	45			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	23	31	24	31			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	25	8	25			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	105	34	105			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	98	16	98			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	35	0	35			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	47	143	48	150			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	128	17	128			
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	250	301	300	300			
27	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	14	0	0	0			
28	Nabaganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	35	35	55			
29	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	35	55			
30	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	54	71	70	72			
31	Manikganj 162MW PP(MPL)	HFO (IPP)	9x18	162	162	35	90	35	90			
32	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	0	30	0	0			
33	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	34	17	35			
34	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	34	50	40	50			
35	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	24	34	30	34			
36	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	17	34	30	34			
37	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	100	0	0	0	0			
Dhaka Zone Total			6004	5822	3040	3757	3225	3796	135	490		
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	60	60	60	60	170	Low water level	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	107	110	110	110	70	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	5	0	5	0			
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	25	8	25			
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	15	0	20	0			
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	35	50	19	50			
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	51	17	51			
45	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
46	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	217	223	225	225			
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	88	297	88	300			
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	12	12	12	12			
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	16	33	17	33			
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	23	24	20	24			
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	11	10	10	10			
*	Malancha, Clp EPZ (United)	Gas	5x8.73+3x9.34			6	33	10	30			
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0			
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17			
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	51	17	34			
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	12	12	12	12			
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRP)	8x13.45	100	100	23	23	23	23			
57	Chattogram 116 MW PP (Anilima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	51	34	51			
58	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	0	0	0	0			
	SS Power Unit-1	Coal (IPP)				0	0	0	0			
	Cox's Bazar Wind PP	(Wind) (IPP)				0	0	18	10			
Chattogram Zone Total			2605	2545	698	1082	742	1077	240	330		
59	Ashuganj 50 MW PP	Gas (APSC)	14x3.968	53	45	10	10	10	10			
60	Ashuganj 225 MW CAPP	Gas (APSC)	1x142+1*75	221	221	193	209	200	210			
61	Ashuganj 450 MW CAPP(South)	Gas (APSC)	1x360	360	360	250	250	250	250	110	Gas Shortage	
62	Ashuganj 450 MW CAPP(North)	Gas (APSC)	1x361	360	360	300	305	300	305			
63	Ashuganj 420 MW CAPP(East)	Gas (APSC)	1x284+1x116	400	400	250	250	250	250	150	Gas Shortage	
64	Ashuganj 195MW PP (APSC-United)	Gas (IPP)	20*9.73+1*16	195	195	0	0	0	0	195	Gas Shortage	
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	43	43	43			
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	5	150	5	150			
67	Tilas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	15	49	30	49			
68	Chandpur 150 MW CAPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under maint.	
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	51	104	50	100			
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	20	20			
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	11	11			
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	32	32	25	32			
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	8	43	43			
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	12	12	12	12			
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	97	114	95	114			
76	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	86	9	86			
77	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	35	35			
78	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	36	115	36	115			
**	Impoport (Tripura)	India		160	160	162	154	129	152			
Cumilla Zone Total			2904	2896	1529	1955	1553	1987	455	163		
79	RPCL 210MW CAPP	Gas (IPP)	4x35+1x70	210	202	12	32	30	40	170	Gas Shortage	
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	18	19			
81	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	19	85	19	85			
82	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	67	87	68	87			
83	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
84	Sutiekhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	28	0	50	0			
85	Tangail 22 MW PP(RPCL)	HFO (IPP)	4x6.7	22	22	12	12	12	12			
Mymensingh Zone Total			622	614	159	235	199	243	170	0		

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	25.06.23 (Yesterday)		26.06.23 (Today)		25.06.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening				
86	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43	27	GT-1 & ST-1 Under maint.	
87	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	40	41	42	42	49	GT-4 Under maint.	
88	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	44	50	50	50			
89	Kushnara 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	112	112	54	ST Under maint.	
90	Hobiganj 11MW PP Confidence-E	Gas (SI/PP, REB)	4x2.90	11	11	5	5	5	5			
91	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	59	60	60	60			
92	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	330	Under maint.	
93	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	84	86	86	86			
94	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	215	202	200	202			
95	Sylhet 20 MW GTPP	Gas (PDB)	1x20	20	20	0	0	0	0	20	Under maint.	
96	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10			
97	Shahjahanulla 25 MW PP	Gas (CI/PP, REB)	3x9.34	25	25	24	16	16	16			
98	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	310	305	300	310			
99	Bibiana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	372	80	0	0		Under maint.	
100	Bibiana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	350	342	350	370			
101	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0	100	Under project work	
102	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.4+5*2	50	50	45	49	50	50			
Sylhet Zone Total					2472	2427	1713	1401	1324	0	580	
103	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
104	Bheramara 410 MW CAPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	145	140	150	150	270	Gas Shortage	
105	Fairdipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	8	28	20	28			
106	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	33	78	35	78			
107	Khulna 225 MW CAPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	203	206	200	210			
108	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	54	54	54	54			
109	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	15	50	15	50			
110	Mongla Orion 100 MW Solar PP	Solar (IPP)	100	100	36	0	100	0				
111	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	63	97	49	97			
112	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	24	16	24			
113	Maitree Super Thermal 1320 MW PP (U-I)	Coal (BIFPCL)	1x617	617	617	308	311	300	310	306	Coal Shortage	
114	Khulna 330 MW CAPP (GT)	Gas/HSD (BFDB)	1x220	220	220	200	200	150	200			
**	Bheramara (HVDC)	India	1000	1000	918	922	929	929				
Khulna Zone Total					3125	3121	1963	2110	2019	576	0	
115	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	32	32	16	48			
116	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	26	38	25	38			
117	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	130	130	130	130			
118	Payra 1320 MW TTP	Coal (BCPCL)	2x622	1244	1244	0	190	370	370	1054	Coal Shortage	
119	Potukhal 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	150	17	150			
120	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	150	250	150	150			
121	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	110	110	110	110	110	Under maint.	
Barishal Zone Total					2265	2265	465	900	818	1054	110	
122	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage	
123	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Under maint.	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	28	30	30			
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	200			
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	21	35	30	35			
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	92	40	92			
128	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	23	0	30			
129	Santahar 50 MW Peaking PP	HFO (QRP)	6x8.9	50	50	50	0	0	0			
130	Sirajgonj 225MW CAPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	159	157	160	160	53	Gas Shortage	
131	Sirajgonj 225MW CAPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	0	0	0	0	220	Gas Shortage	
132	Sirajgonj 225MW CAPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	140	141	150	150	79	Gas Shortage	
133	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	392	398	414	414			
134	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	0	0	0	0			
135	Ullapara 11 MW PP (Summit)	Gas (SI/PP, REB)	4x2.90	11	11	8	8	8	8			
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	15	52	0	8			
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	55	35	55			
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	50	35	50			
139	Aminura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	0	0			
140	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	5	0	6	0			
**	Adani Power Jharkhand Ltd	Coal (Import)	1x748	748	748	761	764	760	760			
Rajshahi Zone Total					2927	2905	1621	1838	1703	423	100	
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	67	70	70	70		Coal Shortage	
142	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overhauling	
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	230	230	230	230		Coal Shortage	
144	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	40	34	35	34			
146	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
147	Majma, Tatala 9 MW Solar PP (Syma Power)	Solar (IPP)	1 x 9	9	9	0	7	8	0			
148	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6*20	115	115	35	115	35	115			
149	Lalmohar 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	16	0	30	0			
150	Treesta Solar Limited	Solar (IPP)	1 x 200	200	200	178	0	130	0			
Rangpur Zone Total					1030	950	573	449	538	449	0	85
Sub-total: Plants in operation					23954	23545	11781.0	13727	12121	14061	3053	1858
(B) Plants under long term maintenance/ contract expired												
150	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			
151	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			
152	Bosolia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	118	0	0	0	0	0			
153	Kishoreganj 55 MW PP (Franchise)	Gas (RPP)	15*4	55	0	0	0	0	0			
Sub-Total: Plants under long term maintenance/ contract expired					309	0	0	0	0	0	0	
Gross Total					24263	23545	11781	13727	12121	14061	3053	1858
(C) Actual data of 25.06.23 (Yesterday) Sunday :												
01.	Max. Demand at eve. peak (Generation end)	:	14600 MW, at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	13928 MW, at =	21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	13768 MW, at =	22:00 hrs	Dhaka	4984	4898	86	Mymensingh	1173	1009	164
04.	Minimum Generation (Generation end)	:	10908 MW, at =	8:00 hrs	Chattogram	1318	1318	0	Sylhet	572	572	0
05.	Day-peak Generation (Generation end)	:	11781 MW, at =	12:00 hrs	Khulna	1686	1505	181	Barishal	406	406	0
06.	Evening-peak Generation (Generation end)	:	13727 MW, at =	21:00 hrs	Rajshahi	1446	1351	95	Rangpur	920	782	138
07.	Evening Peak Load-shed (Sub-station end)	:	834 MW, at =	21:00 hrs	Cumilla	1422	1252	170				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10866 MW, at =	5:00 hrs								
09.	Generation shortfall at evening peak due to :	:			Total							
a)	Gas/LF limitation	:	2883 MW		Total = 13928							
b)	Coal supply Limitation	:	0 MW		Total = 13094							
c)	Plants under shut down/ maintenance	:	1858 MW		Total = 984477992							
10.	Total Energy (Generation + India Import)	:	286.84 MMCFD		834							
	By Gas = 160.342 MKWH		By Oil = 56.619 MKWH									
	By Coal = 39.217 MKWH		By Hydro = 1.465 MKWH									
	By Solar = 3.030 MKWH											
11.	Total Gas Supplied	:	1200.13 MMCFD									
(D) Forecast of 26.06.23 (Today) Monday :												
01.	Maximum Demand	:	14600 MW (Generation end)		04.	Maximum Load-shed	:	510 MW	At evening peak (Sub-station end)			
02.	Maximum Generation	:	14061 MW (Generation end)		05.	Total Generation	:	304.18 MKWh				
03.	Reserve / Shortage	:	-539 MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	:	34° C				

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation