

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9554667, 9551095

Month June, 2023				Day : Tuesday				Date : 27.06.23				
Probable Maximum Demand : 11300 MW				Probable Maximum Generation : 14502 MW								
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 75.27 ft		Today = 75.09 ft		27.06.23 (Today)		Rule Curve = 82.92 ft		
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Dered/ Present Capacity (MW)	26.06.23 (Yesterday)		27.06.23 (Today)		26.06.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW			
					Day	Evening	Day	Evening	Machines shut down (MW)			
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	150	220	210	210			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	115	Under maint.	
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0			
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	77	80	80	80	28	Gas Shortage	
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage	
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	336	342	330	340			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450			
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	395	393	395	395			
11	Siddhirganj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	193	199	200	200			
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	326	333	330	330			
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	309	286	305	305			
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	12	15	15	30			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	25	42	8	40			
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	13	14	15			
17	Summit Power, (Madhabdi-Ashulia)	Gas (SIPP, REB)	8x3.67+7x8.73	80	80	45	46	45	45			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	30	31	33	33			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	25	8	25			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	105	17	105			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	64	16	64			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	35	0	35			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	47	278	300	300			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	149	17	149			
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	301	0	300	300			
27	Aurahat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	8	0	0			
28	Nabaganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	55	35	55			
29	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	17	17	35			
30	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	53	74	70	72			
31	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	35	17	35	90			
32	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	7	0	30	0			
33	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	11	34	17	35			
34	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	34	50	16	16			
35	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	35	22	9	9			
36	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	17	33	17	34			
37	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	100	75	0	0	0			
Dhaka Zone Total			6004	5822	3031	3449	3352	3630	133	490		
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	70	70	70	70	160	Low water level	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	108	105	110	110	75	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	5	0	5	0			
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	8	8	25			
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	5	0	20	0			
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	50	6	50			
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	51	17	51			
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	224	226	225	225			
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	88	298	88	300			
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	12	38	12	38			
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	33	33	33	33			
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	24	24	24	32			
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	11	11	10	10			
*	Malancha, Clp EPZ (United)	Gas	5x8.73+3x9.34			12	31	25	35			
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0			
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17			
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	34	17	34			
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	12	38	12	38			
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRP)	8x13.45	100	100	12	34	23	23			
57	Chattogram 116 MW PP (Anilma Energy Ltd.)	HFO (IPP)	6x21.06	116	116	34	51	34	51			
58	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	0	35	0	0			
	SS Power Unit-1	Coal (IPP)				0	0	0	0			
	Cox's Bazar Wind PP	(Wind) (IPP)				0	0	18	10			
Chattogram Zone Total			2605	2545	715	1154	774	1152	235	330		
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	20	40	40	40			
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	190	205	200	210			
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	250	250	250	250	110	Gas Shortage	
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	280	280	300	305	80	Gas Shortage	
63	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	230	230	250	250	170	Gas Shortage	
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	0	0	0	0	195	Gas Shortage	
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	43	43	43			
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	5	140	5	150			
67	Tilas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	34	45	30	49			
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under maint.	
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	60	120	50	120			
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	20	20	20			
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	11	11			
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	32	32	32	32			
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	43	43	43			
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	12	12	12	12			
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	52	34	114	114			
76	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	86	9	86			
77	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	17	35	35			
78	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	26	115	36	115			
**	Impoort (Tripura)	India		160	160	144	160	146	161			
Cumilla Zone Total			2904	2896	1432	1882	1626	2046	555	163		
79	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	12	53	30	40	149	Gas Shortage	
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	21	18	19			
81	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	19	85	19	85			
82	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	68	88	68	87			
83	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
84	Sutiekhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	0	0	50	0			
85	Tangail 22 MW PP(RPCL)	HFO (IPP)	4x6.7	22	22	12	4	12	12			
Mymensingh Zone Total			622	614	181	251	199	243	149	0		

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	26.06.23 (Yesterday)		27.06.23 (Today)		26.06.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Machines shut down (MW)			
86	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	42	42	43	43	28	GT-1 & ST-1 Under maint.	
87	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	39	40	42	42	50	GT-4 Under maint.	
88	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	47	50	50	50			
89	Kushnara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	112	112	54	ST Under maint.	
90	Hobiganj 11MW PP Confidence-E	Gas (SI/PP, REB)	4x2.90	11	11	5	5	5	5			
91	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	61	60	60			
92	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	330	Under maint.	
93	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	84	86	86	86			
94	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	205	202	200	202			
95	Sylhet 20 MW GTPP	Gas (PDB)	1x20	20	20	0	17	17	17			
96	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10			
97	Shahjahanulla 25 MW PP	Gas (CI/PP, REB)	3x9.34	25	25	16	16	16	16			
98	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	290	300	310			
99	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	0	0	0	0		Under maint.	
100	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	370	390	350	370			
101	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0	100	Under project work	
102	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.4+5*2	50	50	40	48	50	50			
Sylhet Zone Total					2472	2427	1320	1369	1341	1373	0	562
103	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
104	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	170	215	270	270	195	Gas Shortage	
105	Fairdipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	15	27	20	28			
106	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	22	42	36	78			
107	Khulna 225 MW CCPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	207	208	208	208			
108	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	54	54	54	54			
109	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	15	32	15	50			
110	Mongla Orion 100 MW Solar PP	Solar (IPP)	100	100	68	0	100	0				
111	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	64	16	49	97			
112	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	8	8	16	24			
113	Maitree Super Thermal 1320 MW PP (U-I)	Coal (BIFPCL)	1x617	617	617	309	315	300	310	302	Coal Shortage	
114	Khulna 330 MW CCPP (GT)	Gas/HSD (BFDB)	1x220	220	220	0	0	0	0			
**	Bheramara (HVDC)	India	1000	1000	923	787	937	937				
Khulna Zone Total					3125	3121	1855	1704	2005	2056	497	0
115	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	32	16	48			
116	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	17	30	25	38			
117	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	130	130	130	130			
118	Payra 1320 MW TTP	Coal (BCPCL)	2x622	1244	1244	370	370	370	370	874	Coal Shortage	
119	Potukhal 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	116	17	150			
120	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	150	150	150	150			
121	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	110	110	110	110	110	Under maint.	
Barishal Zone Total					2265	2265	810	938	818	996	874	110
122	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Under maint.	
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	35	30	30			
124	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	200			
125	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	28	30	35			
126	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	92	40	92			
127	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	35	0	30			
128	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	0			
129	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	35	35	35			
130	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	167	180	180	180			
131	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	0	0	0	0	220	Gas Shortage	
132	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	148	168	180	180			
133	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	417	421	414	414			
134	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	0	0	0	0			
135	Ullapara 11 MW PP (Summit)	Gas (SI/PP, REB)	4x2.90	11	11	8	8	8	8			
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	0	8			
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	55	35	55			
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	50	35	50			
139	Aminura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	0	0			
140	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	3	0	6	0			
**	Adani Power Jharkhanda Ltd	Coal (Import)	1x748	748	748	1037	1065	1050	1050			
Rajshahi Zone Total					2927	2905	1850	2180	2043	2367	291	100
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	69	68	70	70		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overhauling	
142	Barapukuria 275 MW TTP Unit-3	Coal (PDB)	1 x 274	274	274	220	220	220	220		Coal Shortage	
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	34	34	35	34			
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
146	Majma, Tatalia 9 MW Solar PP (Syma Power)	Solar (IPP)	1 x 8	8	8	2	0	8	0			
147	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6*20	115	115	35	115	35	115			
148	Lalmohith 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	38	0	30	0			
149	Treesta Solar Limited	Solar (IPP)	1 x 200	200	200	204	0	130	0			
Rangpur Zone Total					1030	950	602	437	528	439	0	85
Sub-total: Plants in operation					23954	23545	11796.0	13364	12686	14502	2734	1840
(B) Plants under long term maintenance/ contract expired												
150	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			
151	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			
152	Bosilia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	118	0	0	0	0	0			
153	Kishoreganj 55 MW PP (Franchise)	Gas (RPP)	15*4	35	0	0	0	0	0			
Sub-Total: Plants under long term maintenance/ contract expired					309	0	0	0	0	0	0	0
Gross Total					24263	23545	11796	13364	12686	14502	2734	1840
(C) Actual data of 26.06.23 (Yesterday) Monday :												
01.	Max. Demand at eve. peak (Generation end)	:	13395 MW, at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	12733 MW, at =	21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	13364 MW, at =	21:00 hrs	Dhaka	4409	4409	0	Mymensingh	1113	1083	30
04.	Minimum Generation (Generation end)	:	10866 MW, at =	8:00 hrs	Chattogram	1196	1196	0	Sylhet	543	543	0
05.	Day-peak Generation (Generation end)	:	11796 MW, at =	12:00 hrs	Khulna	1489	1489	0	Barishal	395	395	0
06.	Evening-peak Generation (Generation end)	:	13364 MW, at =	21:00 hrs	Rajshahi	1373	1373	0	Rangpur	905	905	0
07.	Evening Peak Load-shed (Sub-station end)	:	30 MW, at =	21:00 hrs	Cumilla	1311	1311	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	9448 MW, at =	5:00 hrs					Total	12733	12703	30
09.	Generation shortfall at evening peak due to :	:			13.	Fuel cost :	(a) Gas = 170350149 Taka (b) Oil = 675655305 Taka	(c) Coal = 124400894 Taka Total = 970406348 Taka				
	a) Gas/LF limitation	:	2574 MW		14.	Maximum Temperature in Dhaka was :	32° C					
	d) Coal supply Limitation	:	0 MW		15.	Export through East-West interconnections :						
	b) Low water level in Kaptai lake	:	160 MW			At evening peak-hour	:	11796 MW, at	21:00 hrs			
	c) Plants under shut down/ maintenance	:	1840 MW			Maximum	:	880 MW, at	16:00 hrs			
10.	Total Energy (Generation + India Import)	:	282.90 MKWh			Energy	:	0 MKWh				
	By Gas = 152.286 MKWh			By Oil = 50.519 MKWh								
	By Coal = 50.502 MKWh			By Hydro = 1.605 MKWh								
	By Solar= 2.782 MKWh											
11.	Total Gas Supplied	:	1173.21 MMCFD									
(D) Forecast of 27.06.23 (Today) Tuesday :												
01.	Maximum Demand	:	11300 MW (Generation end)		04.	Maximum Load-shed	:	510 MW	At evening peak (Sub-station end)			
02.	Maximum Generation	:	14502 MW (Generation end)		05.	Total Generation	:	239.21 MKWh				
03.	Reserve / Shortage	:	3202 MW (Generation end)		06.	Probable Max. Temperature in Dhaka :		32° C				

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation