

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 27-Jun-23		Page - 2					
Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Enerov Generated	Remarks
			Unit No. X Capacity	MW	MW	KWH	
1	Ghorasal Repowered CCPP-Unit-3 (GT	PDB		120	0	0	Under maint.
2	Ghorasal Repowered CCPP Unit-4	PDB	1*210	180	220	3990375	
	Ghorasal TPP Unit-5	PDB	1*210	190	0	0	Under maint.
3	Ghorasal 365 MW CCPP Unit-7	PDB	1*243+1*122	365	0	0	Under maint.
	Ghorasal 78.5 MW PP(PMAX)	QRPP	2*40	0	0	0	
4	Ghorasal 108MW PP (Regent)	IPP	3*43.35	108	65	1302636	Gas shortage
5	Haripur GTTP	SBU, PDB	2*32	20	0	0	Under maint.
6	Haripur 412 MW CCPP	EGCB	1*273+1*139	412	393	8822780	Gas shortage
7	Haripur 360MW CCPP(HPL)	IPP	1*235+1*125	360	342	7570000	Gas shortage
8	Meghnaghat 450 MW CCPP(MPL)	IPP	2*150+1*150	450	450	9442000	
9	Meghnaghat 30 MW (OPCL)	NENP	1*28	100	9	115200	Fuel shortage
10	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	335	312	7077644	FGMO
11	Madanganj 102 PP(Summit)	NENP	6*17	102	0	126530	High voltage
12	Madanganj-55 MW PP(Summit)	IPP	3*17.08+1*11.3	55	0	20118	High voltage
13	Keraniganj 100 MW PP (Powerpac)	QRPP	8*13.45	20	0	0	
14	Narsingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	0	189936	Engine problem
15	210 MW Siddhirgonj TPP	PDB	1*210	115	0	0	Under maint.
16	Siddhirgonj 2*120 MW GTTP	EGCB	2*105	210	195	3841000	
17	Siddhirgonj 100 PP(Dutch Bangla)	NENP	12*8.9	100	0	69437	High voltage
18	Siddhirgonj 335 MW CCPP	EGCB	1*217+1*18	335	327	7251067	
19	Ganagar 102 MW PP (Digital Power)	IPP	12*8.324	102	33	276490	Fuel shortage
20	Kalpatoti 52 MW PP (Sinha)	IPP	7*7.9	0	0	0	Fuel shortage
21	Kamalaghat 54 MW PP(Banco Energy)	IPP	3*18	54	35	201240	Fuel shortage
22	Kodda 150 MW PP	BPDB-RPCL	9*17.06	149	16	337440	Low Demand
23	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	17	93262	High voltage
24	Nabaghat 55 MW PP (Southern power)	IPP	3*19.3	55	35	191662	High voltage
25	Bosila 108MW PP(OLC)	IPP	12*8.75+1*3.5	0	0	0	
26	Summit Power, (Madhabdi+Ashulia)	SIPP, REB	3*3.67+4*8.73	80	38	963120	Engine problem
27	Maona 33 MW PP(Summit)	SIPP, REB	4*8.73	33	25	706900	Engine problem
28	Rupganj 33 MW PP(Summit)	SIPP, REB	4*8.73	33	32	774600	
29	Gazipur 52 MW PP	RPCL	8*6.9	0	52	0	Low Demand
30	Tongi 80 MW GTTP	PDB	1*105	105	0	0	
31	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	95	785345	Low Demand
32	Keraniganj 300 MW PP (APR)	IPP	256*1.4	300	0	156998	Low Demand
33	Bramhangonj 100 MW PP (Aggreko)	IPP	11*10.959	100	0	0	Contract Expired
34	Auraha 100MW PP (Aggreko)	IPP	0.83*2+0.95*91	100	0	1318	Fuel shortage
35	Kodda 149 MW PP Unit-1 (Summit)	IPP	8*18.45+8.97	149	71	654190	Low Demand
36	Gazipur 100 MW PP	RPCL	6*17.5	105	34	506861	Low Demand
37	Meghnaghat 104 MW PP (OPCL)	IPP	18.5*6	69		584640	Fuel shortage
38	Manikganj 162MW PP(MPGL)	IPP	9*18	162	36	344160	High voltage
39	Spectra Solar Plant Ltd	IPP	0	35	0	91394	
40	Kanchan Purbachal Power Generation Ltd	IPP	18.4*3	55	17	244080	Fuel shortage
Dhaka area Total				5867	2866	56852473	
41	Chattogram TPP-1	PDB	1*210	180	108	2600000	Gas shortage
42	Chattogram TPP-2	PDB	1*210	180	0	0	Gas shortage
	Razzan 25 MW PP	RPCL	3*8.9	25	0	50110	Low Demand
43	Teknaf 20MW PP (Solaritech)	IPP	20	0	0	54270	
44	Patenga 50MW PP (Baraka)	IPP	8*6.98	50	30	143520	Low Demand
45	Kapali Hydro Unit-1,2,3,4, 5	PDB	2*40+3*50	230	70	1685760	Low Water level
46	Sikalbaha 225MW	PDB	1*150+1*75	225	223	5249092	
47	Sikalbaha Feaking GT	PDB	1*150	150	0	0	Under maint.
48	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	6*17.5	105	51	582109	Fuel shortage
49	Halhazari 100 MW peaking PP	PDB	11*8.9	98	0	130800	Low Demand
50	Dohazari -Kalaish 100 MW Peaking	PDB	6*17	102	0	186586	Low Demand
51	Juldah 100 MW Unit-1 (Acom)	NENP	8*13.45	100	34	415200	Fuel shortage
52	Juldah 100 MW PP Unit-3 (Acom)	IPP	8*13.5	100	100	1123200	
53	Barakunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	15	268846	Engine problem
*	Malancha, Ctp, EPZ (United)		5*8.73+3*9.34	0	42	898560	
54	Chattogram 108 MW PP (ECPV)	IPP	16*7	108	0	0	Fuel shortage
55	Kapali 7 MW Solar PP	PDB	7.4 MW	7	0	24719	
56	Anwara 300 MW PP (United)	IPP	17*17+24	300	150	1987200	Low Demand
57	Jodda Power	IPP	3*18.56+13.6	54	17	447831	Fuel shortage
58	Karnaphuli Power Ltd.	IPP	18.415*6+8.5	110	34	535270	Fuel shortage
59	Juldah unit-2 (Acom)	IPP	8*13.6	100	75	769920	Low Demand
60	Anilima Energy Ltd.	IPP	6*21.2	116	51	777818	Fuel shortage
	Minshara 150 MW	BPDB-RPCL	18.5*9	163	0	192363	Fuel shortage
	SS Power I	SS Power	0	0	0	0	On test.
	Cox's Bazar Wind	IPP	66	0	0	0	On test.
Chattogram area Total				2545	998	18123176	
61	Ashuganj TPP Unit- 3	APSCL	1*150	0	0	0	Contract Expired
	Ashuganj TPP Unit- 5	APSCL	1*150	0	0	0	Contract Expired
	Ashuganj TPP Unit- 5	APSCL	1*150	0	0	0	Contract Expired
62	Ashuganj 225 MW CCPP	APSCL	1*142+1*75	221	212	4820000	Gas shortage
63	Ashuganj 450 MW CCPP(North)	APSCL	1*360	360	335	7273200	Gas shortage
64	Ashuganj 450 MW CCPP(South)	APSCL	1*360	360	250	6159000	Gas shortage
	Ashuganj 420 MW CCPP(East)	APSCL	284*1+116*1	400	230	5691700	Gas shortage
65	Ashuganj 50 MW PP I	APSCL	14*3.968	45	47	1048104	
66	Ashuganj 55 MW PP (Precision)	QRPP	0	0	0	0	
67	Ashuganj 195MW PP (APSCL-United)	IPP	20*9.73+1*16	195	0	0	Contract Expired
68	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	43	835764	Engine problem
69	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	114	536945	Low Demand
70	Titas 50 MW Peaking PP	PDB	6*8.92	52	0	47120	Low Demand
71	Chandpur 150 MW CCPP	PDB	1*106+1*57	163	0	0	Under maint.
72	Chandpur 200MW (Desh energy)	IPP	12*18.4	200	34	924480	Low Demand
73	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	20	407736	
74	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	10	245160	
	Import (Tijura)	Imported power	0	160	140	3191040	
75	Jangalia 33MW PP (Summit)	SIPP, PDB	4*9.73	33	32	725400	
76	Jangalia 52 MW PP (Lakdhan)	IPP	6*8.92	52	43	740453	Engine problem
77	Cumilla 25 MW PP (Summit)	SIPP, REB	3*3.67+2*6.97	25	12	245800	Engine problem
78	Daudkandi 200 MW PP (B.Trac)	IPP	154*1.4	200	0	0	Contract Expired
79	Feni Lanka Power	IPP	7*18.415+1*9.78	114	34	606480	High voltage
80	Chowmuhani 113 MW	IPP	12*9.78+2*23.1	113	58	423380	Fuel shortage
81	Bharob 54.5 MW	IPP	3*18.2	54	17	570500	Engine problem
82	Chandpur 115(Doreen)	IPP	4*18.5+2*22.5	115	72	624960	Low Demand
Cumilla Area Total				3096	1703	35117302	
83	RPCL 210MW CCPP	IPP	4*35+1*70	202	104	1800960	Gas shortage
84	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	17	362052	Engine problem
85	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	0	0	0	Under maint.
86	Sarishabari 3 MW Solar Plant.	IPP	1*3	0	0	8150	
87	Mymensingh 200 MW PP (United)	IPP	9*78*12	200	64	1598400	Fuel shortage
88	Jamalpur 115 MW PP (United)	IPP	9*78*12	115	85	706800	Fuel shortage
89	Sutakhal 50 MW Solar PP	IPP	50	50	0	179690	
90	Tangail Pali Power Gen 22 MW	IPP	4*6.7	0	0	196990	Fuel shortage
Mymensingh Area Total				614	270	4843012	
91	Fenchuganj CCPP Phase-1	PDB	2*92+1*33	70	43	1010000	Machine problem
92	Fenchuganj CCPP Phase-2	PDB	2*35+1*35	90	41	933360	Machine problem
93	Kushiana 163 MW CCPP (KP)	IPP	1*109+1*54	163	112	2318400	ST Under maint.
94	Shahjibazar 330 MW CCPP	PDB	0	0	0	0	Under maint.
95	Fenchuganj 51 MW PP (Barakatullah)	RPP	19*2.90	51	50	1036800	
	Fenchuganj 44MW (Energyprima)	NENP	12*3.3+5*2	50	49	1006200	
96	Holiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	11	147100	Machine problem
97	Shahjibazar GTTP Unit- 8 & 9	PDB	2*35	66	60	1290816	
98	Shahjibazar 98MW PP (Shahjibazar)	RPP	32*2.90	86	86	1426560	
99	Shahjibazar 100 MW GTTP	PDB	1*100	100	0	0	Under maint.
100	Sylhet 225 MW CCPP	PDB	1*142+1*89	231	203	5096570	Machine problem
101	Sylhet 20 MW GTTP	PDB	1*20	20	17	404000	
	Sylhet 50MW PP (EPL)	NENP	27*2	0	0	0	Contract Expired
102	Shahjibazar 25 MW PP	SIPP, REB	3*9.34	25	24	523924	Engine problem
103	Bibiana-II 341 MW CCPP (Summit)	IPP	1*222+1*119	341	285	6980000	FGMO
104	Bibiyana-II 400 MW CCPP	PDB	285*1+134*1	400	0	0	Under maint.
105	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	10	241740	
106	Bibiyana South 400 MW	PDB	400 MW	383	380	8854400	
Sylhet Area Total				2427	1371	31269770	
107	Bheramara GTTP Unit-3	PDB	1*20	0	0	0	Fuel shortage
**	Bheramara (HVDC)	Imported power	2*500	1000	850	21869090	
108	Khulna 115 PP MW (KPCL-2)	NENP	7*17	115	40	381120	High voltage
109	Fardpur 50 MW Peaking PP	PDB	8*6.89	54	0	0	Engine problem
110	Khulna 225 MW CCPP	NWPGCL	1*150+1*75	230	0	550795	Low Demand
111	Coxiganga 100 MW Peaking PP	PDB	16*9.98	0	0	2560	Low Demand
112	Bheramara 410 MW CCPP	NWPGCL	1*278+1*132	410	385	6873984	
	Noapara 40 MW PP (Khanjahan Ali)	NENP	5*8.5	40	24	197250	High voltage
113	Noapara 100 MW PP (Bangla Trac)	IPP	70*1.4	0	0	0	Contract Expired
114	Rupsha 105 MW PP (Orion rupsha)	IPP	6*18.445	105	8	159940	Low Demand
115	Madhumati 100 MW PP	NWPGCL	6*18	105	15	244956	Low Demand
116	Mongla Orion 100 MW Solar PP	IPP	100	100	0	308880	
	Khulna 330 MW CCPP (OIL)	BPDB	1*220+1*110	0	0	0	On test.
	Rampal 1320 MW (BFPCL)	NTPC&BPDB	660*2	617	304	6579364	Coal shortage.
	Kulna 225 MW CCPP (GAS)	NWPGCL	0	0	0	0	On test.
Khulna Area Total				2907	1626	37167539	
117	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	16	153312	Fuel shortage
118	Bhola 33 MW PP (Venture)	NENP	1*34.50	40	30	532502	Engine problem
119	Bhola 225 MW CCPP	PDB	2*63+1*68	194	130	3086000	Machine problem
120	Bhola 95 MW PP (Aggreko)	QRPP	96*1.10	0	0	0	Contract Expired
121	Payra 1320 MW	BCPCL	2*622	1244	320	8239600	unit-1 Under S/D.
122	Bhola Nutan Barisal BD LTD	IPP	220	220	110	2670300	GT-1 Under maint.
123	United Payra Power Ltd.	IPP	8*18.5+1*9.5	150	0	122400	High voltage
	Barisal 307 MW	BCPCL	307*1	307	150	3643600	
Barisal Area Total				2265	756	18447714	
124	Baghabari 71 MW GTTP	PDB	1*71	71	0	0	Gas shortage
	Baghabari 100 MW GTTP	PDB	1*100	100	0	0	Gas shortage
125	Baghabari 50 MW Peaking PP	PDB	9*8.9	50	0	0	Low Demand
126	Bera 70 MW Peaking PP	PDB	9*8.29	71	0	84010	Low Demand
127	Ammura 50 MW PP(Sinha)	QRPP	7*7.79	28	0	0	Fuel shortage
128	Katakhal 50 MW PP (Northern)	QRPP	6*8.9	50	0	0	Fuel shortage
129	Katakhal 50 MW Peaking PP	PDB	6*8.7	50	28	158152	Fuel shortage
130	Sirajgonj Unit-1 225MW	NWPGCL	1*150+1*75	225	217	4509927	
131	Sirajgonj Unit-2 225MW	NWPGCL	1*150+1*75	220	0	0	
132	Sirajgonj Unit-3 225MW	NWPGCL	1*141	220	199	4361791	Gas shortage
133	Sirajgonj 400 MW CCPP Unit-4	SNWPGCL	1*282+1*132	414	416	8667236	
134	Santihar 30 MW Peaking PP	PDB	6*8.7	50	35	167956	Engine problem