

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9554567, 9551095

Month June, 2023				Day : Wednesday				Date : 28.06.23				
Probable Maximum Demand : 12000 MW				Probable Maximum Generation : 14433 MW								
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 75.09 ft		Today = 74.66 ft		28.06.23 (Today)		Rule Curve = 82.92 ft.		
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Dered/ Present Capacity (MW)	27.06.23 (Yesterday)		28.06.23 (Today)		27.06.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW			
					Day	Evening	Day	Evening	Machines shut down (MW)			
(A) Plants in operation:												
1	Ghorasal Repowered CCP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCP Unit-4	Gas (PDB)	1 x 210	210	180	120	220	210	210			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	115	Under maint.	
3	Ghorasal 365 MW CCP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0			
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	22	65	80	80	43	Gas Shortage	
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage	
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Haripur 360MW CCP(HPL)	Gas (IPP)	1x235+1x125	360	360	302	342	330	340			
8	Meghnaghat 450 MW CCP(MPL)	Gas (IPP)	2x140+1x170	450	450	380	450	450	450			
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Haripur 412 MW CCP	Gas (EGCB)	1x273+1x139	412	412	333	393	395	395			
11	Siddhirganj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	103	195	100	200			
12	Siddhirganj 335 MW CCP	Gas (EGCB)	1 x 217+1x118	335	335	280	327	330	330			
13	Meghnaghat CCP(Summit)	Gas (IPP)	2x110+1x110	335	335	310	312	305	305			
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	0	15	30			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	33	8	40			
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	14	15			
17	Summit Power, (Madhabdi-Ashulia)	Gas (SIPP, REB)	8x3.67+7x8.73	80	80	38	38	45	45			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	28	25	33	33			
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	32	32	33	33			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	0	8	25			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	34	17	105			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	32	16	16	64			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	35	0	35			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	95	300	300			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	71	17	149			
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	300	300			
27	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0			
28	Nabaganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	35	35	55			
29	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	17	17	35			
30	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	1	69	70	72			
31	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	36	35	90			
32	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	16	0	30	0			
33	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	17	17	35			
34	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	0	16	16			
35	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	0	9	9	9			
36	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	17	34			
37	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	100	0	0	0	0			
Dhaka Zone Total			6004	5822	2039	2866	3252	3630	148	490		
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	70	70	70	70	160	Low water level	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	109	108	110	110	72	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	3	0	5	0			
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	0	8	25			
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	4	0	20	0			
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	30	6	50			
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	51	17	51			
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
46	Sikalbaha 225 MW CCP	Gas (PDB)	1 x 150+1 x 75	225	225	219	223	225	225			
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	50	150	88	300			
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	12	100	12	100			
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	0	33	33			
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	24	32			
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	11	13	10	10			
*	Malancha, Clp EPZ (United)	Gas	5x8.73+3x9.34			25	42	25	35			
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0			
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17			
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	34	17	34			
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	12	75	12	100			
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRP)	8x13.45	100	100	0	34	23	23			
57	Chattogram 116 MW PP (Anilma Energy Ltd.)	HFO (IPP)	6x21.06	116	116	34	51	34	51			
58	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	0	0	0	0			
	SS Power Unit-1	Coal (IPP)				0	0	0	0			
	Cox's Bazar Wind PP	(Wind) (IPP)				0	0	18	10			
Chattogram Zone Total			2605	2545	600	998	774	1276	232	330		
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	20	47	40	40			
60	Ashuganj 225 MW CCP	Gas (APSCL)	1x142+1*75	221	221	212	212	200	210			
61	Ashuganj 450 MW CCP(South)	Gas (APSCL)	1x360	360	360	250	250	250	250	110	Gas Shortage	
62	Ashuganj 450 MW CCP(North)	Gas (APSCL)	1x361	360	360	310	335	300	305			
63	Ashuganj 420 MW CCP(East)	Gas (APSCL)	1x284+1x116	400	400	230	230	250	250	170	Gas Shortage	
64	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	0	0	0	0	195	Gas Shortage	
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	15	43	43	43			
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	114	5	150			
67	Tilas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	30	49			
68	Chandpur 150 MW CCP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under maint.	
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	52	34	50	100			
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	20	20			
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	11	11			
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	32	32	32	32			
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	9	43	43	43			
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	6	12	12	12			
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	34	34	114	114			
76	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	58	9	86			
77	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	35	35			
78	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	18	72	36	115			
**	limport (Tripura)	India		160	160	120	140	146	161			
Cumilla Zone Total			2904	2896	1364	1703	1626	2026	475	163		
79	RPCL 210MW CCP	Gas (IPP)	4x35+1x70	210	202	48	104	145	150	98	Gas Shortage	
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	17	18	19			
81	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	19	85	19	85			
82	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	71	64	68	87			
83	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
84	Sutiekhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	26	0	50	0			
85	Tangail 22 MW PP(RPCL)	HFO (IPP)	4x6.7	22	22	12	0	12	12			
Mymensingh Zone Total			622	614	197	270	314	353	98	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	27.06.23 (Yesterday)		28.06.23 (Today)		27.06.23 (Yesterday)		Status of Machines under shut-down/ Maintenance		
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Machines shut down (MW)	Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening					
86	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	41	43	43	43		27	GT-1 & ST-1 Under maint.		
87	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	40	41	42	42		49	GT-4 Under maint.		
88	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	50	50	50	50					
89	Kushnara 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	80	112	112	112		54	ST Under maint.		
90	Hobiganj 111MW PP Confidence-E	Gas (SI/PP, REB)	4x2.90	11	11	0	11	11	11					
91	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	60	60	60					
92	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.		
93	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	10	86	86	86					
94	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	205	203	200	202					
95	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	17	17	17	17					
96	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10					
97	Shahjahanulla 25 MW PP	Gas (CI/PP, REB)	3x9.34	25	25	24	24	24	24					
98	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	285	300	310					
99	Bibiyana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	0	0	0	0			Under maint.		
100	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	370	380	350	370					
101	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work		
102	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.4+5*2	50	50	45	49	50	50					
Sylhet Zone Total						2472	2427	1251	1371	1355	1387	0	560	
103	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0					
104	Bheramara 410 MW CAPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	250	385	380	410	25		Gas Shortage		
105	Fairdipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	20	28					
106	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	36	78					
107	Khulna 225 MW CAPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	0	0	208	208					
108	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	8	54	54					
109	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	15	15	50					
110	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	34	0	100	0					
111	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	40	49	97					
112	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	24	16	24					
113	Maitree Super Thermal 1320 MW PP (U-I)	Coal (BIFPCL)	1x617	617	617	304	304	300	310	313		Coal Shortage		
114	Khulna 330 MW CAPP (GT)	Gas/HSD (BPDB)	1x220	220	220	0	0	0	0					
**	Bheramara (HVDC)	India		1000	1000	919	850	930	930					
Khulna Zone Total						3125	3121	1507	1626	2108	2189	338	0	
115	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	16	48					
116	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	22	30	25	38					
117	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	130	130	130	130					
118	Payra 1320 MW TTP	Coal (BCPCL)	2x622	1244	1244	270	320	370	370	924		Coal Shortage		
119	Potukhalhi 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	17	150					
120	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	150	150	150	150					
121	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	110	110	110	110		110	Under maint.		
Barishal Zone Total						2265	2265	682	756	818	996	924	110	
122	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage		
123	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Under maint.		
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	30	30					
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	200					
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	30	35					
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	41	40	92					
128	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	28	0	30					
129	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	0					
129	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	35	35	35					
130	Sirajgonj 225MW CAPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	140	217	180	210					
131	Sirajgonj 225MW CAPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage		
132	Sirajgonj 225MW CAPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	140	199	180	200					
133	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	307	416	414	414					
134	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	0	0	0	0					
135	Ullapara 11 MW PP (Summit)	Gas (SI/PP, REB)	4x2.90	11	11	0	8	8	8					
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	0	8					
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	70	35	55					
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	70	50	100					
139	Aminura 30 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	0	0					
140	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	2	0	6	0					
**	Adani Power Jharkhanda Ltd	Coal (Import)	1x748	748	748	850	512	520	520					
Rajshahi Zone Total						2927	2905	1439	1596	1528	1937	291	100	
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	71	71	70	70			Coal Shortage		
142	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling		
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	200	220	220			Coal Shortage		
144	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	34	34	35	34					
146	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
147	Majpara, Tatala 9 MW Solar PP (Syma Power)	Solar (IPP)	1 x 9	9	9	4	0	8	0					
148	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6*20	115	115	35	75	35	115					
149	Lalmoharhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	18	0	30	0					
150	Treesta Solar Limited	Solar (IPP)	1 x 200	200	200	89	0	130	0					
Rangpur Zone Total						1030	950	451	380	528	439	0	85	
Sub-total: Plants in operation						23954	23545	9530.0	11566	12303	14433	2506	1838	
(B) Plants under long term maintenance/ contract expired														
150	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0					
151	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0					
152	Bosolia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	118	0	0	0	0	0					
153	Ashuwin 55 MW PP (Precision)	Gas (RPP)	15.4	35	0	0	0	0	0					
Sub-Total: Plants under long term maintenance/ contract expired						309	0	0	0	0	0	0	0	
Gross Total						24263	23545	9530	11566	12303	14433	2506	1838	
(C) Actual data of 27.06.23 (Yesterday) Tuesday :														
01.	Max. Demand at eve. peak (Generation end)	:	11566 MW, at =	21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :								
02.	Max. Demand at eve. peak (Sub-station end)	:	11172 MW, at =	21:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed		
03.	Highest Generation (Generation end)	:	11668 MW, at =	22:00 hrs		MW	MW	MW		MW	MW	MW		
04.	Minimum Generation (Generation end)	:	9383 MW, at =	9:00 hrs	Dhaka	3429	3429	0	Mymensingh	995	995	0		
05.	Day-peak Generation (Generation end)	:	9530 MW, at =	12:00 hrs	Chattogram	1120	1120	0	Sylhet	540	540	0		
06.	Evening-peak Generation (Generation end)	:	11566 MW, at =	21:00 hrs	Khulna	1479	1479	0	Barishal	373	373	0		
07.	Evening Peak Load-shed (Sub-station end)	:	0 MW, at =	21:00 hrs	Rajshahi	1280	1280	0	Rangpur	831	831	0		
08.	Minimum Generation Forecast up to 8:00 hrs.	:	7678 MW, at =	5:00 hrs	Cumilla	1124	1124	0						
09.	Generation shortfall at evening peak due to :	:							Total	11172	11172	0		
a)	Gas/LF limitation	:	2346 MW		13. Fuel cost :				(a) Gas =	170385751 Taka	(c) Coal =	109179076 Taka		
d)	Coal supply Limitation	:	0 MW						(b) Oil =	315704256 Taka	Total =	595269083 Taka		
b)	Low water level in Kaptai lake	:	160 MW		14. Maximum Temperature in Dhaka was : 28.2° C									
c)	Plants under shut down/ maintenance	:	1838 MW		15. Export through East-West interconnections :									
10.	Total Energy (Generation + India Import)	:	250.46 MKWh		At evening peak-hour : 9530 MW, at 21:00 hrs									
	By Gas = 152.650 MKWh		By Oil = 24.314 MKWh		Maximum : 880 MW, at 16:00 hrs									
	By Coal = 44.862 MKWh		By Hydro = 1.686 MKWh		Energy : 0 MKWh									
	By Solar= 1.890 MKWh													
11.	Total Gas Supplied	:	1135.77 MMCFD											
(D) Forecast of 28.06.23 (Today) Wednesday :														
01.	Maximum Demand	:	12000 MW (Generation end)		04.	Maximum Load-shed	:	0 MW	At evening peak (Sub-station end)					
02.	Maximum Generation	:	14433 MW (Generation end)		05.	Total Generation	:	257.59 MKWh						
03.	Reserve / Shortage	:	2433 MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	:	28.0° C						

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation