

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9554567, 9551095

Month June, 2023				Day : Friday				Date : 30.06.23						
Probable Maximum Demand :				11500 MW		Probable Maximum Generation :				14614 MW				
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 74.03 ft		Today = 73.44 ft		Rule Curve = 83.73 ft						
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Dered/ Present Capacity (MW)	29.06.23 (Yesterday)		30.06.23 (Today)		29.06.23 (Yesterday)		30.06.23 (Today)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Machines shut down (MW)			
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW					
(A) Plants in operation:														
1	Ghorasal Repowered CAPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work		
2	a) Ghorasal Repowered CAPP Unit-4	Gas (PDB)	1 x 210	210	180	100	220	220	220					
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0		115	Under maint.		
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0					
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	12	63	68	68	45		Gas Shortage		
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage		
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0					
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	237	263	320	330					
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	280	450	450	450					
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling		
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	309	392	380	380					
11	Siddhirganj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	39	101	120	200	109		Gas Shortage		
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	220	250	330	330					
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	240	292	305	305					
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	15	15	30					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	0	8	40					
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	10	14	15					
17	Summit Power, Madhabdi-Ashulia	Gas (SIPP, REB)	8x3.67+7x8.73	80	80	23	30	45	45					
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	15	15	33	33					
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	19	13	33	33					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	0	8	25					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	0	17	105					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	0	16	16	64					
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	35	0	35					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	30	300	300					
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	0	10	17	149					
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	300	300					
27	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0					
28	Nabaganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	55	35	55					
29	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	17	17	35					
30	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	27	72	70	72					
31	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	17	35	90					
32	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	5	0	30	0					
33	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	34	17	35					
34	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	0	16	16					
35	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	0	8	9	9					
36	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	17	34					
37	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	100	0	0	0	0					
Dhaka Zone Total			6004	5822	1526	2408	3245	3803	259	490				
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	70	60	35	35	170		Low water level		
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	110	108	110	110	72		Gas Shortage		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.		
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	3	0	5	0					
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	16	8	25					
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	16	0	20	0					
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	32	26	50					
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	34	17	51					
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.		
46	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	150	151	225	225					
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	15	175	88	300					
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	37	100	100	100					
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	34	33	33					
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	24	32					
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	11	8	11	11					
*	Malancha, Clp EPZ (United)	Gas	5x8.73+3x9.34			42	42	35	35					
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0					
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17					
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	34	17	34					
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	12	75	100	100					
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRP)	8x13.45	100	100	12	67	67	67					
57	Chattogram 116 MW PP (Anilima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	34	34	51					
58	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	0	18	163	163					
	SS Power Unit-1	Coal (IPP)				0	0	0	200					
	Cox's Bazar Wind PP	(Wind) (IPP)				0	0	18	10					
Chattogram Zone Total			2605	2545	546	1005	1153	1649	242	330				
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	10	41	46	46					
60	Ashuganj 225 MW CAPP	Gas (APSCCL)	1x142+1*75	221	221	135	215	200	200					
61	Ashuganj 450 MW CAPP(South)	Gas (APSCCL)	1x360	360	360	230	305	250	250					
62	Ashuganj 450 MW CAPP(North)	Gas (APSCCL)	1x361	360	360	280	310	300	300					
63	Ashuganj 420 MW CAPP(East)	Gas (APSCCL)	1x284+1x116	400	400	230	370	240	370					
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	0	26	8	26	169		Gas Shortage		
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	0	43	43	43					
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	40	5	150					
67	Tilas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	20	30	45					
68	Chandpur 150 MW CAPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163	Under maint.		
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	102	50	100					
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	20	20					
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	11	11					
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	32	32	32	32					
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	43	43	43					
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	20	12	12					
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	85	114	114					
76	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	86	9	86					
77	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	35	35					
78	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	18	54	36	115					
**	Impoorti (Tripura)	India		160	160	98	148	146	161					
Cumilla Zone Total			2904	2896	1126	1987	1630	2159	169	163				
79	RPCL 210MW CAPP	Gas (IPP)	4x35+1x70	210	202	140	160	160	160	42		Gas Shortage		
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	19	18	19					
81	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	0	85	19	85					
82	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	0	84	68	87					
83	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	0	0	1.6	0					
84	Sutiekhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	1	0	50	0					
85	Tangail 22 MW PP(RPCL)	HFO (IPP)	4x6.7	22	22	0	0	12	12					
Mymensingh Zone Total			622	614	157	348	329	363	42	0				

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	29.06.23 (Yesterday)		30.06.23 (Today)		29.06.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)	Probable Peak Generation (MW)	Gen. shortfall for : Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date		
												Day	Evening
86	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43	27	GT-1 & ST-1 Under maint.		
87	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	41	31	42	42	59	GT-4 Under maint.		
88	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	5	50	50	50				
89	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	80	0	112	112	54	ST Under maint.		
90	Hobiganj 11MW PP Confidence-E	Gas (SI/PP, REB)	4x2.90	11	11	11	5	11	11				
91	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	40	61	60	60				
92	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	330	Under maint.		
93	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	10	86	86	86				
94	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	204	204	200	202				
95	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	17	17	17				
96	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
97	Shahjahanulla 25 MW PP	Gas (CI/PP, REB)	3x9.34	25	25	0	24	15	24				
98	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	270	270	0	0				
99	Bibiana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	0	0	0	0		Under maint.		
100	Bibiyan South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	321	320	350	370				
101	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0	100	Under project work		
102	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.4*5*2	50	50	5	39	50	50				
Sylhet Zone Total						2472	2427	1040	1160	1046	1077	0	570
103	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
104	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	250	400	350	400				
105	Fairdip 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	20	28				
106	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	36	78				
107	Khulna 225 MW CCPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	0	0	200	200				
108	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	17	54	54				
109	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	15	50				
110	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	0	0	100	0				
111	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	0	49	97				
112	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	16	24				
113	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	304	295	300	300	322	Coal Shortage		
114	Khulna 330 MW CCPP (GT)	Gas/HSD (BPDB)	1x220	220	220	0	0	0	0				
**	Bheramara (HVDC)	India		1000	1000	584	816	579	821				
Khulna Zone Total						3125	3121	1138	1528	1719	2052	322	0
115	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	16	48				
116	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	18	24	25	38				
117	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	80	130	130	130				
118	Payra 1320 MW TTP	Coal (BCPCL)	2x622	1244	1244	250	360	370	370	884	Coal Shortage		
119	Potukhalhi 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	17	150				
120	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	140	150	150	150				
121	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	139	220	205	220	0	Under maint.		
Barishal Zone Total						2265	2265	627	884	913	1106	884	0
122	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	70	70	71	Gas Shortage		
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Under maint.		
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	30	30				
124	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	200				
125	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	30	35				
126	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	0	40	80				
127	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	30				
128	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	0				
129	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	35	35				
130	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	45	170	100	200				
131	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	0	0	0	0	220	Gas Shortage		
132	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	130	218	180	200				
133	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	259	275	414	414				
134	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	0	0	0	0				
135	Ullapara 11 MW PP (Summit)	Gas (SI/PP, REB)	4x2.90	11	11	5	8	8	8				
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	0	8				
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	60	35	60				
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	0	50	100				
139	Aminura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	0	0				
140	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	0	0	6	0				
**	Adani Power Jharkhanda Ltd	Coal (Import)	1x748	748	748	527	513	520	520				
Rajshahi Zone Total						2927	2905	966	1244	1518	1990	291	100
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		Coal Shortage		
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overhauling		
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	180	220	220		Coal Shortage		
143	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	0	82	35	80				
145	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Majpara, Talsia 9 MW Solar PP (Syma Power)	Solar (IPP)	1 x 9	9	8	2	0	8	0				
147	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	70	35	115				
148	Lalmorhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	8	0	30	0				
149	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	55	0	130	0				
Rangpur Zone Total						1030	950	235	332	458	415	0	85
Sub-total: Plants in operation						23954	23545	7361.0	10896	12011	14614	2209	1738
(B) Plants under long term maintenance/ contract expired													
150	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
151	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
152	Bosolia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
153	Ashuapuri 55 MW PP (Precision)	Gas (RPP)	15.4	35	0	0	0	0	0				
Sub-total: Plants under long term maintenance/ contract expired						309	0	0	0	0	0	0	0
Gross Total						24263	23545	7361	10896	12011	14614	2209	1738
(C) Actual data of 29.06.23 (Yesterday) Thursday :													
01.	Max. Demand at eve. peak (Generation end)	:	10896 MW, at =	21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	10456 MW, at =	21:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed	
03.	Highest Generation (Generation end)	:	10904 MW, at =	22:00 hrs		MW	MW	MW		MW	MW	MW	
04.	Minimum Generation (Generation end)	:	7361 MW, at =	9:00 hrs	Dhaka	2762	2762	0	Mymensingh	985	985	0	
05.	Day-peak Generation (Generation end)	:	7361 MW, at =	9:00 hrs	Chattogram	1021	1021	0	Sylhet	492	492	0	
06.	Evening-peak Generation (Generation end)	:	10896 MW, at =	21:00 hrs	Khulna	1423	1423	0	Barishal	381	381	0	
07.	Evening Peak Load-shed (Sub-station end)	:	0 MW, at =	21:00 hrs	Rajshahi	1267	1267	0	Rangpur	811	811	0	
08.	Minimum Generation Forecast up to 8:00 hrs.	:	8445 MW, at =	5:00 hrs	Cumilla	1315	1315	0					
09.	Generation shortfall at evening peak due to :	:							Total	10456	10456	0	
	a) Gas/LF limitation	:	2039 MW		13.	Fuel cost :	(a) Gas = 147795558 Taka	(c) Coal = 89603913 Taka					
	d) Coal supply Limitation	:	0 MW				(b) Oil = 234883089 Taka	Total = 472282560					
	b) Low water level in Kaptai lake	:	170 MW										
	c) Plants under shut down/ maintenance	:	1738 MW		14.	Maximum Temperature in Dhaka was : 27.3° C							
10.	Total Energy (Generation + India Import)	:	211.48 MMCFD		15.	Export through East-West interconnections :							
	By Gas = 136.034 MKWH		By Oil = 19.044 MKWH		At evening peak-hour : 7361 MW, at 21:00 hrs								
	By Coal = 33.874 MKWH		By Hydro = 1.510 MKWH		Maximum : 296 MW, at 7:00 hrs								
	By Solar= 1.303 MKWH				Energy : 0 MKWh								
11.	Total Gas Supplied	:	1048.14 MMCFD										
(D) Forecast of 30.06.23 (Today) Friday :													
01.	Maximum Demand	:	11500 MW (Generation end)	04.	Maximum Load-shed	:	0 MW	At evening peak (Sub-station end)					
02.	Maximum Generation	:	14614 MW (Generation end)	05.	Total Generation	:	223.04 MKWh						
03.	Reserve / Shortage	:	3114 MW (Generation end)	06.	Probable Max. Temperature in Dhaka :	:	27.3° C						

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation