

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9554567, 9551095

Month July, 2023				Day : Sunday				Date : 02.07.23				
Probable Maximum Demand : 11800 MW				Probable Maximum Generation : 14653 MW								
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 73.22 ft		Today = 73.21 ft		Rule Curve = 84.61 ft.				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Dered/ Present Capacity (MW)	01.07.23 (Yesterday)		02.07.23 (Today)		01.07.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)	Probable Peak Generation (MW)	Probable Peak Generation (MW)	Gen. shortfall for : Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)			
										Day		Evening
(A) Plants in operation:												
1	a) Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	120	180	120	120			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180	115	Under maint.	
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0			
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	6	6	6	6	102	Gas Shortage	
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage	
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	327	343	330	330			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	420	450	450	450			
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	400	397	400	400			
11	Siddhirganj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	158	200	150	200			
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	300	45	100	330			
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	305	313	310	310			
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	0	15	30			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	8	8	42			
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	14	15			
17	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	8x3.67+7x8.73	80	80	30	34	45	45			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	15	15	33	33			
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	19	19	33	33			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	0	8	50			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	17	17	105			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	0	0	64	149			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	54	17	54			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	15	300	300			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	0	17	149	149			
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	300	300			
27	Aurahat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0			
28	Nabaganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	17	55	55			
29	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	0	55	55			
30	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	53	51	70	72			
31	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	0	162	162			
32	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	6	0	30	0			
33	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	6	17	35			
34	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	8	8	40			
35	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	35	9	9	9			
36	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	17	34	100			
37	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	0	0	0			
Dhaka Zone Total				6004	5822	2374	2401	3489	4159	207	490	
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	35	65	35	60	165	Low water level	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	108	108	110	110	72	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	3	0	5	0			
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	25	8	25			
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	18	0	20	0			
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	46	6	50			
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	34	17	51			
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
46	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	149	149	150	150			
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	88	296	88	300			
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	50	100	100	100			
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	50	50	50			
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	40	63	32	70			
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	13	13	13	13			
*	Malancha, Clp EPZ (United)	Gas	5x8.73+3x9.34			26	34	25	35			
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0			
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17			
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	34	17	34			
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	50	90	100	100			
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRP)	8x13.45	100	100	46	69	46	69			
57	Chattogram 116 MW PP (Anilma Energy Ltd.)	HFO (IPP)	6x21.06	116	116	34	51	34	51			
58	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	54	18	163	163			
	SS Power Unit-1	Coal (IPP)				0	0	0	0			
	Cox's Bazar Wind PP	(Wind) (IPP)				0	0	18	10			
Chattogram Zone Total				2605	2545	779	1262	1054	1458	237	330	
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	10	47	46	46			
60	Ashuganj 225 MW CAPP	Gas (APSCCL)	1x142+1*75	221	221	184	193	200	200			
61	Ashuganj 450 MW CAPP(South)	Gas (APSCCL)	1x360	360	360	0	0	0	0	360	Gas Storage	
62	Ashuganj 450 MW CAPP(North)	Gas (APSCCL)	1x361	360	360	280	320	300	300			
63	Ashuganj 420 MW CAPP(East)	Gas (APSCCL)	1x284+1x116	400	400	322	329	340	340			
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	102	185	190	190			
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	18	43	43	43			
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	70	150	150			
67	Tilas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	44	47	30	45			
68	Chandpur 150 MW CAPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under maint.	
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	63	104	50	100			
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	20	20			
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	11	11			
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	24	33	32	32			
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	43	43	43			
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	15	12	12	12			
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	34	52	114			
76	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	28	58	9	55			
77	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17			
78	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	17	54	18	54			
**	Impoort (Tripura)	India		160	160	122	146	146	161			
Cumilla Zone Total				2904	2896	1293	1765	1709	1933	360	163	
79	RPCL 210MW CAPP	Gas (IPP)	4x35+1x70	210	202	106	205	200	200			
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	19	20	20			
81	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	24	85	24	85			
82	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	8	32	68	85			
83	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0			
84	Sutiekhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	19	0	50	0			
85	Tangail 22 MW PP(RPCL)	HFO (IPP)	4x6.7	22	22	0	0	12	12			
Mymensingh Zone Total				622	614	178	341	376	402	0	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	01.07.23 (Yesterday)		02.07.23 (Today)		01.07.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)		
86	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 & ST-1 Under maint.	
87	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	30	30	30		60	GT-4 Under maint.	
88	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	25	44	50	50				
89	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	0	0	0		54	ST Under maint.	
90	Hobiganj 111MW PP Confidence-E	Gas (SI/PP, REB)	4x2.90	11	11	11	11	11	11				
91	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	61	61	60	60				
92	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
93	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	60	85	86	86				
94	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	0	0	0	0				
95	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	18	17	17				
96	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	0	9	10	10				
97	Shahjahanulla 25 MW PP	Gas (CI/PP, REB)	3x9.34	25	25	0	24	15	24				
98	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	315	300	300				
99	Bibiana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	0	0	0	250			Under maint.	
100	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	100	128	400	400				
101	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
102	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.4+5*2	50	50	25	49	50	50				
Sylhet Zone Total						2472	2427	757	817	1072	1331	0	571
103	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
104	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	395	410	350	380				
105	Fairdipor 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	20	28				
106	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	36	78				
107	Khulna 225 MW CCPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	0	0	200	200				
108	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	0	54	54				
109	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	105	15	50				
110	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	17	0	100	0				
111	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	49	49	97				
112	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	40	16	24				
113	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	0	0	0	0		617	Coal Shortage	
114	Khulna 330 MW CCPP (GT)	Gas/HSD (BDFD)	1x220	220	220	0	0	0	0				
**	Bheramara (HVDC)	India		1000	1000	904	908	934	934				
Khulna Zone Total						3125	3121	1316	1512	1774	1845	617	0
115	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	16	48				
116	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	18	29	25	38				
117	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	65	65	65	65				
118	Payra 1320 MW TTP	Coal (BCPCL)	2x622	1244	1244	270	360	360	360	884		Coal Shortage	
119	Potukhalhi 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	54	17	150				
120	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	150	160	150	150				
121	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	178	140	220	220				
Barishal Zone Total						2265	2265	681	824	853	1031	884	0
122	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	60	65	70	70				
123	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	30	30				
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	200				
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	30	35				
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	0	40	80				
128	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	30				
129	Katakhal 50 MW PP (Northern)	HFO (QRP)	6x8.9	50	50	0	0	0	0				
129	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	35	35	35				
130	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	0	214	180	200				
131	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage	
132	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	166	220	180	200				
133	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	376	422	414	414				
134	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	0	0	0	0				
135	Ullapara 11 MW PP (Summit)	Gas (SI/PP, REB)	4x2.90	11	11	0	8	8	8				
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	0	8				
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	113	113	113				
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	74	70	113				
139	Aminura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	0	0				
140	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	0	0	6	0				
**	Adani Power Jharkhanda Ltd	Coal (Import)	1x748	748	748	459	557	550	550				
Raishahi Zone Total						2927	2905	1061	1708	1726	2086	220	100
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	180	180	180	180			Coal Shortage	
143	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	0	106	113	113				
145	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Majpara, Taltula 8 MW Solar PP (Syma Power)	Solar (IPP)	1 x 8	8	8	4	0	8	0				
147	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	115	35	115				
148	Lalmorhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	14	0	30	0				
149	Treesta Solar Limited	Solar (IPP)	1 x 200	200	200	64	0	130	0				
Rangpur Zone Total						1030	950	262	401	496	408	85	85
Sub-total: Plants in operation						23954	23545	8701.0	11031	12549	14653	2610	1739
(B) Plants under long term maintenance/ contract expired													
150	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
151	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
152	Bosolia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
153	Ashupani 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	0	0	0	0				
Sub-Total: Plants under long term maintenance/ contract expired						309	0	0	0	0	0	0	0
Gross Total						24263	23545	8701	11031	12549	14653	2610	1739
(C) Actual data of 01.07.23 (Yesterday) Saturday :													
01.	Max. Demand at eve. peak (Generation end)	:	11031 MW, at =	21:00 hrs	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :								
02.	Max. Demand at eve. peak (Sub-station end)	:	10530 MW, at =	21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW	
03.	Highest Generation (Generation end)	:	11198 MW, at =	22:00 hrs	Dhaka	2615	2615	0	Mymensingh	929	929	0	
04.	Minimum Generation (Generation end)	:	8071 MW, at =	8:00 hrs	Chattogram	1220	1220	0	Sylhet	467	467	0	
05.	Day-peak Generation (Generation end)	:	8701 MW, at =	12:00 hrs	Khulna	1496	1496	0	Barishal	473	473	0	
06.	Evening-peak Generation (Generation end)	:	11031 MW, at =	21:00 hrs	Rajshahi	1225	1225	0	Rangpur	872	872	0	
07.	Evening Peak Load-shed (Sub-station end)	:	0 MW, at =	21:00 hrs	Cumilla	1234	1234	0					
08.	Minimum Generation Forecast up to 8:00 hrs.	:	8750 MW, at =	5:00 hrs									
09.	Generation shortfall at evening peak due to :	:			Total								
	a) Gas/LF limitation	:	2360 MW		Total = 10530								
	d) Coal supply Limitation	:	85 MW		Total = 92196818 Taka								
	b) Low water level in Kaptai lake	:	165 MW		Total = 578578864 Taka								
	c) Plants under shut down/ maintenance	:	1739 MW										
10.	Total Energy (Generation + India Import)	:	235.56 MKWh										
	By Gas = 136.675 MKWh		By Oil = 26.135 MKWh										
	By Coal = 45.808 MKWh		By Hydro = 0.916 MKWh										
	By Solar= 1.306 MKWh												
11.	Total Gas Supplied	:	1107.47 MMCFD										
(D) Forecast of 02.07.23 (Today) Sunday :													
01.	Maximum Demand	:	11800 MW (Generation end)		04.	Maximum Load-shed	:	0 MW	At evening peak (Sub-station end)				
02.	Maximum Generation	:	14653 MW (Generation end)		05.	Total Generation	:	248.23 MKWh					
03.	Reserve / Shortage	:	2853 MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	:	31.8° C					

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation