

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 954567, 9551095

Month July, 2023				Day : Tuesday				Date : 04.07.23				
Probable Maximum Demand :				13000 MW		Probable Maximum Generation :				15616 MW		
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 73.20 ft		Today = 73.20 ft		Rule Curve = 84.48 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Dered/ Present Capacity (MW)	03.07.23 (Yesterday)		04.07.23 (Today)		03.07.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW			
					Day	Evening	Day	Evening	Machines shut down (MW)	Description/ Remarks		Probable start-up date
(A) Plants in operation:												
1	Ghorasal Repowered CAPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CAPP Unit-4	Gas (PDB)	1 x 210	210	180	160	220	130	180			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180			
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0			
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	12	12	12	12	96	Gas Shortage	
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage	
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	337	336	330	330			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	420	450	450	450			
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	397	397	400	400			
11	Siddhirganj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	103	160	100	160			
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	324	300	280	300			
13	Meghnaghat CAPP(Summit)	Gas (IPP)	2x110+1x110	335	335	306	305	310	310			
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	30	45	45			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	74	24	64			
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	18	14	15			
17	Summit Power, (Madhabdi-Ashulia)	Gas (SIPP, REB)	8x3.67+7x8.73	80	80	36	27	45	45			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	15	15	33	33			
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	20	20	33	33			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	25	8	50			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	50	17	105			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	0	16	64	150			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	35	0	35			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	160	300	300			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	0	75	149	149			
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	300	300			
27	Aurahat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0			
28	Nabaganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	25	55	55	55			
29	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	55	55	55			
30	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	54	53	70	72			
31	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	35	162	162			
32	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	25	0	30	0			
33	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	34	17	35			
34	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	66	16	40			
35	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	8	0	0	8			
36	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	65	100	100			
37	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	100	75	0	0	0			
Dhaka Zone Total			6904	5822	2447	3268	3729	4173	201	375		
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	30	60	30	60	170	Low water level	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	107	106	110	110	74	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	5	0	5	0			
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	16	25	8	25			
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	18	0	20	0			
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	50	6	50			
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	34	34	17	51			
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
46	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	219	224	222	222			
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	88	295	88	300			
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	50	100	50	100			
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	33	33	33			
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	34	76	32	72			
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	13	13	13	13			
*	Malancha, Clp EPZ (United)	Gas	5x8.73+3x9.34			33	36	25	35			
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0			
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17			
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	34	17	34			
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	50	90	50	90			
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRP)	8x13.45	100	100	57	80	58	80			
57	Chattogram 116 MW PP (Anilma Energy Ltd.)	HFO (IPP)	6x21.06	116	116	34	51	34	51			
58	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	0	36	163	163			
	SS Power Unit-1	Coal (IPP)				280	326	300	300			
	Cox's Bazar Wind PP	(Wind) (IPP)				0	0	18	10			
Chattogram Zone Total			2605	2545	1108	1686	1316	1816	244	330		
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	40	23	46	46			
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	187	183	200	200			
61	Ashuganj 450 MW CAPP(South)	Gas (APSCL)	1x360	360	360	0	0	0	0	360	Gas Storage	
62	Ashuganj 450 MW CAPP(North)	Gas (APSCL)	1x361	360	360	285	285	300	300			
63	Ashuganj 420 MW CAPP(East)	Gas (APSCL)	1x284+1x116	400	400	322	228	290	290			
64	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	189	180	190	190			
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	10	43	10	43			
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	5	74	5	150			
67	Tilas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	37	36	36	36			
68	Chandpur 150 MW CAPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under maint.	
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	51	104	50	100			
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	20	20	20			
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	11	11			
72	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	31	32	32	32			
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	43	43	43	43			
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	20	20	20			
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	88	70	88	105			
76	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	58	9	55			
77	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	0	17	17	17			
78	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	18	115	18	115			
**	Imphort (Tripura)	India		160	160	128	146	129	152			
Cumilla Zone Total			2904	2896	1491	1687	1514	1925	360	163		
79	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	191	199	200	200			
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	20	20			
81	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	38	66	38	85			
82	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	8	70	65	85			
83	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
84	Sutiekhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	36	0	50	0			
85	Tangail 22 MW PP(RPCL)	HFO (IPP)	4x6.7	22	22	0	12	12	12			
Mymensingh Zone Total			622	614	294	366	387	402	0	0		

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	03.07.23 (Yesterday)		04.07.23 (Today)		03.07.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening				
86	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43		27	GT-1 & ST-1 Under maint.	
87	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	30	30		60	GT-4 Under maint.	
88	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	14	47	50				
89	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	0	0	0	0		54	ST Under maint.	
90	Hobiganj 11MW PP Confidence-E	Gas (SI/PP, REB)	4x2.90	11	11	5	5	11				
91	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	61	60				
92	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0		330	Under maint.	
93	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	10	85	86				
94	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	135	130	135				
95	Sylhet 20 MW GTTP	Gas (PDB)	1x20	20	20	17	18	17				
96	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10				
97	Shahjahanulla 25 MW PP	Gas (CI/PP, REB)	3x9.34	25	25	24	24	24				
98	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	285	300				
99	Bibiana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	80	402	400			Under maint.	
100	Bibiana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	387	385	400				
101	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0		100	Under project work	
102	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.4*5*2	50	50	10	45	50				
Sylhet Zone Total					2472	2427	1114	1570	1616	0	571	
103	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0				
104	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	405	370	350		380		
105	Fairdipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	23	20		28		
106	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	55	36		78		
107	Khulna 225 MW CCPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	0	0	200		200		
108	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	17	17				
109	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	15	15		105		
110	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	49	0	100		0		
111	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	16	44	49		97		
112	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	16		24		
113	Maitree Super Thermal 1320 MW PP (U-I)	Coal (BIFPCL)	1x617	617	617	0	0	0		617	Under maint.	
114	Khulna 330 MW CCPP (GT)	Gas/HSD (BFDB)	1x220	220	220	0	0	0		0		
**	Bheramara (HVDC)	India		1000	1000	912	845	934		934		
Khulna Zone Total					3125	3121	1399	1369	1737	1863	0	617
115	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	32	16		48		
116	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	21	29	25		38		
117	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	65	0	65		65		
118	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	0	0	622		622	1244	was under maint.
119	Potukhalhi 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	54	17		150		
120	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	150	150	150		150		
121	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	225	220		220		
Barishal Zone Total					2265	2265	472	490	1115	1293	0	1244
122	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	60	60	65		65		
123	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0		0	100	Under maint.
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	30		30		
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0		200		
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	5	30		35		
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	24	40		80		
128	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	22	0		30		
129	Santahar 50 MW Peaking PP	HFO (QRP)	6x8.9	50	50	0	0	0		0		
130	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	170	160	150		180		
131	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	0	0	0		0	220	Gas Shortage
132	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	164	150	160		160	70	Gas Shortage
133	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	314	423	414		414		
134	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	0	0	0		0		
135	Ullapara 11 MW PP (Summit)	Gas (SI/PP, REB)	4x2.90	11	11	0	8	8		8		
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	52	0		52		
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	70	113		113		
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	70	35		113		
139	Aminura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	0		0		
140	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	5	0	6		0		
**	Adani Power Jharkhand Ltd	Coal (Import)	1x748	748	748	615	614	611		611		
Rajshahi Zone Total					2927	2905	1328	1693	1697	2126	290	100
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0		85		Coal Shortage
142	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0		0	85	Under Overhauling
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	180	180	180		180		Coal Shortage
144	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0		0		
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	34	70	107		107		
146	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0		0		
147	Majma, Tatalia 9 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 9	9	9	3	0	8		0		
148	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6*20	115	115	36	75	35		115		
149	Lalmorhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	20	0	30		0		
150	Treeta Solar Limited	Solar (IPP)	1 x 200	200	200	25	0	130		0		
Rangpur Zone Total					1030	950	298	325	490	402	85	85
Sub-total: Plants in operation					23954	23545	9951.0	12454	13601	15616	1180	3485
(B) Plants under long term maintenance/ contract expired												
150	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0		0		
151	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0		0		
152	Bosolia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	118	0	0	0	0		0		
153	Kishoreganj 55 MW PP (Franchise)	Gas (RPP)	15*4	55	0	0	0	0		0		
Sub-Total: Plants under long term maintenance/ contract expired					309	0	0	0	0	0	0	0
Gross Total					24263	23545	9951	12454	13601	15616	1180	3485
(C) Actual data of 03.07.23 (Yesterday) Monday :												
01.	Max. Demand at eve. peak (Generation end)	:	12454 MW, at =	21:00 hrs	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	11910 MW, at =	21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	12605 MW, at =	23:00 hrs	Dhaka	3369	3369	0	Mymensingh	1007	1007	0
04.	Minimum Generation (Generation end)	:	9324 MW, at =	7:00 hrs	Chattogram	1344	1344	0	Sylhet	507	507	0
05.	Day-peak Generation (Generation end)	:	9951 MW, at =	12:00 hrs	Khulna	1712	1712	0	Barishal	483	483	0
06.	Evening-peak Generation (Generation end)	:	12454 MW, at =	21:00 hrs	Rajshahi	1252	1252	0	Rangpur	838	838	0
07.	Evening Peak Load-shed (Sub-station end)	:	0 MW, at =	21:00 hrs	Cumilla	1399	1399	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	9961 MW, at =	5:00 hrs								
09.	Generation shortfall at evening peak due to :	:										
a)	Gas/LF limitation	:	925 MW		13.	Fuel cost :	(a) Gas = 178742877 Taka	(c) Coal = 23259601 Taka				
d)	Coal supply Limitation	:	85 MW				(b) Oil = 454051511 Taka	Total = 656053989 Taka				
b)	Low water level in Kaptai lake	:	170 MW									
c)	Plants under shut down maintenance	:	3485 MW		14.	Maximum Temperature in Dhaka was :	33.5° C					
10.	Total Energy (Generation + India Import)	:	253.34 MMCFD		15.	Export through East-West interconnections :						
	By Gas = 160.037 MKWH	By Oil =	35.144 MKWH			At evening peak-hour	:	9951 MW, at	21:00 hrs			
	By Coal = 30.611 MKWH	By Hydro =	0.869 MKWH			Maximum	:	248 MW, at	20:00 hrs			
	By Solar= 1.656 MKWH					Energy	:	0 MKWH				
11.	Total Gas Supplied	:	1231.18 MMCFD									
(D) Forecast of 04.07.23 (Today) Tuesday :												
01.	Maximum Demand	:	13000 MW (Generation end)		04.	Maximum Load-shed	:	0 MW	At evening peak (Sub-station end)			
02.	Maximum Generation	:	15616 MW (Generation end)		05.	Total Generation	:	261.28 MKWH				
03.	Reserve / Shortage	:	2616 MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	33.3° C					

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation