

Bangladesh Power Generation Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9554667, 9551095

Month July, 2023				Day : Wednesday				Date : 05.07.23					
Probable Maximum Demand :				13900 MW		Probable Maximum Generation :				14891 MW			
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 73.20 ft		Today = 73.21 ft		Rule Curve = 84.64 ft.					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Dered/ Present Capacity (MW)	04.07.23 (Yesterday)		05.07.23 (Today)		04.07.23 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Machines shut down (MW)	Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening					
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work		
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	180	220	130	180				
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180				
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0				
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	12	12	12	12	96	Gas Shortage		
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage		
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0				
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	333	342	330	330				
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450				
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling		
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	402	405	400	400				
11	Siddhirganj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	158	150	100	160				
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	317	320	280	320				
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	300	306	305	305				
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	30	55	55				
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	16	102	48	102				
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	19	19	19				
17	Summit Power, (Madhabdi-Ashulia)	Gas (SIPP, REB)	8x3.67+7x8.73	80	80	38	30	45	45				
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	15	15	33	33				
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	31	32	33	33				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	0	8	50				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	105	17	105				
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	0	32	54	150				
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	35	0	35				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	15	195	300	300				
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	15	96	130	130				
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	300	300				
27	Aurahat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0				
28	Nabaganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	55	55	55				
29	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	35	55	55				
30	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	53	72	70	72				
31	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	72	72	108				
32	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	34	0	30	0				
33	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	34	17	35				
34	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	9	70	16	40				
35	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	9	8	8	8				
36	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	16	72	100	100				
37	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	23	0	23				
Dhaka Zone Total			6004	5822	2705	3517	3652	4190	201	375			
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	30	30	30	60	200	Low water level		
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	107	106	110	110	74	Gas Shortage		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.		
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	5	0	5	0				
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	16	8	25				
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	0	0	20	0				
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	50	6	50				
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	34	51	17	51				
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.		
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	220	151	151	151				
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	88	245	88	300				
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	50	100	50	100				
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	31	33	33	33				
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	32	73	32	72				
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	8	13	13	13				
*	Malancha, Clt EPZ (United)	Gas	5x8.73+3x9.34			20	42	15	30				
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0				
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17				
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	34	17	34				
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	50	90	50	90				
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRP)	8x13.45	100	100	58	80	58	80				
57	Chattogram 116 MW PP (Anilma Energy Ltd.)	HFO (IPP)	6x21.06	116	116	34	51	34	51				
58	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	72	157	163	163				
	SS Power Unit-1	Coal (IPP)				106	0	0	0				
	Cox's Bazar Wind PP	(Wind) (IPP)				0	0	18	10				
Chattogram Zone Total			2605	2545	993	1339	935	1440	274	330			
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	33	41	46	46				
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	205	198	200	200				
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	0	0	0	0				
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	305	330	300	330				
63	Ashuganj 420 MW CCPP(East)	Gas (APSCL)	1x284+1x116	400	400	322	273	220	270				
64	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	123	158	150	150				
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	43	10	43				
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	6	128	5	150				
67	Tilas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	36	36	36	36				
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under maint.		
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	68	103	50	100				
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	20	20	20				
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	11	11				
72	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	31	32	32	32				
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	40	43	43	43				
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	20	20	20				
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	105	105	105				
76	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	27	58	9	55				
77	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17				
78	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	75	94	55	115				
**	Imphort (Tripura)	India		160	160	140	152	129	152				
Cumilla Zone Total			2904	2896	1537	1861	1458	1895	0	163			
79	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	194	153	200	200				
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	13	20	20				
81	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	38	56	38	85				
82	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	24	112	65	85				
83	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0				
84	Sutiekhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	21	0	50	0				
85	Tangail 22 MW PP(RPCL)	HFO (IPP)	4x6.7	22	22	0	12	12	12				
Mymensingh Zone Total			622	614	296	346	387	402	0	0			

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	04.07.23 (Yesterday)		05.07.23 (Today)		04.07.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)		
86	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 & ST-1 Under maint.	
87	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	20	39	30	30		51	GT-4 Under maint.	
88	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	44	47	50	50				
89	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0		54	ST Under maint.	
90	Hobiganj 11MW PP Confidence-E	Gas (SI/PP, REB)	4x2.90	11	11	8	8	11	11				
91	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	61	60	60				
92	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
93	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	85	85	86	86				
94	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	135	132	135	135				
95	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	17	18	17	17				
96	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
97	Shahjahanulla 25 MW PP	Gas (CI/PP, REB)	3x9.34	25	25	24	24	24	24				
98	Bibianna-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	290	0	0				
99	Bibianna-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	366	406	400	400				
100	Bibianna South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	350	378	400	400				
101	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
102	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.4+5*2	50	50	41	47	50	50				
Sylhet Zone Total						2472	2427	1503	1588	1316	0	562	
103	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
104	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	350	400	350	400				
105	Fairdipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	32	20	32				
106	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	65	36	78				
107	Khulna 225 MW CCPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	0	0	150	150				
108	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	5	17	17	17				
109	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	15	15	105				
110	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	54	0	100	0				
111	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	64	49	98				
112	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	8	16	24				
113	Maitree Super Thermal 1320 MW PP (U-I)	Coal (BIFPCL)	1x617	617	617	0	0	0	0		617	Under maint.	
114	Khulna 330 MW CCPP (GT)	Gas/HSD (BFDB)	1x220	220	220	0	0	0	0				
**	Bheramara (HVDC)	India		1000	1000	909	814	934	934				
Khulna Zone Total						3125	3121	1318	1415	1687	0	617	
115	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	96	16	96				
116	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	19	29	25	38				
117	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	0	67	65	65				
118	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	460	622	622	622	622		Coal Shortage	
119	Potukhalhi 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	17	17	150				
120	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	150	150	130	130	157		Coal Shortage	
121	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	222	220	220				
Barishal Zone Total						2265	2265	865	1203	1095	779	0	
122	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	60	60	65	65				
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.	
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	28	30	30				
124	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	200				
125	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	30	35				
126	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	82	40	82				
127	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	22	0	30				
128	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	8	0	34				
129	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	35	35	35				
130	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	183	171	150	180				
131	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage	
132	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	163	185	160	185				
133	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	422	415	414	414				
134	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	0	0	0	0				
135	Ullapara 11 MW PP (Summit)	Gas (SI/PP, REB)	4x2.90	11	11	8	6	8	8				
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	0	52				
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	113	55	113				
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	50	35	50				
139	Aminura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	0	0				
140	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	5	0	6	0				
**	Adani Power Jharkhanda Ltd	Coal (Import)	1x748	748	748	613	622	611	611				
Rajshahi Zone Total						2927	2905	1524	1805	1639	2124	220	100
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling	
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	180	180	180	180			Coal Shortage	
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	34	34	34	70				
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Majma. Talsila 5 MW Solar PP (Syma Power)	Solar (IPP)	1 x 8	8	8	1	0	8	0				
147	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6*20	115	115	35	114	35	115				
148	Lalmohith 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	7	0	30	0				
149	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	53	0	130	0				
Rangpur Zone Total						1030	950	310	328	417	365	85	85
Sub-total: Plants in operation						23954	23545	11051.0	13402	12586	14891	1559	2232
(B) Plants under long term maintenance/ contract expired													
150	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
151	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
152	Bosilia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	118	0	0	0	0	0				
153	Ashwaman 55 MW PP (Precision)	Gas (RPP)	17.4	35	0	0	0	0	0				
Sub-Total: Plants under long term maintenance/ contract expired						309	0	0	0	0	0	0	
Gross Total						24263	23545	11051	13402	12586	14891	1559	2232
(C) Actual data of 04.07.23 (Yesterday) Tuesday :													
01.	Max. Demand at eve. peak (Generation end)	:	13440 MW, at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :								
02.	Max. Demand at eve. peak (Sub-station end)	:	12847 MW, at =	21:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed	
03.	Highest Generation (Generation end)	:	13474 MW, at =	23:00 hrs		MW	MW	MW		MW	MW	MW	
04.	Minimum Generation (Generation end)	:	9961 MW, at =	7:00 hrs	Dhaka	3843	3843	0	Mymensingh	1101	1101	0	
05.	Day-peak Generation (Generation end)	:	11051 MW, at =	12:00 hrs	Chattogram	1350	1350	0	Sylhet	573	573	0	
06.	Evening-peak Generation (Generation end)	:	13402 MW, at =	21:00 hrs	Khulna	1819	1819	0	Barishal	499	499	0	
07.	Evening Peak Load-shed (Sub-station end)	:	36 MW, at =	21:00 hrs	Rajshahi	1386	1386	0	Rangpur	866	830	36	
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10481 MW, at =	5:00 hrs	Cumilla	1410	1410	0					
09.	Generation shortfall at evening peak due to :	:							Total	12847	12811	36	
	a) Gas/LF limitation	:	1274 MW										
	d) Coal supply Limitation	:	85 MW										
	b) Low water level in Kaptai lake	:	200 MW										
	c) Plants under shut down/ maintenance	:	2232 MW										
10.	Total Energy (Generation + India Import)	:	279.46 MCKWh										
	By Gas = 168.641 MCKWh		By Oil = 46.180 MCKWh										
	By Coal = 36.943 MCKWh		By Hydro = 0.822 MCKWh										
	By Solar= 1.948 MCKWh												
11.	Total Gas Supplied	:	1293.54 MMCFD										
(D) Forecast of 05.07.23 (Today) Wednesday :													
01.	Maximum Demand	:	13900 MW (Generation end)		04.	Maximum Load-shed	:	0 MW	At evening peak (Sub-station end)				
02.	Maximum Generation	:	14891 MW (Generation end)		05.	Total Generation	:	288.30 MCKWh					
03.	Reserve / Shortage	:	991 MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	:	36.0° C					

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation