

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 18-Jul-23

Page: 2

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak hour Generation	Energy Generated	Remarks
			Unit No. & Capacity	MW	MW	KWH	
1	Ghorasol Reconvert CAPP Unit-3 (GT)	PCB	1250	180	110	2911469	Under maint.
2	Ghorasol Reconvert CAPP Unit-4	PCB	1250	180	110	2911469	Gas shortage
3	Ghorasol TPF Unit-1	PCB	1250	180	110	4195000	Under maint.
4	Ghorasol 365 MW CCPP Unit-2	QAPP	1243+122	365	0	0	Under maint.
5	Ghorasol 76 MW PP (BM)	QAPP	3+3+35	108	0	0	Gas shortage
6	Haripur 412 MW CCPP	ECGB	272	20	0	0	Under maint.
7	Haripur 300 MW CCPP (PPCL)	IPP	1235+125	360	342	7606000	Gas shortage
8	Meghrajpur 400 MW CCPP (PPCL)	IPP	2150+1150	450	410	8631000	Gas shortage
9	Meghrajpur 100 MW (EC)	NEP	126.9	100	74	1225920	Fuel shortage
10	Meghrajpur CAPP Unit-1	NEP	1210+1110	335	310	7253445	Fuel short
11	Maharajpur 100 PP (Summit)	NEP	617	102	80	1805198	Engine problem
12	Maharajpur 58 MW PP (Summit)	IPP	217.08+111.3	55	55	1333645	Fuel shortage
13	Kemangan 100 MW PP (Powermax)	NEP	813.45	75	23	4445093	Under maint.
14	Narasingpur 22 MW PP (Dewan)	SIPP, REB	82.80	22	19	336060	Engine problem
15	210 MW Sidhupur TPF	PCB	1250	115	0	0	Under maint.
16	Sidhupur 210 MW GTPP	ECGB	2165	210	55	2917000	Gas shortage
17	Sidhupur 180 PP (Dewan)	NEP	126.9	100	15	1234460	Fuel shortage
18	Sidhupur 335 MW CCPP	ECGB	1217+118	335	330	7864023	Fuel shortage
19	Gadgaon 102 MW PP (Gadgaon Power)	IPP	129.804	102	74	1221858	Engine problem
20	Kashid 32 MW PP (Sumit)	IPP	77.5	0	0	0	Fuel shortage
21	Karavajpur 14 MW PP (Banco Energy)	IPP	818	54	54	523080	Engine problem
22	Koda 160 MW PP []	IPCB-PPCL	8717.08	149	130	2311120	Fuel shortage
23	Mangan 55 MW PP (Northern)	IPP	219.3	55	55	657819	Under maint.
24	Nashikpur 65 MW PP (Northern)	IPP	219.3	55	55	656997	Under maint.
25	Bansa 108 MW PP (EC)	IPP	128.775+13.5	0	0	0	Under maint.
26	Bansa 108 MW PP (EC)	SIPP, REB	23.6+19.73	80	42	902590	Engine problem
27	Mansa 33 MW PP (Summit)	SIPP, REB	438.73	33	25	530000	Engine problem
28	Rajapur 32 MW PP (Summit)	PCB	819.3	52	25	522500	Engine problem
29	Gadgaon 2 MW PP []	PCB	11.05	0	0	0	Fuel shortage
30	Tong 80 MW GTPP	IPP	18717.076	300	289	6766257	Under maint.
31	Koda 300 MW PP Unit-2 (Sumit)	IPP	289.4	300	207	4423051	Low demand
32	Kemanganpur 100 MW PP (Agreya)	IPP	11475.083	0	0	0	Contract Expired
33	Aurahi 100 MW PP (Agreya)	IPP	8.8523+8.9591	100	0	0	Contract Expired
34	Koda 160 MW PP Unit-1 (Sumit)	IPP	818.454+8.97	149	132	297079	Machine problem
35	Gadgaon 100 MW PP	PPCL	617.5	105	88	2128320	Fuel shortage
36	Meghrajpur 104 MW PP (PPCL)	IPP	18.576	104	54	1264320	Fuel shortage
37	Maharajpur 100 MW PP (PPCL)	IPP	818	162	162	1544000	Fuel shortage
38	Spectra Solar Plant Ltd	IPP	35	35	0	1947.78	On test
39	Kashid Parvati Power Generation Ltd.	IPP	18.473	65	14	555200	On test
Chhota area Total							86459338
41	Chhatrapati TPF Unit-1	PCB	1250	180	103	240000	Gas shortage
42	Chhatrapati TPF Unit-2	PCB	1250	180	0	0	Gas shortage
43	Rajapur 25 MW PP	PPCL	29.9	25	17	243448	Gas shortage
44	Tatkal 50 MW PP (Sumit)	IPP	26	20	0	68115	Fuel shortage
45	Pargana 50 MW PP (Sumit)	IPP	616.98	50	50	538060	Under maint.
46	Kodai Hiten Unit-1 & 2	PCB	2140+1750	230	40	1030440	Low Water level
47	Shikhar 22 MW []	PCB	1150+175	225	225	5251200	Under maint.
48	Shikhar 100 MW PP (Shikhar Station)	IPP	1750	150	0	0	Under maint.
49	Shikhar 100 MW PP (Shikhar Station)	IPP	617.5	105	68	1205199	Engine problem
50	Shikhar 100 MW PP (Shikhar Station)	IPP	1178.9	96	74	862499	Engine problem
51	Jahan 100 MW Unit-1 (Accor)	NEP	813.45	100	80	1476840	Fuel shortage
52	Jahan 100 MW Unit-2 (Accor)	IPP	813.5	100	100	1504000	Fuel shortage
53	Banskhari 22 MW PP (Sumit)	SIPP, PCB	87.73+19.34	22	11	261504	Engine problem
54	Chhatrapati 108 MW PP (ECPP)	IPP	187	108	12	107520	Fuel shortage
55	Kajur 1 MW Solar PP	PCB	1.488	0	0	1385	On test
56	Anveta 300 MW PP (Unit-1)	IPP	1717+24	300	258	2880473	Fuel shortage
57	Jodha Power	IPP	218.58+13.6	54	17	449441	Fuel shortage
58	Karnajpur Power Ltd.	IPP	18.419+8.5	110	51	802396	Fuel shortage
59	Jahan Unit-2 (Accor)	IPP	813.6	100	76	1376660	Fuel shortage
60	Anveta Energy Ltd.	IPP	872.2	116	68	1073555	Fuel shortage
61	Mishra 195 MW	IPCB-PPCL	18.579	163	180	1597454	On test
SE Power							0
Govt. Solar Wind							0
Chhatrapati area Total							24714238
61	Ashuganj TPF Unit-1	APSCCL	1750	0	0	0	Contract Expired
62	Ashuganj TPF Unit-4	APSCCL	1750	0	0	0	Contract Expired
63	Ashuganj TPF Unit-5	APSCCL	1750	0	0	0	Contract Expired
64	Ashuganj 225 MW CCPP	APSCCL	1142+175	221	209	4998000	Contract Expired
65	Ashuganj 450 MW CCPP (Sumit)	APSCCL	1750	360	310	8003000	11/1904
66	Ashuganj 450 MW CCPP (Sumit)	APSCCL	1750	360	0	0	Under maint.
67	Ashuganj 420 MW CCPP (Sumit)	APSCCL	284+1181	400	322	8281200	Under maint.
68	Ashuganj 50 MW PP []	APSCCL	143.088	45	45	1021480	Under maint.
69	Ashuganj 55 MW PP (Sumit)	QAPP	1974	0	0	0	Contract Expired
70	Ashuganj 105 MW PP (Sumit)	IPP	2079.79+118	105	76	1923636	Contract Expired
71	Ashuganj 81 MW PP (Sumit)	IPP	679.34	51	43	975394	Contract Expired
72	Ashuganj 100 MW PP (Sumit)	IPP	877.015	100	145	526000	Contract Expired
73	Tita 50 MW Peaking PP	PCB	67.92	52	38	931952	Machine problem
74	Chhatrapati 100 MW PP (Sumit)	IPP	1150+140	163	0	0	Under maint.
75	Chhatrapati 200 MW (Sumit)	IPP	1218.4	200	100	1216360	Under maint.
76	Fen 22 MW PP (Sumit)	SIPP, PCB	82.80	22	20	430008	Engine problem
77	Fen 11 MW PP (Sumit)	SIPP, REB	42.80	11	10	241140	Engine problem
78	Impet (Tigra)	Imported power	0	160	168	3750360	Under maint.
79	Jangala 33 MW PP (Sumit)	SIPP, PCB	479.73	33	33	803000	Under maint.
80	Jangala 57 MW PP (Sumit)	IPP	679.52	52	43	988366	Engine problem
81	Corilla 25 MW PP (Sumit)	SIPP, REB	273.67+96.87	25	20	453850	Contract Expired
82	Dandand 200 MW PP (B. Trac)	IPP	1547.4	200	0	0	Contract Expired
83	Far Lark Power	IPP	218.19+179.5	114	108	1101498	Engine problem
84	Chowmand 115 MW	IPP	129.78+2+1.3	113	76	616240	Fuel shortage
85	Shorok 5.5 MW []	IPP	218.2	54	17	449441	Fuel shortage
86	Chhatrapati 115 (Sumit)	IPP	474.5+2+2+2.5	115	95	1387200	Fuel shortage
Cumilla Area Total							38246425
87	Chhatrapati 100 MW CCPP	IPP	618+175	306	184	38246425	Gas shortage
88	Targal 32 MW PP (Sumit)	SIPP, PCB	82.80	22	16	383400	Engine problem
89	Jaharpur 50 MW PP (Sumit)	IPP	129.804	0	0	0	Under maint.
90	Barhathari 3 MW Solar Plant	IPP	19	3	0	8000	On test
91	Myerampur 200 MW PP (Unit-1)	IPP	9.7821	200	87	1698000	Fuel shortage
92	Jaharpur 115 MW PP (Sumit)	IPP	9.7821	115	85	693400	Fuel shortage
93	Subahar 50 MW Solar PP	IPP	50	80	0	171070	Fuel shortage
94	Targal Fall Power Gen 12 MW	IPP	479.7	12	12	288960	Fuel shortage
Bhymenasingh Area Total							814 232 2803372
95	Chhatrapati CCPP Phase-1	PCB	273+175	70	43	1040000	Machine problem
96	Chhatrapati CCPP Phase-2	PCB	273+175	90	39	920880	Machine problem
97	Kodara 180 MW CCPP (PP)	PCB	1150+154	180	112	2647718	ET under maint.
98	Shikhar 335 MW CCPP	PCB	2710	330	0	0	Under maint.
99	Fenchuganj 51 MW PP (Baranathari)	NEP	197.50	51	45	1070400	Under maint.
100	Fenchuganj 43 MW (Engine)	NEP	123.3+92.2	50	47	1120448	Under maint.
101	Holagunj 11 MW PP (Sumit)	SIPP, REB	42.80	11	5	106880	Machine problem
102	Shikhar CCPP Unit-1 & 2	PCB	2710	66	59	1426096	Under maint.
103	Shikhar 85 MW PP (Baranathari)	NEP	32+90	86	86	2059000	Under maint.
104	Shikhar 100 MW PP (Baranathari)	PCB	1750	100	0	0	Under maint.
105	Sybil 225 MW CCPP	PCB	1142+199	231	207	4718800	Under maint.
106	Sybil 20 MW GTPP	PCB	720	20	17	395000	Contract Expired
107	Sybil 50 MW PP (PPCL)	NEP	272	0	0	0	Contract Expired
108	Shikhar 25 MW PP (Sumit)	SIPP, REB	273.34	25	24	511104	Contract Expired
109	Bansa 141 MW CCPP (Sumit)	IPP	1722+1118	341	305	7360500	Fuel short
110	Banskhari 400 MW CCPP	IPP	289+134+1	400	240	850000	Under maint.
111	Sybil 160 MW PP (Sumit)	IPP	81.36	10	10	248450	Under maint.
112	Banskhari South 400 MW	PCB	400 MW	383	390	8937400	Under maint.
Sybil area Total							28933336
107	Banskhari 140 PP (Unit-3)	PCB	720	86	0	0	Fuel shortage
108	Banskhari 140 PP (Unit-3)	Imported power	2700	1000	791	21541818	Fuel shortage
109	Khula 15 PP MW (PPCL-2)	NEP	711.7	115	84	730560	Fuel shortage
110	Fairpur 50 MW Peaking PP	PCB	676.89	54	29	327840	Engine problem
111	Khula 200 MW CCPP	NWPPCL	1150+175	230	160	2091174	Engine problem
112	Chhatrapati 100 MW Peaking PP	PCB	1676.98	109	72	848832	Engine problem
113	Banskhari 415 MW CCPP	NEP	1279+102	410	115	3988008	Gas shortage
114	Nopora 40 MW PP (Banskhari)	NEP	57.5	40	40	228750	Under maint.
115	Nopora 100 MW PP (Banskhari)	IPP	707.4	0	0	0	Contract Expired
116	Rajapur 105 MW PP (Sumit)	IPP	678.645	105	54	869760	Fuel shortage
117	Maharajpur 100 MW PP	IPP	818	105	67	1410624	Fuel shortage
118	Maharajpur 100 MW PP	IPP	100	0	0	443320	Under maint.
119	Khula 330 MW CCPP (OL)	IPCB	1220+1110	220	200	2534131	On test
120	Rajapur 130 MW PP (Sumit)	NTP-PPCB	872	67	50	154648	On test
121	Khula 225 MW CCPP (OL)	NWPPCL	0	0	0	0	On test
Khula area Total							3847762
117	Banskhari 100 MW PP (Sumit)	IPP	717.076	110	100	2354688	Fuel shortage
118	Banskhari 30 MW PP (Sumit)	NEP	134.30	40	33	667233	Engine problem
119	Banskhari 30 MW CCPP	PCB	293+108	104	132	3198000	Machine problem
120	Banskhari 50 MW PP (Agreya)	QAPP	367.10	0	0	0	Contract Expired
121	Parga 100 MW	PPCL	2762	224	622	1579995	Machine problem
122	Banskhari 100 MW PP (Sumit)	IPP	220	220	228	5386391	Under maint.
123	United Parga Power Ltd.	IPP	818.5+17.5	150	150	1110000	Contract Expired
124	Banskhari 30 MW	IPP	209.1	307	0	0	Under maint.
Banskhari area Total							28473812
124	Banskhari 11 MW GTPP	PCB	173	255	1283	28473812	Under maint.
125	Banskhari 100 MW GTTP	PCB	1150	100	0	0	Gas shortage
126	Banskhari 50 MW Peaking PP	PCB	676.9	52	35	239768	Engine problem
127	Banskhari 70 MW Peaking PP	IPP	978.29	71	0	30910	Under maint.
128	Anveta 50 MW PP (Sumit)	NEP	171.79	26	28	68410	Engine problem
129	Kashid 50 MW PP (Sumit)	QAPP	676.9	34	34	788083	Engine problem
130	Banskhari 50 MW Peaking PP	PCB	67.7	50	22	43268	Engine problem
131	Singpur Unit-1 225 MW	NWPPCL	1150+175	210	0	0	Contract Expired
132	Singpur Unit-2 225 MW	NWPPCL	1150+175	22			