

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9554667, 9551095

Month July, 2023				Day : Tuesday				Date : 11.07.23				
Probable Maximum Demand :				15000 MW		Probable Maximum Generation :				15074 MW		
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 75.24 ft		Today = 75.31 ft		Rule Curve = 85.60 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	10.07.23 (Yesterday)		11.07.23 (Today)		10.07.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW			
					Day	Evening	Day	Evening	Machines shut down (MW)	Description/ Remarks		Probable start-up date
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	120	110	110	110			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	170	170	170	170			
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0			
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108	Gas Shortage	
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage	
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	327	342	330	330			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	410	450	450			
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	402	401	400	400			
11	Siddhirganj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	120	56	50	100			
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	322	330	320	320			
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	303	310	310	310			
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	50	74	32	102			
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	16	19	19	19			
17	Summit Power, Madhabdi+Ashulia	Gas (SIPP, REB)	8x3.67+7x8.73	80	80	42	42	38	38			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25			
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	22	22	24	24			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	25	8	25			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	88	88	88	88			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	82	130	82	130			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	54	0	54			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	240	293	293	293			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	112	132	135	135			
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	252	207	300	300			
27	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0			
28	Nabaganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	55	35	55			
29	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	35	55			
30	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	53	54	54	54			
31	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	35	162	17	162			
32	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	21	0	30	0			
33	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	34	17	35			
34	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	54	75	50	75			
35	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	60	74	55	74			
36	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	66	80	80	80			
37	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	36	23	20	36			
Dhaka Zone Total				6004	5822	3618	3907	3632	4104	213	375	
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	60	60	30	60	170	Low water level	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	102	103	110	110	77	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	1	0	5	0			
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	17	8	17			
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	7	0	20	0			
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	50	6	50			
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	34	68	34	68			
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	226	225	225	225			
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	88	258	88	280			
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	62	100	50	88			
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	33	34	33	33			
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	24	74	32	74			
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	11	11	11	11			
*	Malancha, Clp EPZ (United)	Gas	5x8.73+3x9.34			2	28	15	30			
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	5	12	12	12			
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17			
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	18	51	17	34			
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	63	76	50	75			
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRP)	8x13.45	100	100	58	80	58	80			
57	Chattogram 116 MW PP (Anilma Energy Ltd.)	HFO (IPP)	6x21.06	116	116	34	68	34	68			
58	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	54	160	54	163			
	SS Power Unit-1	Coal (IPP)				0	0	0	0			
	Cox's Bazar Wind PP	(Wind) (IPP)				2	6	15	10			
Chattogram Zone Total				2605	2545	915	1498	924	1505	247	330	
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	39	45	45	45			
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	206	209	200	210			
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	0	0	0	0	360	Under maint.	
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	300	310	330	330			
63	Ashuganj 420 MW CCPP(East)	Gas (APSCL)	1x284+1x116	400	400	409	322	350	350			
64	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	83	76	78	83	119	Gas Shortage	
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	43	43	43			
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	6	145	5	150			
67	Tilas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	36	36	44	45			
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under maint.	
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	51	100	50	120			
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	20	20	20			
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	10	10			
72	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33			
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	37	43	42	42			
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	20	20	20			
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	106	52	106			
76	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	76	9	76			
77	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17			
78	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	68	95	55	94			
**	Imphort (Tripura)	India		160	160	166	158	129	160			
Cumilla Zone Total				2904	2896	1568	1864	1532	1954	119	523	
79	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	11	32	30	35	170	Gas Shortage	
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	16	18	18			
81	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	19	85	20	85			
82	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	69	87	68	88			
83	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0			
84	Sutiekhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	51	0	50	0			
85	Tangail 22 MW PP(RPCL)	HFO (IPP)	4x6.7	22	22	12	12	12	12			
Mymensingh Zone Total				622	614	179	232	200	238	170	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	10.07.23 (Yesterday)		11.07.23 (Today)		10.07.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening				
86	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 & ST-1 Under maint.	
87	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	39	39	39	39		51	GT-4 Under maint.	
88	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	44	45	45	45				
89	Kushihara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	112	112		54	ST Under maint.	
90	Hobigani 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	3	5	5	5				
91	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	59	60	60				
92	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
93	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	83	86	86	86				
94	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	204	207	204	204				
95	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	17	17	17	18				
96	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
97	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	24	24	24				
98	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	320	305	300	300				
99	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	0	240	80	300				
100	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	350	390	376	380				
101	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
102	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.4+5*2	50	50	47	47	44	44				
Sylhet Zone Total						2472	2427	1348	1629	1445	1670	0	562
103	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
104	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	135	115	105	115				
105	Fairdipor 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	8	29	20	33				
106	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	25	72	36	70				
107	Khulna 225 MW CCPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	100	150	150	225				
108	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	35	54	35	55				
109	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	15	67	25	68				
110	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	58	0	100	0				
111	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	32	64	80	95				
112	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	40	8	40				
113	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	0	360	380	380				
114	Khulna 330 MW CCPP (GT)	Gas/HSD (B/PDB)	1x220	220	220	100	200	200	200				
**	Bheramara (HVDC)	India		1000	1000	904	791	927	927				
Khulna Zone Total						3125	3121	1412	1942	2066	2208	0	0
115	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	100	100	100	100				
116	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	22	33	25	27				
117	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	134	132	130	130				
118	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	600	622	622	622	622		Coal Shortage	
119	Potukhalhi 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	150	17	150				
120	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	0	0	0	0	307		Coal Shortage	
121	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	223	226	220	220				
Barishal Zone Total						2265	2265	1096	1263	1114	1249	929	0
122	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0				
123	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	35	0	35				
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	150	175	150	200				
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	0				
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	90	0	90				
128	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	26	22	22	27				
129	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	34	34	34	34				
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	35	35	35	35				
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	0	0	0	0		210	Under Maint.	
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	125	126	128	132	94		Gas Shortage	
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	122	124	128	129	96		Gas Shortage	
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	270	304	300	300	110		Gas Shortage	
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	0	0	0	0				
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8				
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	0	8				
138	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	55	55	35	55				
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	45	50	35	50				
140	Ammura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	28	28	28	28				
141	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	5	0	6	0				
**	Adani Power Jharkhanda Ltd	Coal (Import)	1x748	748	748	592	627	600	600				
Rajshahi Zone Total						2927	2905	1495	1721	1509	1731	300	310
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
143	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling	
144	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	240	220	230	230	54		Coal Shortage	
145	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	34	70	34	70				
147	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
148	Majma. Talsia 9 MW Solar PP (Syma Power)	Solar (IPP)	1 x 9	9	8	2	0	8	0				
149	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6*20	115	115	52	113	35	115				
150	Lalmoharhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	4	0	30	0				
151	Teesa Solar Limited	Solar (IPP)	1 x 200	200	200	99	0	130	0				
Rangpur Zone Total						1030	950	431	403	467	415	139	85
Sub-total: Plants in operation						23954	23545	12062.0	14459	12889	15074	2117	2185
(B) Plants under long term maintenance/ contract expired													
152	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
153	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
154	Bosilla 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
155	Ashugani 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	0	0	0	0				
Sub-Total: Plants under long term maintenance/ contract expired						309	0	0	0	0	0	0	0
Gross Total						24263	23545	12062	14459	12889	15074	2117	2185
(C) Actual data of 10.07.23 (Yesterday) Monday :													
01.	Max. Demand at eve. peak (Generation end)	:	14765 MW, at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :								
02.	Max. Demand at eve. peak (Sub-station end)	:	14100 MW, at =	21:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed	
03.	Highest Generation (Generation end)	:	14459 MW, at =	21:00 hrs	Dhaka	4943	4908	35	Mymensingh	1131	1051	80	
04.	Minimum Generation (Generation end)	:	10967 MW, at =	4:00 hrs	Chattogram	1269	1269	0	Sylhet	564	564	0	
05.	Day-peak Generation (Generation end)	:	12062 MW, at =	12:00 hrs	Khulna	1830	1828	2	Barishal	462	462	0	
06.	Evening-peak Generation (Generation end)	:	14459 MW, at =	21:00 hrs	Rajshahi	1530	1530	0	Rangpur	966	801	165	
07.	Evening Peak Load-shed (Sub-station end)	:	292 MW, at =	21:00 hrs	Cumilla	1405	1395	10					
08.	Minimum Generation Forecast up to 8:00 hrs.	:	11675 MW, at =	5:00 hrs					Total	14100	13808	292	
09.	Generation shortfall at evening peak due to :	:							(a) Gas =	167257169 Taka	(c) Coal =	170809691 Taka	
	a) Gas/LF limitation	:	1808 MW						(b) Oil =	1081070404 Taka	Total =	1419137264 Taka	
	d) Coal supply Limitation	:	139 MW										
	b) Low water level in Kaptai lake	:	170 MW										
	c) Plants under shut down/ maintenance	:	2185 MW										
10.	Total Energy (Generation + India Import)	:	292.55 MKWh										
	By Gas =	151.341 MKWh	By Oil =	80.414 MKWh									
	By Coal =	32.463 MKWh	By Hydro =	1.039 MKWh									
	By Solar =	1.922 MKWh											
11.	Total Gas Supplied	:	1177.36 MMCFD										
(D) Forecast of 11.07.23 (Today) Tuesday :													
01.	Maximum Demand	:	15000 MW (Generation end)		04.	Maximum Load-shed	:	0 MW	At evening peak (Sub-station end)				
02.	Maximum Generation	:	15074 MW (Generation end)		05.	Total Generation	:	303.50 MKWh					
03.	Reserve / Shortage	:	74 MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	:	34.4° C					