

**Bangladesh Power Generation Board
DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation
Tel : 9564667, 9551095

Month July, 2023			Day : Wednesday				Date : 12.07.23							
Probable Maximum Demand : 15000 MW			Probable Maximum Generation : 15429 MW											
Water Level of Kaptai Lake at 06:00 AM			Yesterday = 75.31 ft				Today = 75.32 ft				Rule Curve = 85.60 ft			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Dered/ Present Capacity (MW)	11.07.23 (Yesterday)		12.07.23 (Today)		Rule Curve = 85.60 ft		Status of Machines under shut-down/ Maintenance			
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date		
					Day	Evening	Day	Evening	Gas/Coal/Water Limitation MW	Machines shut down (MW)				
(A) Plants in operation:														
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work		
2	a) Ghorasal Repowered CCPP Unit-4 b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	180	110	120	120	120					
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0					
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	3x3.35	108	108	0	0	0	0	108		Gas Shortage		
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage		
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0					
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	330	301	280	280					
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	400	370	370					
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling		
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	401	401	380	380					
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0					
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	331	315	230	230					
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	299	291	300	300					
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	48	101	33	102					
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	19	19	19					
17	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	8x3.67+7x8.73	80	80	40	38	42	42					
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25					
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	18	18	24	24					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	25	8	25					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	88	88	88	88					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	82	132	82	130					
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	54					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	265	292	115	293					
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	132	132	149	149					
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	245	295	300	300					
27	Aurahat 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0					
28	Nabaganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	55	35	55					
29	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	35	55					
30	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	53	72	54	72					
31	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	54	162	72	162					
32	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	28	0	30	0					
33	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	34	17	35					
34	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	50	58	58	75					
35	Meghnaghat 100 MW(WIEL)	HFO (NENP)	12x8.9	100	100	41	74	50	74					
36	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	80	80	80	80					
37	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	100	75	22	22	22					
Dhaka Zone Total			6004	5822	3537	3884	3260	3786	213	375				
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	60	60	60	60	170		Low water level		
39	a) Chattogram TPP-1 b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	105	108	110	110	72		Gas Shortage Under maint.		
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	3	0	5	0	180		Under maint.		
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	17	8	17					
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	15	0	20	0					
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	50	6	50					
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	68	68	51	68					
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Under maint.		
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	219	225	225	225					
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	88	280	88	280					
48	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	50	87	50	88					
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	32	34	34	34					
50	Hathazeri 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	32	48	32	70					
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	10	10	11	11					
*	Malancha, Clq EPZ (United)	Gas	5x8.73+3x9.34			2	28	2	25					
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	10	30	12	30					
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	35	17	35					
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	51	51	51	51					
55	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	50	76	50	75					
56	Juldah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	58	70	58	80					
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	34	107	34	107					
58	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	53	160	54	163					
59	SS Power Unit-1	Coal (IPP)				0	0	0	0					
	Cox's Bazar Wind PP	(Wind) (IPP)				0	11	15	10					
Chattogram Zone Total			2605	2545	971	1555	993	1571	242	330				
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	43	45	45	45					
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	206	211	200	200					
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	0	0	0	0	360		Under maint.		
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	320	310	310	320					
63	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	325	317	350	350					
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	55	8	8	8	187		Gas Shortage		
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	43	43	43					
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	5	135	5	150					
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	30	45	44	45					
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163		Under maint.		
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	51	104	50	120					
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	20	20	20					
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	10	10					
72	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33					
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	34	43	43	43					
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	14	20	20	20					
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	106	52	106					
76	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	66	9	76					
77	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17					
78	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	57	115	55	115					
**	limpoort (Tripura)	India		160	160	148	154	129	160					
Cumilla Zone Total			2904	2896	1435	1802	1443	1881	187	523				
79	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	10	30	25	30	172		Gas Shortage		
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	19	18	18					
81	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	19	85	20	85					
82	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	69	108	78	105					
83	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0					
84	Sutakhalai 50 MW Solar PP	Solar (IPP)	1x50	50	50	13	0	50	0					
85	Tangail 22 MW PP(RPCL)	HFO (IPP)	4x6.7	22	22	12	12	12	12					
Mymensingh Zone Total			622	614	142	254	205	250	172	0				

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	11.07.23 (Yesterday)		12.07.23 (Today)		11.07.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Gas/Coal/Oil/ Water Limitation MW	Machines shut down (MW)		
86	Fenchugonj CDDP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43	27	GT-1 & ST-1 Under maint.	
87	Fenchugonj CDDP Phase-2	Gas (PDB)	2x35+1x35	104	90	39	39	39	39	51	GT-4 Under maint.	
88	Fenchugonj 51 MW PP (Barakattullah)	Gas (RPP)	19x2.90	51	51	42	45	45	45			
89	Kushiera 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	112	112	54	ST Under maint.	
90	Hobganga 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	5	5	5			
91	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	7x3.5	70	66	59	60	60	60			
92	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	330	Under maint.	
93	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	3x2.90	86	86	86	84	86	86			
94	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	204	207	204	204			
95	Sylhet 20 MW GTPP	Gas (PDB)	1x 20	20	20	17	17	17	18			
96	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10			
97	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	24	24	24			
98	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	310	300	300	300			
99	Bibiana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	80	366	400	400			
100	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	350	364	376	380			
101	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0	100	Under project work	
102	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.4+5*2	50	50	47	47	44	44			
Sylhet Zone Total												
103	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	15	0	0	0	0	0	562	
104	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	100	130	240	240			
105	Fairpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	10	25	20	33			
106	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	30	60	36	70			
107	Khulna 225 MW CCPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	0	205	150	225			
108	Rupsha 105 MW PP (Oron rupsha)	HFO (IPP)	6x18.445	105	105	36	36	35	35			
109	Madhumat 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	15	67	15	68			
110	Mongla Oron 100 MW Solar PP	Solar (IPP)	100	100	44	0	100	0	0			
111	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	31	95	80	95			
112	Noapara 40 MW PP (Khaniahan Ali)	HFO (NENP)	5*8.5	40	40	0	24	8	40			
113	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	365	374	370	370	243	Coal Shortage	
114	Khulna 330 MW CCPP (GT)	Gas/HSD	1x220	220	220	180	200	200	200			
**	Bheramara (HVDC)	India	1000	1000	910	814	930	930	930			
Khulna Zone Total												
115	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	83	98	100	100			
116	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	23	32	25	27			
117	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	136	136	135	135			
118	Payra 1320 MW TTP	Coal (BCPCL)	2x622	1244	1244	622	622	622	622	622	Coal Shortage	
119	Potukhal 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	150	17	150			
120	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	0	0	0	0	307	Coal Shortage	
121	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	226	220	220	220			
Barishal Zone Total												
122	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage	
123	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Under maint.	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	35	0	35			
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	200	200	150	200			
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	0			
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	92	0	90			
128	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	34	50	42	50			
129	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	25	35	35	35			
130	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	0	0	0	0	210	Under Maint.	
131	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	121	0	0	0	220	Gas Shortage	
132	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	118	166	170	170	54	Gas Shortage	
133	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	241	416	380	400			
134	Bogra 22 MW PP (GGB)	Gas (RPP)	6x4.0	22	22	0	0	0	0			
135	Ulipara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	0	8	8			
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	0	8			
137	Baoura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	55	35	55			
138	Baoura 113 MW (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	50	35	50			
139	Amnura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	28	21	28	28			
140	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	3	0	6	0			
**	Adani Power Jharkhanda Ltd	Coal (Import)	1x748	748	748	618	627	1050	1050			
Rajshahi Zone Total												
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Coal Shortage	
142	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overhauling	
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	220	220	220	220	54	Coal Shortage	
144	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	27	70	34	70			
146	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
147	Majma. Tatala 5 MW Solar PP (Syrpa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0			
148	Teesta 119MW PP (Energypac)	HFO (IPP)	6*20	119	115	36	114	35	115			
149	Lalmohar 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	6	0	30	0			
149	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	64	0	130	0			
Rangpur Zone Total												
Sub-total: Plants in operation												
(B) Plants under long term maintenance/ contract expired												
150	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			
151	Katcott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			
152	Bosilia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			
153	Ashugani 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	0	0	0	0			
Sub-Total: Plants under long term maintenance/ contract expired												
Gross Total												
(C) Actual data of 11.07.23 (Yesterday) Tuesday :												
01.	Max. Demand at eve. peak (Generation end)	: 14921 MW, at = 21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
02.	Max. Demand at eve. peak (Sub-station end)	: 14322 MW, at = 21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW		
03.	Highest Generation (Generation end)	: 14691 MW, at = 21:00 hrs	Dhaka	4899	4887	12	Mymensingh	1192	1095	97		
04.	Minimum Generation (Generation end)	: 11487 MW, at = 9:00 hrs	Chattogram	1439	1439	0	Sylhet	586	586	0		
05.	Day-peak Generation (Generation end)	: 12178 MW, at = 12:00 hrs	Khulna	1839	1839	0	Barishal	463	463	0		
06.	Evening-peak Generation (Generation end)	: 14691 MW, at = 21:00 hrs	Rajshahi	1554	1554	0	Rangpur	947	836	111		
07.	Evening Peak Load-shed (Sub-station end)	: 220 MW, at = 21:00 hrs	Cumilla	1403	1403	0						
08.	Minimum Generation Forecast up to 8:00 hrs.	: 11475 MW, at = 5:00 hrs	Total : 14322 Demand, 14102 Supply, 220 Load Shed									
09.	Generation shortfall at evening peak due to :		13. Fuel cost : (a) Gas = 162169710 Taka, (c) Coal = 169677212 Taka, (b) Oil = 1043787068 Taka, Total = 1375633991 Taka									
a)	Gas/LF limitation	: 2161 MW	14. Maximum Temperature in Dhaka was : 33.4° C									
c)	Coal supply Limitation	: 139 MW	15. Export through East-West interconnections :									
b)	Low water level in Kaptai lake	: 170 MW	At evening peak-hour : 12178 MW, at 21:00 hrs									
c)	Plants under shut down/ maintenance	: 2185 MW	Maximum : 46 MW, at 7:00 hrs									
10.	Total Energy (Generation + India Import)	: 301.36 MCKWh	Energy : 0 MCKWh									
	By Gas = 148.651 MCKWh	By Oil = 79.845 MCKWh										
	By Coal = 44.858 MCKWh	By Hydro = 1.410 MCKWh										
	By Solar = 1.454 MCKWh											
11.	Total Gas Supplied	: 1071.79 MMCFD										
(D) Forecast of 12.07.23 (Today) Wednesday :												
01.	Maximum Demand	: 15000 MW (Generation end)	04.	Maximum Load-shed	: 0 MW (Sub-station end)							
02.	Maximum Generation	: 15429 MW (Generation end)	05.	Total Generation	: 307.70 MCKWh							
03.	Reserve / Shortage	: 429 MW (Generation end)	06.	Probable Max. Temperature in Dhaka :	33.4° C							

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation