

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month July, 2023					Day : Saturday				Date : 15.07.23					
Probable Maximum Demand : 14400 MW					Probable Maximum Generation : 15812 MW									
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 75.28 ft		Today = 75.20 ft		Rule Curve = 86.24 ft.					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	14.07.23 (Yesterday)		15.07.23 (Today)		14.07.23 (Yesterday)		15.07.23 (Today)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Water Limitation MW		Machines shut down (MW)			
					Day	Evening	Day	Evening						
(A) Plants in operation:														
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260		Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	160	160	160	160					
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180					
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0					
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108			Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105			Gas Shortage	
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0					
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	313	332	330	330					
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450					
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115		Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	406	404	400	412					
11	Siddhirganj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	61	96	70	96					
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	328	300	330					
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	258	309	300	310					
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	40	55	55	55					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	24	16	48	102					
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	19	19	19					
17	Summit Power(Madhabdi-Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	38	39	40	40					
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25					
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	23	24	24	24					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	25	8	25					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	35	88	88	88					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	60	119	82	129					
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	54	17	54					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	16x17.076	300	300	62	112	112	112					
25	Kodda 148 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	35	148	34	148					
26	Keraniganj 300 MW PP (AFR)	HSD (IPP)	25x61.4	300	300	0	0	300	300					
27	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	55	35	55					
28	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	35	55					
29	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	65	55	54	55					
30	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	72	90	72	162					
31	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	36	0	30	0					
32	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	17					
33	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	12	35	58	75					
34	Meghnaghat 100 MW(EL)	HFO (NENP)	12x8.9	100	100	10	28	50	70					
35	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	82	82	85	85					
36	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	22	21	22	22					
Dhaka Zone Total				5904	5722	2583	3422	3500	3986	213	375			
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	60	60	60	60	170			Low water level	
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	100	100	100	80			Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180		Under maint.	
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	2	0	5	0					
40	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	17	8	17					
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	3	0	20	0					
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	46	6	50					
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	17	17	51					
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150		Under maint.	
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	226	227	225	225					
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	88	279	88	280					
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	37	62	38	62					
48	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	50	33	33	33					
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	66	32	66					
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	10	10	10	10					
*	Malancha, Ctg EP2 (United)	Gas	5x8.73+3x9.34			41	36	10	30					
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	5	30	12	30					
52	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	35					
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	34	34	34	34					
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	38	63	38	65					
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	25	58	35	58					
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	34	87	34	87					
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	53	53	54	163					
	SS Power Unit-1	Coal (IPP)				0	0	0	0					
	Cox's Bazar Wind PP	(Wind) (IPP)				0	0	15	10					
Chattogram Zone Total				2605	2545	854	1295	891	1466	250	330			
58	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	5	5	5	5					
59	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+175	221	221	182	200	200	200					
60	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	260	260	260	260					
61	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	280	280	300	300					
62	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	230	230	230	230					
63	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20'9.73+1'16	195	195	0	0	0	0	195			Gas Shortage	
64	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51					
65	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	2	100	5	150					
66	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	36	36	36	36					
67	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163		Under maint.	
68	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	51	104	50	100					
69	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	20	20					
70	Feni 11 MW PP (Doreen)	Gas (SIPP, PDB)	4x2.90	11	11	8	10	10	10					
71	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	32	33	33	33					
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	16	25	43	43					
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	20	20	20					
74	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	83	88	52	114					
75	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	9	97	9	97					
76	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17					
77	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	57	115	55	115					
**	Impoort (Tirupura)	India		160	160	148	154	146	169					
Cumilla Zone Total				2904	2896	1507	1845	1542	1970	195	163			
78	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	26	31	30	35	171			Gas Shortage	
79	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	0	18	18					
80	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	19	85	20	85					
81	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	200	87	85	85					
82	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0					
83	Sutiakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	35	0	50	0					
84	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	12	8	12	12					
Mymensingh Zone Total				622	614	312	211	217	235	171	0			

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	14.07.23 (Yesterday)		15.07.23 (Today)		14.07.23 (Yesterday)		Status of Machines under shut-down/ Maintenance			
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date		
						Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)				
85	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 & ST-1 Under maint.			
86	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	38	39	39	39		51	GT-4 Under maint.			
87	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	47	47	45	47						
88	Kushiera 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	80	112	112	112		54	ST Under maint.			
89	Hobigani 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11						
90	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	58	60	60						
91	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.			
92	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	84	84	86	86						
93	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	207	204	206	206						
94	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	17	17	17	17						
95	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	8	8	8						
96	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	24	24	24						
97	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	295	310	300	310						
98	Bibiyan-II 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	307	392	400	400						
99	Bibiyan South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	375	388	376	395						
100	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work			
101	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.4+5*2	50	50	45	48	44	48						
Sylhet Zone Total						2472	2427	1631	1785	1771	1806	0	562		
102	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0						
103	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	260	295	250	300						
104	Fairdip 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	21	20	30						
105	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	36	70						
106	Khulna 225 MW CAPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	120	120	150	225						
107	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	4	35	35	35						
108	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	15	48	50	105						
109	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	103	0	100	0						
110	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	19	16	80	95						
111	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	24	8	24						
112	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	373	306	300	310	311		Coal Shortage			
113	Khulna 330 MW CAPP (GT)	Gas/HSD (BDFD)	1x220	220	220	0	0	200	200						
**	Bheramara (HVDC)	India		1000	1000	887	758	920	920						
Khulna Zone Total						3125	3121	1781	1623	2149	2314	311	0		
114	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	32	16	32						
115	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	18	30	25	30						
116	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	136	136	135	136						
117	Payra 1320 MW TTP	Coal (BCPCL)	2x622	1244	1244	1192	1244	1244	1244	0					
118	Potukhalhi 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	54	17	150						
119	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	0	0	0	0	307		Coal Shortage			
120	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	225	220	225						
Barishal Zone Total						2265	2265	1599	1721	1657	1817	307	0		
121	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage			
122	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Under maint.			
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	35						
124	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	150	200						
125	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	21	0	21						
126	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	92	0	92						
127	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	28	22	28						
128	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	34	0	42	42						
129	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	27	0	30						
130	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Under Maint.			
131	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage			
132	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	204	209	200	200						
133	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	377	422	400	414						
134	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	0	0	0	0	0						
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	6	8	8						
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	50	50						
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	55	35	55						
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	50	35	50						
139	Ammura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	21	14	28	28						
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	2	0	6	0						
**	Adani Power Jharkhanda Ltd	Coal (Import)	2x748	1496	1496	615	609	600	610						
Rajshahi Zone Total						3675	3631	1331	1541	1576	1863	291	310		
140	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage			
141	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling			
141	Barapukuria 275 MW TTP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170	104		Coal Shortage			
142	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
143	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	0	3	34	70						
144	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
145	Mapara Taluk 9 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 9	9	9	1	0	8	0						
146	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6*20	115	115	35	114	35	115						
147	Lalmoharhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	2	0	30	0						
148	Teesa Solar Limited	Solar (IPP)	1 x 200	200	200	73	0	130	0						
Rangpur Zone Total						1030	950	281	287	407	355	189	85		
Sub-total: Plants in operation						24602	24171	11879.0	13730	13710	15812	1927	1825		
(B) Plants under long term maintenance/ contract expired															
149	Jamailpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0						
150	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0						
151	Bosilia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0						
152	Ashugani 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	0	0	0	0						
Sub-Total: Plants under long term maintenance/ contract expired						309	0	0	0	0	0	0	0		
Gross Total						24911	24171	11879	13730	13710	15812	1927	1825		
(C) Actual data of 14.07.23 (Yesterday) Friday :															
01.	Max. Demand at eve. peak (Generation end)	:	0	MW, at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
02.	Max. Demand at eve. peak (Sub-station end)	:	13259	MW, at =	21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW		
03.	Highest Generation (Generation end)	:	13775	MW, at =	22:00 hrs	Dhaka	4526	4526	0	Mymensingh	1110	1055	55		
04.	Minimum Generation (Generation end)	:	11075	MW, at =	9:00 hrs	Chattogram	1267	1267	0	Sylhet	567	567	0		
05.	Day-peak Generation (Generation end)	:	11879	MW, at =	12:00 hrs	Khulna	1739	1739	0	Barishal	429	429	0		
06.	Evening-peak Generation (Generation end)	:	13730	MW, at =	21:00 hrs	Rajshahi	1394	1394	0	Rangpur	861	782	79		
07.	Evening Peak Load-shed (Sub-station end)	:	134	MW, at =	21:00 hrs	Cumilla	1367	1367	0						
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10930	MW, at =	5:00 hrs										
09.	Generation shortfall at evening peak due to :	:				Total						13259	13125	134	
a)	Gas/LF limitation	:	1568	MW		(a) Gas = 171064106 Taka						(c) Coal = 289665852 Taka			
b)	Coal supply Limitation	:	189	MW		(b) Oil = 768181807 Taka						Total = 1228911765 Taka			
c)	Low water level in Kaptai lake	:	170	MW											
d)	Plants under shut down/ maintenance	:	1825	MW											
10.	Total Energy (Generation + India Import)	:	293.63	MW											
	By Gas = 154.379 MKWH			By Oil =	57.403 MKWH										
	By Coal = 54.075 MKWH			By Hydro =	1.451 MKWH										
	By Solar = 1.945 MKWH														
11.	Total Gas Supplied	:	1175.99	MMCFD											
(D) Forecast of 15.07.23 (Today) Saturday :															
01.	Maximum Demand	:	14400	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)				
02.	Maximum Generation	:	15812	MW	(Generation end)	05.	Total Generation	:	306.95	MW					
03.	Reserve / Shortage	:	1412	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	35.1° C						

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation