

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month July, 2023				Day : Sunday				Date : 16.07.23					
Probable Maximum Demand : 15200 MW				Probable Maximum Generation : 15540 MW				Rule Curve = 86.24 ft.					
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 75.20 ft Today = 75.12 ft									
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	15.07.23 (Yesterday)		16.07.23 (Today)		15.07.23 (Yesterday)		16.07.23 (Today)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Water Limitation MW		Machines shut down (MW)		
					Day	Evening	Day	Evening					
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260		Under project work
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	160	160	160	160				
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180				
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0				
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108			Gas Shortage
5	Tong 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105			Gas Shortage
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0				
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	332	326	330	330				
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	420	450	450	450				
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115		Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	406	400	400	412				
11	Siddhirganj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	96	194	150	200				
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	330	330	300	330				
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	306	286	280	290				
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	40	55	55	55				
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	24	83	48	83				
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	19	19	19				
17	Summit Power(Madhabdi-Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	40	40	40	41				
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25				
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	22	22	22	22				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	25	8	25				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	35	88	88	88				
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	64	130	82	130				
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	54				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	16x17.076	300	300	107	183	112	145				
25	Kodda 148 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	23	149	34	148				
26	Keraniganj 300 MW PP (AFR)	HSD (IPP)	25x61.4	300	300	0	0	300	300				
27	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	35	35	55				
28	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	34	55				
29	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	105	36	54	55				
30	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	72	144	72	144				
31	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	36	0	30	0				
32	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	30	17	17	17				
33	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	50	75	58	75				
34	Meghnaghat 100 MW(EL)	HFO (NENP)	12x8.9	100	100	27	68	50	70				
35	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	75	80	80	80				
36	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	11	11	22				
Dhaka Zone Total				5904	5722	3119	3720	3541	4061	213	375		
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	60	60	30	60	170			Low water level
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	100	100	100	80			Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180		Under maint.
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	3	0	5	0				
40	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	17	8	17				
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	15	0	20	0				
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	46	6	50				
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	17	17	34				
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150		Under maint.
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	222	226	225	225				
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	87	279	88	280				
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	37	50	38	50				
48	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	32	34	33	34				
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	16	66	32	66				
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	10	10	10	10				
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			6	20	10	20				
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	25	12	25				
52	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	36	17	36				
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	34	34	34	34				
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	38	50	38	50				
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	25	58	35	58				
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	34	87	34	87				
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	53	163	54	163				
	SS Power Unit-1	Coal (IPP)				0	0	0	0				
	Cox's Bazar Wind PP	(Wind) (IPP)				0	0	15	10				
Chattogram Zone Total				2605	2545	820	1378	861	1409	250	330		
58	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	15	20	5	20				
59	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+175	221	221	208	205	200	210				
60	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	230	230	230	230				
61	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	270	270	270	270				
62	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	230	230	230	230				
63	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20'9.73+1'16	195	195	0	0	0	0	195			Gas Shortage
64	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51				
65	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	5	118	5	150				
66	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	29	35	35	35				
67	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163		Under maint.
68	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	51	100	50	100				
69	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	20	20	20				
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	0	10	10				
71	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	0	33	33	33				
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	30	34	34	34				
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	20	20	20				
74	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	88	106	52	114				
75	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	9	97	9	95				
76	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17				
77	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	54	115	55	115				
**	Importo (Tripura)	India		160	160	156	164	146	169				
Cumilla Zone Total				2904	2896	1482	1865	1472	1923	195	163		
78	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	30	92	60	90	110			Gas Shortage
79	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	19	18	19				
80	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	19	85	20	85				
81	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	68	88	85	88				
82	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0				
83	Sutiakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	17	0	50	0				
84	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	12	12	12	12				
Mymensingh Zone Total				622	614	166	296	247	294	110	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	15.07.23 (Yesterday)		16.07.23 (Today)		15.07.23 (Yesterday)		Status of Machines under shut-down/ Maintenance			
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date		
						Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)				
85	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 & ST-1 Under maint.			
86	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	29	30	30	30		60	GT-4 Under maint.			
87	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	44	47	45	47						
88	Kushiera 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	112	112		54	ST Under maint.			
89	Hobigunj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11						
90	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	58	58	60	60						
91	Shajibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.			
92	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	81	84	86	86						
93	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	204	204	200	204						
94	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	17	17	17	17						
95	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	8	10						
96	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	24	20	20	24						
97	Bibiara-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	285	290	300	300						
98	Bibiara-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	368	367	400	400						
99	Bibiara South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	392	260	250	260						
100	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work			
101	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.4+5*2	50	50	47	48	44	48						
Sylhet Zone Total						2472	2427	1725	1601	1626	1652	0	571		
102	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0						
103	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	310	235	200	200						
104	Fairdipor 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	23	20	30						
105	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	0						
106	Khulna 225 MW CCPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	120	222	150	225						
107	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	35	36	35	36						
108	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	105	50	105						
109	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	60	0	100	0						
110	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	0	98	80	98						
111	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	24	8	24						
112	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	308	316	300	310	301		Coal Shortage			
113	Khulna 330 MW CCPP (GT)	Gas/HSD (BFDPC)	1x220	220	220	0	0	200	200						
**	Bheramara (HVDC)	India		1000	1000	909	766	920	920						
Khulna Zone Total						3125	3121	1742	1825	2063	2148	301	0		
114	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	50	16	50						
115	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	20	31	25	31						
116	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	130	137	135	137						
117	Payra 1320 MW TTP	Coal (BCPCL)	2x622	1244	1244	1140	1244	1244	1244	0					
118	Potukhalhi 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	150	17	150						
119	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	0	0	0	0	307		Coal Shortage			
120	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	225	222	220	225						
Barishal Zone Total						2265	2265	1532	1834	1657	1837	307	0		
121	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage			
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.			
122	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	35	0	35						
123	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	150	200						
124	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	28	0	28						
125	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	93	0	93						
126	Katakhalhi 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	29	22	29						
127	Katakhalhi 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	42	42	42						
128	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	27	0	30						
129	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	0	0	0	0		210	Under Maint.			
130	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage			
131	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	170	183	170	180						
132	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	417	427	400	414						
133	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	0	0	0	0						
134	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8						
135	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	52	50	52						
136	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	57	35	55						
137	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	50	35	50						
138	Ammura 50 MW PPS(Sinha)	HFO (NENP)	7x7.79	50	28	0	28	28	28						
139	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	2	0	6	0						
**	Adani Power Jharkhanda Ltd	Coal (Import)	2x748	1496	1496	616	607	600	610						
Rajshahi Zone Total						3675	3631	1283	1666	1546	1854	291	310		
140	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage			
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling			
141	Barapukuria 275 MW TTP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170	104		Coal Shortage			
142	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
143	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	34	77	34	77						
144	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
145	Majma. Talsia 9 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 9	9	9	0	0	8	0						
146	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6*20	119	115	36	113	35	115						
147	Lalmoharhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	35	0	30	0						
148	Teesa Solar Limited	Solar (IPP)	1 x 200	200	200	69	0	130	0						
Rangpur Zone Total						1030	950	350	360	407	362	189	85		
Sub-total: Plants in operation						24602	24171	12219.0	14545	13420	15540	1856	1834		
(B) Plants under long term maintenance/ contract expired															
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0						
150	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0						
151	Bosilia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0						
152	Ashugani 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	0	0	0	0						
Sub-Total: Plants under long term maintenance/ contract expired						309	0	0	0	0	0	0	0		
Gross Total						24911	24171	12219	14545	13420	15540	1856	1834		
(C) Actual data of 15.07.23 (Yesterday) Saturday :															
01.	Max. Demand at eve. peak (Generation end)	:	14545 MW, at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :										
02.	Max. Demand at eve. peak (Sub-station end)	:	14028 MW, at =	21:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed			
03.	Highest Generation (Generation end)	:	14545 MW, at =	21:00 hrs		MW	MW	MW		MW	MW	MW			
04.	Minimum Generation (Generation end)	:	10930 MW, at =	8:00 hrs	Dhaka	4918	4918	0	Mymensingh	1128	1128	0			
05.	Day-peak Generation (Generation end)	:	12219 MW, at =	12:00 hrs	Chattogram	1373	1373	0	Sylhet	598	598	0			
06.	Evening-peak Generation (Generation end)	:	14545 MW, at =	21:00 hrs	Khulna	1761	1761	0	Barishal	424	424	0			
07.	Evening Peak Load-shed (Sub-station end)	:	0 MW, at =	21:00 hrs	Rajshahi	1495	1495	0	Rangpur	966	966	0			
08.	Minimum Generation Forecast up to 8:00 hrs.	:	11227 MW, at =	5:00 hrs	Cumilla	1364	1364	0							
09.	Generation shortfall at evening peak due to :	:													
a)	Gas/LF limitation	:	1497 MW												
c)	Coal supply Limitation	:	189 MW												
b)	Low water level in Kaptai lake	:	170 MW												
c)	Plants under shut down/ maintenance	:	1834 MW												
10.	Total Energy (Generation + India Import)	:	298.53 MCKWh												
	By Gas = 157.705		MCKWh	By Oil =	56.467	MCKWh									
	By Coal = 55.715		MCKWh	By Hydro =	1.446	MCKWh									
	By Solar= 2.391		MCKWh												
11.	Total Gas Supplied	:	1227.39 MMCFD												
(D) Forecast of 16.07.23 (Today) Sunday :															
01.	Maximum Demand	:	15200 MW (Generation end)	04. Maximum Load-shed : 0 MW At evening peak (Sub-station end)											
02.	Maximum Generation	:	15540 MW (Generation end)	05. Total Generation : 311.97 MCKWh											
03.	Reserve / Shortage	:	340 MW (Generation end)	06. Probable Max. Temperature in Dhaka : 32.7° C											