

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month July, 2023				Day : Monday				Date : 17.07.23						
Probable Maximum Demand : 15000 MW				Probable Maximum Generation : 15179 MW										
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 75.12 ft Today = 75.04 ft				Rule Curve = 86.56 ft						
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	16.07.23 (Yesterday)		17.07.23 (Today)		16.07.23 (Yesterday)		17.07.23 (Today)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Machines shut down (MW)		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening						
(A) Plants in operation:														
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	0	0	0	0			260		Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	170	160	160						
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180						
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0						
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0			108		Gas Shortage	
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0			105		Gas Shortage	
6	Haripur GT/PP	Gas (PDB)	1 x 32	32	20	0	0	0						
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	338	337	330			330			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450			450			
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0			115		Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	398	400	400			412			
11	Siddhirganj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	195	195	150			200			
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	331	331	330			330			
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	312	309	300			300			
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55			55			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	50	102	50			102			
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	16	19	19			19			
17	Summit Power(Madhabdi-Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	40	40	40			41			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25			25			
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	24	24	24			24			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	25	8			25			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	35	70	35			88			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	48	115	64			132			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	35	17			35			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	16x17.076	300	300	115	115	115			115			
25	Kodda 148 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.15+1x8.97	149	149	34	133	34			148			
26	Keraniganj 300 MW PP (AFR)	HSD (IPP)	25x61.4	300	300	50	32	300			300			
27	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	35	35			55			
28	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	35			55			
29	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	54	61	54			72			
30	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	72	90	17			126			
31	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	33	0	30			0			
32	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17			17			
33	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	52	80	58			80			
34	Meghnaghat 100 MW(EL)	HFO (NENP)	12x8.9	100	100	49	56	50			70			
35	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	65	80	80			80			
36	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	11	23	21			22			
Dhaka Zone Total				5904	5722	3324	3659	3483	4049	213	375			
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	60	60	60			90		Low water level	
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	99	105	100			75		Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0			0		Under maint.	
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	6	0	5			0			
40	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	0	8			17			
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	16	0	20			0			
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	12	21	6			50			
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	51	51	17			34			
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0			0		Under maint.	
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	218	221	225			225			
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	87	296	88			280			
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	37	50	38			50			
48	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	19	33	50			50			
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	32	66	32			66			
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	10	11	10			10			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			3	26	5			20			
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	11	9	12			25			
52	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17			17			
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	46	51	34			51			
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	38	50	38			50			
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	25	58	25			58			
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	68	87	51			87			
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	53	162	54			163			
	SS Power Unit-1	Coal (IPP)				0	0	0			0			
	Cox's Bazar Wind PP	(Wind) (IPP)				0	5	15			10			
Chattogram Zone Total				2605	2545	916	1379	910	1453	245	330			
58	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	20	20	20			20			
59	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+175	221	221	205	202	200			200			
60	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	230	230	230			230			
61	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	270	270	270			270			
62	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	230	230	230			230			
63	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20'9.73+1'16	195	195	0	0	0			0		Gas Shortage	
64	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51			51			
65	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	5	145	5			150			
66	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	36	43	43			43			
67	Chandpur 150 MW CCPP	Gas (PDB)	1x106+1x57	163	163	0	0	0			0		Under maint.	
68	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	51	105	50			100			
69	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	20			20			
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	8	10			10			
71	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33			33			
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	34	39	34			34			
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	18	20	20			20			
74	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	70	106	70			106			
75	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	9	96	9			95			
76	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17			17			
77	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	84	96	55			96			
**	Import (Tirupura)	India		160	160	114	122	146			169			
Cumilla Zone Total				2904	2896	1497	1853	1513	1894	195	163			
78	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	31	49	30			153		Gas Shortage	
79	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	19			19			
80	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	19	85	20			85			
81	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	68	88	68			88			
82	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6			0			
83	Sutiakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	39	0	50			0			
84	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	12	12	12			12			
Mymensingh Zone Total				622	614	189	253	201	254	153	0			

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	16.07.23 (Yesterday)		17.07.23 (Today)		16.07.23 (Yesterday)		Status of Machines under shut-down/ Maintenance							
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date						
						Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)								
85	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 & ST-1 Under maint.							
86	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	0	0	0		90	GT-4 Under maint.							
87	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	47	47	47	47										
88	Kushihara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	112	112		54	ST Under maint.							
89	Hobigunj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11										
90	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	57	58	60	60										
91	Shajibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.							
92	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	81	84	86	86										
93	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	206	204	203	204										
94	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	17	17	17	17										
95	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10										
96	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	24	24	24										
97	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	280	300	300										
98	Bibiyan-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	401	368	400	400										
99	Bibiyan South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	250	260	250	260										
100	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work							
101	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.4+5*2	50	50	47	44	44	44										
Sylhet Zone Total						2472	2427	1580	1562	1607	1618	0	601						
102	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0										
103	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	190	150	200	200										
104	Fairdipor 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	22	20	30										
105	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	0										
106	Khulna 225 MW CCPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	120	224	150	225										
107	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	67	54	35										
108	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	105	105	105										
109	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	14	0	100	0										
110	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	97	80	98										
111	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	24	8	24										
112	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	331	0	0	0	617			Coal Shortage						
113	Khulna 330 MW CCPP (GT)	Gas/HSD (BDFB)	1x220	220	220	0	100	200	200										
**	Bheramara (HVDC)	India		1000	1000	916	916	935	935										
Khulna Zone Total						3125	3121	1588	1705	1852	1852	617	0						
114	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	110	110	110										
115	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	22	16	25	31										
116	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	132	132	135	137										
117	Payra 1320 MW TTP	Coal (BCPCL)	2x622	1244	1244	1120	1244	1244	1244	0									
118	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	150	17	150										
119	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	0	0	0	0	307			Coal Shortage						
120	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	225	223	220	220										
Barishal Zone Total						2265	2265	1499	1875	1751	1892	307	0						
121	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71			Gas Shortage						
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100		Under maint.						
122	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	35	0	35										
123	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	120	150	200										
124	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	14	0	28										
125	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	93	0	93										
126	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	28	22	29										
127	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	42	0	0	0										
128	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	27	0	30										
129	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	0	0	0	0		210		Under Maint.						
130	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	0	0	0	0	220			Gas Shortage						
131	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	170	164	150	170										
132	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	415	414	414	414										
133	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	0	0	0	0	0										
134	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8										
135	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	52	52	52	52										
136	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	57	35	55										
137	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	50	35	50										
138	Ammura 50 MW PPS(Sinha)	HFO (NENP)	7x7.79	50	28	28	28	28	28										
139	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	2	0	6	0										
**	Adani Power Jharkhanda Ltd	Coal (Import)	2x748	1496	1496	622	625	620	620										
Rajshahi Zone Total						3675	3631	1409	1715	1520	1812	291	310						
140	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85			Coal Shortage						
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85		Under Overhauling						
141	Barapukuria 275 MW TTP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170	104			Coal Shortage						
142	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0										
143	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	28	70	34	70										
144	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0										
145	Mapjira, Tatalia 8 MW Solar PP (Sympha Power)	Solar (IPP)	1 x 8	8	5	0	0	8	0										
146	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6*20	115	115	54	75	35	115										
147	Lalmourihaat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	37	0	30	0										
148	Teesha Solar Limited	Solar (IPP)	1 x 200	200	200	161	0	130	0										
Rangpur Zone Total						1030	950	455	315	407	355	189	85						
Sub-total: Plants in operation						24602	24171	12457.0	14316	13244	15179	2210	1864						
(B) Plants under long term maintenance/ contract expired																			
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0										
150	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0										
151	Bosilia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0										
152	Ashugani 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	0	0	0	0										
Sub-Total: Plants under long term maintenance/ contract expired						309	0	0	0	0	0	0	0						
Gross Total						24911	24171	12457	14316	13244	15179	2210	1864						
(C) Actual data of 16.07.23 (Yesterday) Sunday :																			
01.	Max. Demand at eve. peak (Generation end)	:	14485	MW, at =	21:00 hrs	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :													
02.	Max. Demand at eve. peak (Sub-station end)	:	13882	MW, at =	21:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed						
03.	Highest Generation (Generation end)	:	14316	MW, at =	21:00 hrs		MW	MW	MW		MW	MW	MW						
04.	Minimum Generation (Generation end)	:	11227	MW, at =	8:00 hrs	Dhaka	4853	4831	22	Mymensingh	1136	1063	73						
05.	Day-peak Generation (Generation end)	:	12457	MW, at =	12:00 hrs	Chattogram	1270	1270	0	Sylhet	597	597	0						
06.	Evening-peak Generation (Generation end)	:	14316	MW, at =	21:00 hrs	Khulna	1766	1766	0	Barishal	446	446	0						
07.	Evening Peak Load-shed (Sub-station end)	:	161	MW, at =	21:00 hrs	Rajshahi	1472	1472	0	Rangpur	965	914	51						
08.	Minimum Generation Forecast up to 8:00 hrs.	:	11440	MW, at =	5:00 hrs	Cumilla	1376	1361	15										
09.	Generation shortfall at evening peak due to :	:				Total													
	a) Gas/LF limitation	:	1851	MW		(a) Gas = 177049136 Taka			(c) Coal = 295338756 Taka			Taka							
	d) Coal supply Limitation	:	189	MW		(b) Oil = 820818989 Taka			Total = 1293206881 Taka			Taka							
	b) Low water level in Kaptai lake	:	170	MW															
	c) Plants under shut down/ maintenance	:	1864	MW															
10.	Total Energy (Generation + India Import)	:	303.46	MWWh															
	By Gas = 159.115	159.115	MWWh	By Oil =	61.733														
	By Coal = 53.461	53.461	MWWh	By Hydro =	1.423														
	By Solar= 2.516	2.516	MWWh																
11. Total Gas Supplied						:	1236.09	MMCFD											
(D) Forecast of 17.07.23 (Today) Monday :																			
01.	Maximum Demand	:	15000	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)								
02.	Maximum Generation	:	15179	MW	(Generation end)	05.	Total Generation	:	317.96	MWWh									
03.	Reserve / Shortage	:	1579	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	31.6° C										