

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month July, 2023					Day : Tuesday					Date : 18.07.23				
Probable Maximum Demand : 15100 MW					Probable Maximum Generation : 15173 MW									
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 75.04 ft					Today = 75.00 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	17.07.23 (Yesterday)		18.07.23 (Today)		17.07.23 (Yesterday)		18.07.23 (Today)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Water Limitation MW		Machines shut down (MW)			
					Day	Evening	Day	Evening			Description/ Remarks	Probable start-up date		
(A) Plants in operation:														
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260		Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	170	180	170	180					
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180					
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0					
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108			Gas Shortage	
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105			Gas Shortage	
6	Haripur GT/PP	Gas (PDB)	1 x 32	32	20	0	0	0	0					
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	327	331	330	330					
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450					
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115		Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	399	404	400	412					
11	Siddhirganj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	189	189	190	200					
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	323	323	330	330					
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	300	305	300	310					
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	50	102	50	102					
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	19	19	19					
17	Summit Power(Madhabdi-Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	33	41	40	41					
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25					
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	21	22	24	24					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	25	8	25					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	35	88	35	88					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	64	132	64	130					
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	35	17	35					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	16x17.076	300	300	112	112	115	115					
25	Kodda 148 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	148	148	35	148	34	148					
26	Keraniganj 300 MW PP (AFR)	HSD (IPP)	25x61.4	300	300	157	300	300	300					
27	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	55	17	55					
28	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	55	17	55					
29	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	53	72	54	72					
30	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	126	17	126					
31	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	30	0	30	0					
32	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	34	17	17					
33	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	58	45	58	80					
34	Meghnaghat 100 MW(EL)	HFO (NENP)	12x8.9	100	100	49	59	42	75					
35	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	60	80	80	80					
36	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	22	45	45	45					
Dhaka Zone Total			5904	5722	3309	4038	3513	4105	213	375				
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	60	60	60	60	170			Low water level	
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	99	0	0	81			Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180		Under maint.	
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	3	0	5	0					
40	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	16	8	17					
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	20	0	20	0					
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	40	6	40					
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	48	34	17	34					
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150		Under maint.	
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	218	221	225	225					
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	82	300	88	300					
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	37	37	36	36					
48	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	49	50	32	32					
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	32	71	32	70					
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	10	11	11	11					
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	28	5	20					
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	12	18	12	18					
52	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	36	17	17					
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	48	51	51	51					
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	38	38	38	50					
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	25	58	34	58					
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	51	87	51	87					
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	53	162	17	163					
	SS Power Unit-1	Coal (IPP)				0	0	0	0					
	Cox's Bazar Wind PP	(Wind) (IPP)				16	5	15	10					
Chattogram Zone Total			2605	2545	935	1422	780	1299	251	330				
58	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	5	27	20	20					
59	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+175	221	221	175	206	200	200					
60	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	230	230	300	300					
61	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	270	280	280	280					
62	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	320	230	230	230					
63	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20'9.73+1'16	195	195	0	0	0	0	195			Gas Shortage	
64	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	51	51					
65	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	5	140	5	150					
66	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	28	44	43	43					
67	Chandpur 150 MW CCPP	Gas (PDB)	1x106+1x57	163	163	0	0	0	0		163		Under maint.	
68	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	35	51	34	51					
69	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	20	20					
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	0	11	11					
71	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33					
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	34	43	43	43					
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	12	17	20	20					
74	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	88	105	52	88					
75	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	9	97	9	95					
76	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17					
77	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	74	96	55	96					
**	Import (Tirupura)	India		160	160	142	158	146	169					
Cumilla Zone Total			2904	2896	1551	1845	1569	1917	195	163				
78	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	29	49	30	50	153			Gas Shortage	
79	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	19	19					
80	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	19	85	20	85					
81	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	68	88	68	88					
82	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0					
83	Sutiakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	34	0	50	0					
84	Tangail 22 MW PP(PGCL)	HFO (IPP)	4x6.7	22	22	12	12	12	12					
Mymensingh Zone Total			622	614	183	253	201	254	153	0				

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	17.07.23 (Yesterday)		18.07.23 (Today)		17.07.23 (Yesterday)		Status of Machines under shut-down/ Maintenance			
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date		
						Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)				
85	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 & ST-1 Under maint.			
86	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	20	20	20		70	GT-4 Under maint.			
87	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	47	47	47	47						
88	Kushiera 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	112	112		54	ST Under maint.			
89	Hobigunj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	8	11	11						
90	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	58	60	60						
91	Shajibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.			
92	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	81	81	86	86						
93	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	202	204	203	204						
94	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	17	17	17	17						
95	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10						
96	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	24	24	24	24						
97	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	310	280	300	300						
98	Bibiyan-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	404	369	400	400						
99	Bibiyan South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	260	260	260	260						
100	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work			
101	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.4+5*2	50	50	44	48	44	44						
Sylhet Zone Total						2472	2427	1619	1581	1637	1638	0	581		
102	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0						
103	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	175	150	200	200						
104	Fairdipor 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	20	20	30						
105	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	60	20	60						
106	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	226	222	225	225						
107	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	36	36	36	36						
108	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	105	105	105	105						
109	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	90	0	100	0						
110	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	16	96	80	98						
111	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	16	40	8	24						
112	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	0	0	0	0	617		Coal Shortage			
113	Khulna 330 MW CCPP (GT)	Gas/HSD (BDFB)	1x220	220	220	0	233	200	200						
**	Bheramara (HVDC)	India		1000	1000	916	773	928	928						
Khulna Zone Total						3125	3121	1580	1735	1922	1923	617	0		
114	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	50	48	110	110						
115	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	17	33	25	31						
116	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	132	133	135	137						
117	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	1244	1244	1244	1244	0					
118	Potukhalhi 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	150	17	150						
119	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	0	0	0	0	307		Coal Shortage			
120	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	222	222	220	220						
Barishal Zone Total						2265	2265	1682	1830	1751	1892	307	0		
121	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage			
121	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Under maint.			
122	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	35	0	35						
123	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	35	150	200						
124	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	21	0	28						
125	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	94	0	93						
126	Katakhalhi 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	28	22	29						
127	Katakhalhi 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	42	42	42						
128	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	27	0	30						
129	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0		210	Under Maint.			
130	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage			
131	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	148	167	150	170						
132	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	414	414	414						
133	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	0	0	0	0	0						
134	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8						
135	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	8	8	8						
136	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	55	35	55						
137	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	50	35	50						
138	Ammura 50 MW PPS(Sinha)	HFO (NENP)	7x7.79	50	28	28	28	28	28						
139	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	1	0	6	0						
**	Adani Power Jharkhanda Ltd	Coal (Import)	2x748	1496	1496	587	631	600	600						
Rajshahi Zone Total						3675	3631	1264	1643	1498	1790	291	310		
140	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage			
140	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling			
141	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170	104		Coal Shortage			
142	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
143	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	29	70	34	70						
144	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
145	Majpara, Taluk 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0						
146	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6*20	115	115	35	114	35	115						
147	Lalmohiniat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	20	0	30	0						
148	Teesa Solar Limited	Solar (IPP)	1 x 200	200	200	49	0	130	0						
Rangpur Zone Total						1030	950	309	354	407	355	189	85		
Sub-total: Plants in operation						24602	24171	12432.0	14701	13278	15173	2216	1844		
(B) Plants under long term maintenance/ contract expired															
149	Jamailpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0						
150	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0						
151	Bosilia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0						
152	Ashugani 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	0	0	0	0						
Sub-Total: Plants under long term maintenance/ contract expired						309	0	0	0	0	0	0	0		
Gross Total						24911	24171	12432	14701	13278	15173	2216	1844		
(C) Actual data of 17.07.23 (Yesterday) Monday :															
01.	Max. Demand at eve. peak (Generation end)	:	15066 MW, at =	21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
02.	Max. Demand at eve. peak (Sub-station end)	:	14455 MW, at =	21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW			
03.	Highest Generation (Generation end)	:	14701 MW, at =	21:00 hrs											
04.	Minimum Generation (Generation end)	:	11440 MW, at =	6:00 hrs	Dhaka	5055	5018	37	Mymensingh	1214	1070	144			
05.	Day-peak Generation (Generation end)	:	12432 MW, at =	12:00 hrs	Chattogram	1422	1422	0	Sylhet	566	566	0			
06.	Evening-peak Generation (Generation end)	:	14701 MW, at =	21:00 hrs	Khulna	1799	1741	58	Barishal	463	463	0			
07.	Evening Peak Load-shed (Sub-station end)	:	349 MW, at =	21:00 hrs	Rajshahi	1519	1519	0	Rangpur	1011	901	110			
08.	Minimum Generation Forecast up to 8:00 hrs.	:	11586 MW, at =	5:00 hrs	Cumilla	1407	1407	0							
09.	Generation shortfall at evening peak due to :	:			Total								14455	14106	349
a) Gas/LF limitation	:	:	1857 MW		13.	Fuel cost :	(a) Gas = 177697061 Taka	(c) Coal = 304514988 Taka							
d) Coal supply Limitation	:	:	189 MW				(b) Oil = 859120642 Taka	Total = 1341332601 Taka							
b) Low water level in Kaptai lake	:	:	170 MW		14.	Maximum Temperature in Dhaka was :								34° C	
c) Plants under shut down/ maintenance	:	:	1844 MW		15.	Export through East-West interconnections :									
10.	Total Energy (Generation + India Import)	:	305.18 MMWh			At evening peak-hour	:	12432 MW, at	21:00 hrs						
	By Gas = 159.856 MKWH	By Oil =	65.510 MKWH			Maximum	:	360 MW, at	21:00 hrs						
	By Coal = 50.417 MKWH	By Hydro =	1.433 MKWH			Energy	:	0 MKWh							
	By Solar= 2.685 MKWH														
11.	Total Gas Supplied	:	1234.47 MMCFD												
(D) Forecast of 18.07.23 (Today) Tuesday :															
01.	Maximum Demand	:	15100 MW (Generation end)		04.	Maximum Load-shed								0 MW At evening peak (Sub-station end)	
02.	Maximum Generation	:	15173 MW (Generation end)		05.	Total Generation								313.46 MKWh	
03.	Reserve / Shortage	:	73 MW (Generation end)		06.	Probable Max. Temperature in Dhaka :								34° C	

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman