

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month July, 2023					Day : Wednesday				Date : 19.07.23					
Probable Maximum Demand : 15500 MW					Probable Maximum Generation : 15300 MW									
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 75.00 ft		Today = 74.99 ft		Rule Curve = 86.88 ft.					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	18.07.23 (Yesterday)		19.07.23 (Today)		18.07.23 (Yesterday)		Status of Machines under shut-down/ Maintenance			
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Water Limitation MW		Machines shut down (MW)		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening						
(A) Plants in operation:														
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work		
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	170	160	170	170					
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180					
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0					
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108		Gas Shortage		
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage		
6	Haripur GT/PP	Gas (PDB)	1 x 32	32	20	0	0	0	0					
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	324	327	330	330					
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450					
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling		
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	401	400	400	412					
11	Siddhirganj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	189	193	190	200					
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	319	324	330	330					
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	302	308	310	310					
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	15	30					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	66	102	50	102					
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	19	19	19					
17	Summit Power(Madhabdi-Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	41	39	40	41					
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25					
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	23	23	24	24					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	25	8	25					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	35	70	35	88					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	64	132	64	130					
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	35	17	35					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	16x17.076	300	300	115	116	115	115					
25	Kodda 148 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	34	149	34	149					
26	Keraniganj 300 MW PP (AFR)	HSD (IPP)	25x61.4	300	300	200	300	300	300					
27	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	55	35	55					
28	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	35	17	55					
29	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	51	72	54	72					
30	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	126	17	126					
31	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	34	0	30	0					
32	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	17					
33	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	65	60	58	70					
34	Meghnaghat 100 MW(EL)	HFO (NENP)	12x8.9	100	100	55	53	58	72					
35	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	65	94	96	96					
36	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	44	57	45	45					
Dhaka Zone Total			5904	5722	3380	3961	3533	4073	213	375				
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	60	60	60	60	170		Low water level		
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.		
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	5	0	5	0					
40	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	16	8	17					
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	6	0	20	0					
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	39	26	46					
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	43	43	51	51					
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Under maint.		
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	215	225	225	225					
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	88	280	88	300					
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	50	25	50					
48	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	32	49	50	50					
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	32	83	32	70					
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	11	11	11	11					
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	29	5	20					
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	18	12	18					
52	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17					
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	51	74	74	74					
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	38	25	38					
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	35	46	35	46					
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	47	87	51	87					
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	17	163	17	163					
	SS Power Unit-1	Coal (IPP)				0	0	0	0					
	Cox's Bazar Wind PP	(Wind) (IPP)				6	25	15	10					
Chattogram Zone Total			2605	2545	723	1353	852	1353	350	330				
58	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	5	5	5	5					
59	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	186	184	200	200					
60	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	240	240	280	280					
61	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	300	280	280	280					
62	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	230	290	250	250					
63	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	0	0	0	0	195		Gas Shortage		
64	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	43	43	43					
65	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	5	145	5	150					
66	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	36	44	43	43					
67	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163		Under maint.		
68	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	36	52	34	51					
69	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	20	20					
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11					
71	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	33	33	33					
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	34	43	43	43					
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	20	20	20					
74	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	52	88	52	88					
75	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	97	9	95					
76	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17					
77	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	91	95	98	98					
**	Impoort (Tripura)	India		160	160	162	162	146	169					
Cumilla Zone Total			2904	2896	1522	1869	1589	1896	195	163				
78	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	31	86	30	50	116		Gas Shortage		
79	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	19	19					
80	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	19	85	20	85					
81	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	68	88	68	88					
82	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0					
83	Sutiakhalai 50 MW Solar PP	Solar (IPP)	1x50	50	50	52	0	50	0					
84	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	12	12	12	12					
Mymensingh Zone Total			622	614	203	290	201	254	116	0				

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	18.07.23 (Yesterday)		19.07.23 (Today)		18.07.23 (Yesterday)		Status of Machines under shut-down/ Maintenance		
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
						Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)			
85	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.		
86	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	30	30	30		60	GT-4 & ST-2 Under maint.		
87	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	44	47	47	47					
88	Kushiarra 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	112	112		54	ST Under maint.		
89	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	5	5	11	11				
90	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	59	60	60	60					
91	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.		
92	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	81	81	86	86					
93	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	202	200	203	204					
94	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	16	17	17	17					
95	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10					
96	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	24	24	24	24					
97	Bibiara-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	310	290	300	300					
98	Bibiara-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	378	367	400	400					
99	Bibiara South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	254	255	100	400					
100	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work		
101	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.4+5*2	50	50	46	45	44	44					
Sylhet Zone Total						2472	2427	1614	1586	1487	1788	0	571	
102	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0					
103	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	105	145	160	160					
104	Fairdipor 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	11	25	20	30					
105	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	22	58	26	60					
106	Khulna 225 MW CCPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	204	223	225	225					
107	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	35	35	35	35					
108	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	105	105	105	105					
109	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	75	0	100	0					
110	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	32	97	80	98					
111	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	16	40	8	24					
112	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	0	0	0	0		617	Under maint.		
113	Khulna 330 MW CCPP (GT)	Gas/HSD (BDFB)	1x220	220	220	0	232	200	200					
**	Bheramara (HVDC)	India		1000	1000	910	767	924	924					
Khulna Zone Total						3125	3121	1515	1727	1883	1861	617	0	
114	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	48	16	48					
115	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	22	33	25	31					
116	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	130	133	135	137					
117	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	1244	1244	1244	1244		0			
118	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	150	17	150					
119	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	0	0	0	0		307	Coal Shortage		
120	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	224	222	220	220					
Barishal Zone Total						2265	2265	1653	1830	1657	1830	307	0	
121	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage		
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.		
122	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	35	0	35					
123	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	150	200					
124	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	28					
125	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	91	0	93					
126	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	29	0	29					
127	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	42	42	42	42					
128	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	27	0	30					
129	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	0	0	0	0		210	Gas Shortage		
130	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	0	0	0	0		220	Gas Shortage		
131	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	161	153	150	170					
132	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	414	414	414					
133	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	0	0	0	0	0					
134	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8					
135	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	8	8	8					
136	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	55	35	55					
137	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	50	35	50					
138	Ammura 50 MW PPS(Sinha)	HFO (NENP)	7x7.79	50	28	21	21	28	28					
139	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	5	0	6	0					
**	Adani Power Jharkhanda Ltd	Coal (Import)	2x748	1496	1496	618	615	700	700					
Rajshahi Zone Total						3675	3631	1347	1548	1576	1890	501	100	
140	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage		
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling		
141	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170		104	Coal Shortage		
142	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
143	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	32	70	34	70					
144	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
145	Majpara, Talsia 9 MW Solar PP (Syma Power)	Solar (IPP)	1 x 9	9	8	7	0	8	0					
146	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6*20	119	115	35	114	35	115					
147	Lalmohinihal 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	25	0	30	0					
148	Teesa Solar Limited	Solar (IPP)	1 x 200	200	200	202	0	130	0					
Rangpur Zone Total						1030	950	471	354	407	355	189	85	
Sub-total: Plants in operation						24602	24171	12428.0	14518	13185	15300	2488	1624	
(B) Plants under long term maintenance/ contract expired														
149	Jamulpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0					
150	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0					
151	Bosilia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0					
152	Ashugani 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	0	0	0	0					
Sub-Total: Plants under long term maintenance/ contract expired						309	0	0	0	0	0	0	0	
Gross Total						24911	24171	12428	14518	13185	15300	2488	1624	
(C) Actual data of 18.07.23 (Yesterday) Tuesday :														
01.	Max. Demand at eve. peak (Generation end)	:	15200 MW, at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
02.	Max. Demand at eve. peak (Sub-station end)	:	14549 MW, at =	21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW		
03.	Highest Generation (Generation end)	:	14574 MW, at =	22:00 hrs	Dhaka	5200	5100	100	Mymensingh	1180	1030	150		
04.	Minimum Generation (Generation end)	:	11586 MW, at =	8:00 hrs	Chattogram	1353	1353	0	Sylhet	640	640	0		
05.	Day-peak Generation (Generation end)	:	12428 MW, at =	12:00 hrs	Khulna	1820	1820	0	Barishal	473	473	0		
06.	Evening-peak Generation (Generation end)	:	14518 MW, at =	21:00 hrs	Rajshahi	1518	1462	56	Rangpur	982	794	188		
07.	Evening Peak Load-shed (Sub-station end)	:	651 MW, at =	21:00 hrs	Cumilla	1384	1227	157						
08.	Minimum Generation Forecast up to 8:00 hrs.	:	11652 MW, at =	5:00 hrs										
09.	Generation shortfall at evening peak due to :	:												
a)	Gas/LF limitation	:	2129 MW											
d)	Coal supply Limitation	:	189 MW											
b)	Low water level in Kaptai lake	:	170 MW											
c)	Plants under shut down/ maintenance	:	1624 MW											
10.	Total Energy (Generation + India Import)	:	303.39 MMkWh											
	By Gas = 158.091 MKWh	By Oil =	65.115 MKWh											
	By Coal = 50.344 MKWh	By Hydro =	1.437 MKWh											
	By Solar= 3.237 MKWh													
11. Total Gas Supplied :						1206.69	MMCFD							
(D) Forecast of 19.07.23 (Today) Wednesday :														
01.	Maximum Demand	:	15500 MW (Generation end)	04. Maximum Load-shed : 184 MW At evening peak (Sub-station end)										
02.	Maximum Generation	:	15300 MW (Generation end)	05. Total Generation : 322.67 MKWh										
03.	Reserve / Shortage	:	-200 MW (Generation end)	06. Probable Max. Temperature in Dhaka : 35.2° C										