

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month July, 2023				Day : Thursday				Date : 20.07.23						
Probable Maximum Demand : 15800 MW				Probable Maximum Generation : 15338 MW										
Water Level of Kaptai Lake at 06:00 AM				Today = 75.54 ft.				Rule Curve = 87.04 ft.						
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Dated/ Present Capacity (MW)	19.07.23 (Yesterday)		20.07.23 (Today)		19.07.23 (Yesterday)		20.07.23 (Today)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Water Limitation		Machines shut down (MW)		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	MW		MW			
(A) Plants in operation:														
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260		Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	160	160	180	180					
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180					
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0					
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108			Gas Shortage	
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105			Gas Shortage	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0					
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	327	343	330	330					
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450					
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115		Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	401	403	400	400					
11	Siddhirganj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	191	195	185	195					
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	324	323	330	330					
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	294	274	300	300					
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	15	30					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	50	102	50	102					
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	19	19	19					
17	Summit Power (Madhabdi-Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	40	40	40	41					
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25					
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	23	22	22	22					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	25	8	25					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	52	88	35	88					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	96	130	64	130					
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	35	17	35					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	16x17.076	300	300	145	97	115	115					
25	Kodda 148 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.15+1x8.97	149	149	88	151	34	148					
26	Keraniganj 300 MW PP (AFR)	HSD (IPP)	25x61.4	300	300	260	296	300	300					
27	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	55	35	55					
28	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	17	17	55					
29	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	54	59	54	72					
30	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	108	17	126					
31	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	16	0	30	0					
32	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	17					
33	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	50	72	58	70					
34	Meghnaghat 100 MW(EL)	HFO (NENP)	12x8.9	100	100	58	58	58	64					
35	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	95	96	96	96					
36	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	36	31	45	45					
Dhaka Zone Total				5904	5722	3544	3886	3526	4046	213	375			
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	60	60	60	60	170			Low water level	
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180			Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180		Under maint.	
39	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	5	0	5	0					
40	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	16	8	17					
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	12	0	20	0					
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	32	39	26	46					
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	74	96	105	105					
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150		Under maint.	
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	220	224	225	225					
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	87	276	88	300					
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	37	37	25	50					
48	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	32	33	50	50					
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	24	66	32	66					
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	11	11	11	11					
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	34	5	20					
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	18	12	18					
52	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	36	17	36					
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	54	74	74	74					
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	38	44	25	38					
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	35	46	35	46					
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	51	100	51	107					
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	53	163	17	163					
	SS Power Unit-1	Coal (IPP)				0	0	0	0					
	Cox's Bazar Wind PP	(Wind) (IPP)				6	2	15	10					
Chattogram Zone Total				2605	2545	858	1375	906	1442	350	330			
58	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	5	5	5	5					
59	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1x75	221	221	179	205	200	200					
60	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	280	240	240	240					
61	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	280	275	280	300					
62	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	240	240	240	240					
63	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20'9.73+1'16	195	195	0	0	0	0	195			Gas Shortage	
64	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	43	43	43					
65	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	5	125	6	150					
66	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	36	42	43	43					
67	Chandpur 150 MW CCPP	Gas (PDB)	1x106+1x57	163	163	0	0	0	0		163		Under maint.	
68	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	34	51	34	51					
69	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	20	20	20					
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11					
71	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	32	33	33	33					
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	43	42	43	43					
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	20	20	20					
74	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	52	103	52	88					
75	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	9	97	9	95					
76	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17					
77	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	93	99	98	98					
**	Import (Tripura)	India		160	160	160	120	146	169					
Cumilla Zone Total				2904	2896	1558	1788	1540	1866	195	163			
78	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	30	53	30	50	149			Gas Shortage	
79	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	19	19					
80	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	19	84	20	85					
81	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	67	87	68	88					
82	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0					
83	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	48	0	50	0					
84	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	12	12	12	12					
Mymensingh Zone Total				622	614	197	255	201	254	149	0			

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	19.07.23 (Yesterday)		20.07.23 (Today)		19.07.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)		
85	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.	
86	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	40	40	40		50	GT-4 Under maint.	
87	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	44	44	45	45				
88	Kushiera 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	80	112	112	112		54	ST Under maint.	
89	Hobigani 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11				
90	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	60	60	60				
91	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
92	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	77	81	86	86				
93	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	204	201	203	204				
94	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	17	17	17	17				
95	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
96	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	24	24	24	24				
97	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	290	300	300				
98	Bibiya-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	368	407	400	400				
99	Bibiya South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	50	347	340	385				
100	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
101	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.4+5*2	50	50	46	46	44	44				
Sylhet Zone Total						2472	2427	1351	1730	1735	1781	0	561
102	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
103	Bheramara 410 MW CAPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	145	160	150	150				
104	Fairdipor 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	11	21	20	30				
105	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	25	54	26	60				
106	Khulna 225 MW CAPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	218	208	210	225				
107	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	36	36	35	35				
108	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	32	105	50	105				
109	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	107	0	100	0				
110	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	16	86	80	98				
111	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	16	40	8	40				
112	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	0	0	0	0		617	Under maint.	
113	Khulna 330 MW CAPP (GT)	Gas/HSD (BDFB)	1x220	220	220	0	233	200	233				
**	Bheramara (HVDC)	India		1000	1000	904	764	924	924				
Khulna Zone Total						3125	3121	1510	1707	1803	1900	617	0
114	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	32	16	32				
115	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	22	34	21	34				
116	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	124	132	135	135				
117	Payra 1320 MW TTP	Coal (BCPCL)	2x622	1244	1244	1222	1222	1244	1244		22		
118	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	0	17	150				
119	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	0	0	0	0		307	Coal Shortage	
120	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	221	220	220	220				
Barishal Zone Total						2265	2265	1622	1640	1653	1815	329	0
121	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage	
121	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.	
122	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	35	0	35				
123	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	150	200				
124	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	28				
125	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	90	0	93				
126	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	29	0	29				
127	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	42	25	34	42				
128	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	35	0	35				
129	Sirajgonj 225MW CAPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	0	0	0	0		210	Gas Shortage	
130	Sirajgonj 225MW CAPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	0	0	0	0		220	Gas Shortage	
131	Sirajgonj 225MW CAPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	150	155	148	155				
132	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	414	380	380				
133	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	0	0	0	0	0				
134	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	0	8	8				
135	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	8	8	8				
136	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	75	35	75				
137	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	70	35	70				
138	Ammura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	21	21	21	21				
139	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	5	0	6	0				
**	Adani Power Jharkhanda Ltd	Coal (Import)	2x748	1496	1496	716	716	700	700				
Rajshahi Zone Total						3675	3631	1434	1673	1525	1879	501	100
140	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage	
140	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
141	Barapukuria 275 MW TTP Unit-3	Coal (PDB)	1 x 274	274	274	170	235	170	170		39	Coal Shortage	
142	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
143	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	34	84	34	70				
144	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
145	Majmaera, Talsia 9 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 9	9	8	7	0	8	0				
146	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6*20	115	115	75	75	35	115				
147	Lalmohini 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	19	0	30	0				
148	Teesa Solar Limited	Solar (IPP)	1 x 200	200	200	207	0	130	0				
Rangpur Zone Total						1030	950	512	394	407	355	124	85
Sub-total: Plants in operation						24602	24171	12586.0	14448	13296	15338	2478	1614
(B) Plants under long term maintenance/ contract expired													
149	Jamailpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
150	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
151	Bosilia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
152	Ashugani 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	0	0	0	0				
Sub-Total: Plants under long term maintenance/ contract expired						309	0	0	0	0	0	0	0
Gross Total						24911	24171	12586	14448	13296	15338	2478	1614
(C) Actual data of 19.07.23 (Yesterday) Wednesday :													
01.	Max. Demand at eve. peak (Generation end)	:	15600 MW, at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :								
02.	Max. Demand at eve. peak (Sub-station end)	:	14903 MW, at =	21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW	
03.	Highest Generation (Generation end)	:	14448 MW, at =	21:00 hrs	Dhaka	5296	5158	138	Mymensingh	1239	1039	200	
04.	Minimum Generation (Generation end)	:	11652 MW, at =	8:00 hrs	Chattogram	1440	1440	0	Sylhet	632	542	90	
05.	Day-peak Generation (Generation end)	:	12586 MW, at =	12:00 hrs	Khulna	1892	1720	172	Barishal	480	440	40	
06.	Evening-peak Generation (Generation end)	:	14448 MW, at =	21:00 hrs	Rajshahi	1632	1532	100	Rangpur	991	811	180	
07.	Evening Peak Load-shed (Sub-station end)	:	1100 MW, at =	21:00 hrs	Cumilla	1303	1123	180					
08.	Minimum Generation Forecast up to 8:00 hrs.	:	11991 MW, at =	5:00 hrs					Total	14903	13803	1100	
09.	Generation shortfall at evening peak due to :	:											
	a) Gas/LF limitation	:	2184 MW										
	d) Coal supply Limitation	:	124 MW										
	b) Low water level in Kaptai lake	:	170 MW										
	c) Plants under shut down/ maintenance	:	1614 MW										
10.	Total Energy (Generation + India Import)	:	303.44 MKWh										
	By Gas = 153.385 MKWh	By Oil =	67.450 MKWh										
	By Coal = 53.103 MKWh	By Hydro =	1.460 MKWh										
	By Solar= 3.290 MKWh												
11.	Total Gas Supplied	:	1196.89 MMCFD										
(D) Forecast of 20.07.23 (Today) Thursday :													
01.	Maximum Demand	:	15800 MW (Generation end)		04.	Maximum Load-shed	:	426 MW (At evening peak (Sub-station end))					
02.	Maximum Generation	:	15338 MW (Generation end)		05.	Total Generation	:	331.83 MKWh					
03.	Reserve / Shortage	:	-462 MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	:	35.4° C					

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00