

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month July, 2023					Day : Saturday				Date : 22.07.23				
Probable Maximum Demand : 15000 MW					Probable Maximum Generation : 15628 MW								
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 75.83 ft		Today = 76.17 ft		Rule Curve = 87.36 ft.				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	21.07.23 (Yesterday)		22.07.23 (Today)		21.07.23 (Yesterday)		22.07.23 (Today)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Water Limitation MW		Machines shut down (MW)		
					Day	Evening	Day	Evening			Description/ Remarks	Probable start-up date	
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	160	200	180	180				
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180				
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0				
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108		Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage	
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0				
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	331	343	330	330				
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	420	450	450	450				
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	388	407	400	400				
11	Siddhirganj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	160	159	185	195				
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	320	333	330	330				
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	280	289	300	300				
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	15	30				
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	64	40	48	102				
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	19	19	19				
17	Summit Power(Madhabdi-Ashulia)	Gas (SIPP, REB)	6x3.07+7x8.73	80	80	40	38	40	41				
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25				
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	23	23	22	22				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	24	8	25				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	35	88	35	88				
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	64	64	64	130				
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	35	17	35				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	16x17.076	300	300	97	97	100	100				
25	Kodda 148 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.15+1x18.97	149	149	35	79	45	149				
26	Keraniganj 300 MW PP (AFR)	HSD (IPP)	25x61.4	300	300	0	0	0	200				
27	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	55	17	55				
28	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	35	17	55				
29	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	51	72	54	72				
30	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	144	17	144				
31	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	34	0	30	0				
32	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	17				
33	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	18	40	40	65				
34	Meghnaghat 100 MW(EL)	HFO (NENP)	12x8.9	100	100	34	49	33	50				
35	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	65	85	96	96				
36	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	0	45	45				
Dhaka Zone Total				5904	5722	2932	3405	3159	3930	213	375		
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	60	60	60	60	170		Low water level	
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.	
39	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	5	0	5	0				
40	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	15	8	17				
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	16	0	20	0				
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	18	19	26	46				
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	17	17	17				
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.	
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	219	226	225	225				
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	123	269	88	300				
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	50	25	50				
48	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	34	50	50	50				
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	24	59	32	59				
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	11	11	11	11				
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			21	38	15	30				
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	12	12	12				
52	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17				
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	76	85	74	85				
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	38	38	25	38				
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	35	46	35	46				
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	51	107	51	107				
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	53	141	17	141				
	SS Power Unit-1	Coal (IPP)				0	0	0	0				
	Cox's Bazar Wind PP	(Wind) (IPP)				21	5	25	25				
Chattogram Zone Total				2605	2545	864	1265	838	1336	350	330		
58	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	0	0	0	0				
59	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1x75	221	221	180	195	190	190				
60	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	240	240	240	240				
61	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	280	280	280	280				
62	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	230	230	230	230				
63	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20'9.73+1'16	195	195	0	0	0	0	195		Gas Shortage	
64	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	51	51				
65	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	5	142	6	150				
66	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	33	40	40	40				
67	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163	Under maint.	
68	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	34	51	34	51				
69	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	19	20	20				
70	Feni 11 MW PP (Doreen)	Gas (SIPP, PDB)	4x2.90	11	11	8	10	10	10				
71	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33				
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	42	43	43	43				
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	17	15	15	15				
74	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	70	105	52	106				
75	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	27	81	9	95				
76	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17				
77	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	54	49	17	98				
**	Impoort (Tripura)	India		160	160	120	124	146	169				
Cumilla Zone Total				2904	2896	1453	1725	1433	1838	195	163		
78	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	31	87	50	80	115		Gas Shortage	
79	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	19	19	19				
80	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	19	85	20	85				
81	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	68	88	68	88				
82	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0				
83	Sutiakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	40	0	50	0				
84	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	12	12	12	12				
Mymensingh Zone Total				622	614	190	291	221	284	115	0		

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	21.07.23 (Yesterday)		22.07.23 (Today)		21.07.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Machines shut down (MW)			
85	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43	27	GT-1 Under maint.	
86	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	40	40	40	40	50	GT-4 Under maint.	
87	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	47	47	45	45			
88	Kushiera 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	80	112	112	112	54	ST Under maint.	
89	Hobgiri 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11			
90	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	50	51	60	60			
91	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	330	Under maint.	
92	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	72	81	86	86			
93	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	205	204	203	204			
94	Sylhet 20 MW GTTP	Gas (PDB)	1x 20	20	20	17	17	17	17			
95	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10			
96	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	24	24	24	24			
97	Bibiya-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	295	300	300			
98	Bibiya-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	368	368	400	400			
99	Bibiya South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	350	350	340	385			
100	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0	100	Under project work	
101	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.4+5*2	50	50	45	44	44	44			
Sylhet Zone Total					2472	2427	1652	1697	1735	0	561	
102	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
103	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	115	160	225	225			
104	Fairdipor 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	23	20	30			
105	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	57	26	60			
106	Khulna 225 MW CAPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	120	120	120	225			
107	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	36	35	35	35			
108	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	15	50	50	105			
109	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	7	0	100	0			
110	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	16	64	80	98			
111	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	8	8	8	40			
112	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	475	503	503	503	114		
113	Khulna 330 MW CAPP (GT)	Gas/HSD (PDB)	1x220	220	220	0	0	0	0			
**	Bheramara (HVDC)	India		1000	1000	918	868	933	933			
Khulna Zone Total					3125	3121	1710	1888	2100	114	0	
114	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	48	64	32	110			
115	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	19	31	21	34			
116	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	132	50	135	135			
117	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	1130	1244	1244	1244	0		
118	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	72	17	150			
119	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	0	0	0	0	307	Under maint.	
120	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220			
Barishal Zone Total					2265	2265	1566	1681	1669	307	0	
121	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage	
121	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Under maint.	
122	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	35	35	21	35			
123	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0			
124	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	28			
125	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	92	0	93			
126	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	30	30	30			
127	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	34	34			
128	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	35	35	0	35			
129	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210	Gas Shortage	
130	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	150	130	130	130			
131	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	138	154	148	155			
132	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	351	414	380	414			
133	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	0	0	0	0	0			
134	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8			
135	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	52	8	52			
136	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	55	55	55			
137	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6*18.55	113	113	35	95	35	95			
138	Ammura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	28	21	21			
139	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	3	0	6	0	0			
**	Adani Power Jharkhanda Ltd	Coal (Import)	2x748	1496	1496	752	753	750	750			
Rajshahi Zone Total					3675	3631	1542	1881	1626	281	100	
140	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Coal Shortage	
140	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overhauling	
141	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170	104	Coal Shortage	
142	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
143	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	37	100	34	92			
144	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
145	Mapara, Tatalia 9 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 9	9	0	1	0	8	0			
146	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6*20	115	115	36	115	35	115			
147	Lalmorhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	10	0	30	0			
148	Teesa Solar Limited	Solar (IPP)	1 x 200	200	200	127	0	130	0			
Rangpur Zone Total					1030	950	381	385	407	189	85	
Sub-total: Plants in operation					24602	24171	12290.0	14218	13188	15628	1764	1614
(B) Plants under long term maintenance/ contract expired												
149	Jamailpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			
150	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			
151	Bosilia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			
152	Ashugani 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	0	0	0	0			
Sub-Total: Plants under long term maintenance/ contract expired					309	0	0	0	0	0	0	
Gross Total					24911	24171	12290	14218	13188	15628	1764	1614
(C) Actual data of 21.07.23 (Yesterday) Friday :												
01.	Max. Demand at eve. peak (Generation end)	:	0	MW, at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	13766	MW, at =	21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW
03.	Highest Generation (Generation end)	:	14318	MW, at =	23:00 hrs	Dhaka	4593	4593	0	Mymensingh	1137	1122
04.	Minimum Generation (Generation end)	:	11545	MW, at =	9:00 hrs	Chattogram	1422	1422	0	Sylhet	582	582
05.	Day-peak Generation (Generation end)	:	12290	MW, at =	12:00 hrs	Khulna	1771	1771	0	Barishal	452	452
06.	Evening-peak Generation (Generation end)	:	14218	MW, at =	21:00 hrs	Rajshahi	1497	1497	0	Rangpur	964	964
07.	Evening Peak Load-shed (Sub-station end)	:	120	MW, at =	21:00 hrs	Cumilla	1349	1244	105			
08.	Minimum Generation Forecast up to 8:00 hrs.	:	11701	MW, at =	5:00 hrs							
09.	Generation shortfall at evening peak due to :	:										
	a) Gas/LF limitation	:	1405	MW								
	d) Coal supply Limitation	:	189	MW								
	b) Low water level in Kaptai lake	:	170	MW								
	c) Plants under shut down/ maintenance	:	1614	MW								
10.	Total Energy (Generation + India Import)	:	304.62	MW								
	By Gas = 153.569 MKWH			By Oil =	59.065 MKWH							
	By Coal = 63.330 MKWH			By Hydro =	1.437 MKWH							
	By Solar= 2.108 MKWH											
11.	Total Gas Supplied	:	1161.20	MMCFD								
(D) Forecast of 22.07.23 (Today) Saturday :												
01.	Maximum Demand	:	15000	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)	
02.	Maximum Generation	:	15628	MW	(Generation end)	05.	Total Generation	:	319.13	MW		
03.	Reserve / Shortage	:	628	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	35.8° C			

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation