

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month July, 2023					Day : Tuesday					Date : 25.07.23				
Probable Maximum Demand : 15600 MW					Probable Maximum Generation : 16010 MW									
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 76.48 ft		Today = 76.70 ft		Rule Curve = 87.84 ft					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	24.07.23 (Yesterday)		25.07.23 (Today)		24.07.23 (Yesterday)		25.07.23 (Today)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date		
					Day	Evening	Day	Evening	Gas/Coal/Water Limitation MW	Machines shut down (MW)				
(A) Plants in operation:														
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	0	0	0	0		260	Under project work			
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	190	190	190						
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180						
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0						
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	108		Gas Shortage			
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	105		Gas Shortage			
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0						
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	291	289	290	290					
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450					
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0		115	Under Overhauling			
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	403	391	400	400					
11	Siddhirganj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	187	192	185	195					
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	320	323	330	330					
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	305	289	280	300					
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	30	15	30					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	32	82	32	82					
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	10	19	19					
17	Summit Power(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	40	40	40	40					
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	33	33	33					
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	22	8	24	24					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	50	8	50					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	52	88	35	88					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	64	82	64	130					
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	22	35	17	35					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	16x17.076	300	300	97	97	95	95					
25	Kodda 148 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.15+1x8.97	149	149	35	135	35	135					
26	Keraniganj 300 MW PP (AFR)	HSD (IPP)	25x61.4	300	300	0	215	0	200					
27	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	55	35	55					
28	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	35	55					
29	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	17	54	72					
30	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	54	162	35	162					
31	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	36	0	30	0					
32	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	17	17	17					
33	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	41	64	40	70					
34	Meghnaghat 100 MW(EL)	HFO (NENP)	12x8.9	100	100	49	73	25	66					
35	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	85	95	96	96					
36	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	45	40	45	55					
Dhaka Zone Total			5904	5722	3119	3767	3134	3944	213	375				
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	70	70	70	70	160	Low water level			
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	54	110	115	115	70	Gas Shortage			
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.			
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	5	0	5	0					
40	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	25	8	25					
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	0	0	20	0					
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	44	26	46					
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	45	68	17	51					
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.			
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	217	221	225	225					
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	122	190	88	300					
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	20	68	35	68					
48	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	50	37	50	50					
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	40	80	40	80					
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	11	11	11	11					
*	Malancha, Ctg EP2 (United)	Gas	5x8.73+3x9.34			3	33	5	30					
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	12	12	12					
52	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	36	17	36					
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	93	93	75	93					
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	12	38	38	38					
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	25	58	35	58					
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	48	68	34	68					
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	108	90	17	90					
	SS Power Unit-1	Coal (IPP)				0	0	0	0					
	Cox's Bazar Wind PP	(Wind) (IPP)			4	0	25	25						
Chattogram Zone Total			2605	2545	972	1352	968	1491	230	330				
58	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	3	3	3	3					
59	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+175	221	221	163	181	190	190					
60	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	230	230	230	230					
61	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	280	300	300	300					
62	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	230	230	230	230					
63	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20'9.73+1'16	195	195	0	0	0	0	195	Gas Shortage			
64	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	35	43	43	43					
65	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	5	134	6	150					
66	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	23	35	35	40					
67	Chandpur 150 MW CCPP	Gas (PDB)	1x106+1x57	163	163	0	0	0	0	163	Under maint.			
68	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	34	51	34	51					
69	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	19	15	19					
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	10	10					
71	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	30	33	33	33					
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	34	43	43	43					
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	17	20	20	20					
74	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	88	70	35	105					
75	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	9	97	27	75					
76	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17					
77	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	55	114	94	114					
**	Imphoct (Tripura)	India		160	160	140	104	146	169					
Cumilla Zone Total			2904	2896	1420	1734	1511	1842	195	163				
78	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	30	55	44	80	147	Gas Shortage			
79	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	18	19	19					
80	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	56	78	70	78					
81	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	19	93	68	88					
82	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0					
83	Sutiakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	51	0	50	0					
84	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	6	6	6	12					
Mymensing Zone Total			622	614	182	250	259	277	147	0				

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	24.07.23 (Yesterday)		25.07.23 (Today)		24.07.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Machines shut down (MW)			
85	Fenchuganj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	0	43	43		GT-1 Under maint.	
86	Fenchuganj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	40	0	0	0	90	GT-4 Under maint.	
87	Fenchuganj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	44	47	45	45			
88	Kushiera 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	112	112	54	ST Under maint.	
89	Hobgiri 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	3	11	3			
90	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	49	50	60	60			
91	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	330	Under maint.	
92	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	72	78	78	80			
93	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	204	115	115	115			
94	Sylhet 20 MW GTTP	Gas (PDB)	1x 20	20	20	16	17	17	17			
95	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10			
96	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	24	24	24	24			
97	Bibiya-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	300	300	300			
98	Bibiya-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	367	368	370	370			
99	Bibiya South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	350	350	350	385			
100	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0	100	Under project work	
101	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.4+5*2	50	50	45	46	44	44			
Sylhet Zone Total					2472	2427	1676	1520	1579	1616	0	644
102	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
103	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	110	95	115	115			
104	Fairdipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	10	24	20	30			
105	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	30	55	40	55			
106	Khulna 225 MW CAPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	120	120	120	120			
107	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	35	35	35	35			
108	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	85	105	85	105			
109	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	108	0	100	0			
110	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	95	86	80	86			
111	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	8	8	8			
112	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	445	472	450	507	145		
113	Khulna 330 MW CAPP (GT)	Gas/HSD (BFD)	1x220	220	220	230	150	220	220			
**	Bheramara (HVDC)	India		1000	1000	917	844	934	934			
Khulna Zone Total					3125	3121	2185	1994	2207	2215	145	0
114	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	32	32	32			
115	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	22	31	22	34			
116	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	134	136	135	135			
117	Payra 1320 MW TTP	Coal (BCPCL)	2x622	1244	1244	1222	1244	1244	1244			
118	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	150	17	150			
119	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	58	150	307	307	157		Under maint.
120	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	221	220	220			
Barishal Zone Total					2265	2265	1689	1964	1977	2122	157	0
121	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage
122	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Under maint.
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	34	33	35	35			
124	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	200	200	200	200			
125	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	23	0	35			
126	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	55	0	93			
127	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	38	35	35			
128	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	34	34	34	42			
129	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	35	0	35			
130	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage
131	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	138	143	143	143			HSD
132	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	140	143	145	143	80		Gas Shortage
133	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	283	321	320	320	131		Gas Shortage
134	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	0	0	0	0	0			
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8			
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	16	52	8	52			
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	55	35	55			
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6*18.55	113	113	35	94	35	95			
139	Ammura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	28	28	28	28			
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0			
**	Adani Power Jharkhanda Ltd	Coal (Import)	2x748	1496	1496	744	746	750	750			
Rajshahi Zone Total					3675	3631	1700	2008	1782	2069	492	100
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage
142	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling
143	Barapukuria 275 MW TTP Unit-3	Coal (PDB)	1 x 274	274	274	240	250	210	250	24		Coal Shortage
144	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	34	85	34	92			
146	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
147	Majma. Talsia 9 MW Solar PP (Syma Power)	Solar (IPP)	1 x 9	9	9	5	0	8	0			
148	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6*20	119	115	36	94	35	92			
149	Lalmoharhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	13	0	30	0			
150	Teesa Solar Limited	Solar (IPP)	1 x 200	200	200	148	0	130	0			
Rangpur Zone Total					1030	950	476	429	447	434	109	85
Sub-total: Plants in operation					24602	24171	13419.0	15018	13864	16010	1688	1697
(B) Plants under long term maintenance/ contract expired												
151	Jamelpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			
152	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			
153	Bosilia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			
154	Ashugani 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	0	0	0	0			
Sub-Total: Plants under long term maintenance/ contract expired					309	0	0	0	0	0	0	0
Gross Total					24911	24171	13419	15018	13864	16010	1688	1697
(C) Actual data of 24.07.23 (Yesterday) Monday :												
01.	Max. Demand at eve. peak (Generation end)	:	15550 MW, at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	14893 MW, at =	21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	15018 MW, at =	21:00 hrs	Dhaka	5184	5139	45	Mymensingh	1182	1075	107
04.	Minimum Generation (Generation end)	:	12254 MW, at =	8:00 hrs	Chattogram	1564	1564	0	Sylhet	588	523	65
05.	Day-peak Generation (Generation end)	:	13419 MW, at =	12:00 hrs	Khulna	1847	1770	77	Barishal	485	485	0
06.	Evening-peak Generation (Generation end)	:	15018 MW, at =	21:00 hrs	Rajshahi	1719	1719	0	Rangpur	999	907	92
07.	Evening Peak Load-shed (Sub-station end)	:	508 MW, at =	21:00 hrs	Cumilla	1325	1203	122				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	12460 MW, at =	5:00 hrs					Total	14893	14385	508
09.	Generation shortfall at evening peak due to :	:			13.	Fuel cost :	(a) Gas = 169858087 Taka (b) Oil = 919602681 Taka	(c) Coal = 312639373 Taka Total = 1402100141 Taka				
	a) Gas/LF limitation	:	1419 MW		14.	Maximum Temperature in Dhaka was :	36.1° C					
	d) Coal supply Limitation	:	109 MW		15.	Export through East-West interconnections :						
	b) Low water level in Kaptai lake	:	160 MW			At evening peak-hour	:	13419 MW, at	21:00 hrs			
	c) Plants under shut down/ maintenance	:	1697 MW			Maximum	:	800 MW, at	22:00 hrs			
10.	Total Energy (Generation + India Import)	:	319.87 MMkWh			Energy	:	0 MMkWh				
	By Gas = 153.633 MMkWh	By Oil = 69.559 MMkWh										
	By Coal = 67.191 MMkWh	By Hydro = 1.688 MMkWh										
	By Solar= 2.644 MMkWh											
11.	Total Gas Supplied	:	1186.22 MMCFD									
(D) Forecast of 25.07.23 (Today) Tuesday :												
01.	Maximum Demand	:	15600 MW (Generation end)		04.	Maximum Load-shed	:	0 MW	At evening peak (Sub-station end)			
02.	Maximum Generation	:	16010 MW (Generation end)		05.	Total Generation	:	332.27 MMkWh				
03.	Reserve / Shortage	:	410 MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	36.1° C					

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation