

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month July, 2023				Day : Friday				Date : 28.07.23			
Probable Maximum Demand : 14500 MW				Probable Maximum Generation : 16062 MW							
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 78.37 ft		Today = 79.87 ft		Rule Curve = 88.32 ft			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	27.07.23 (Yesterday)		28.07.23 (Today)		27.07.23 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)	Probable Peak Generation (MW)	Probable Peak Generation (MW)	Gen. shortfall for :			
								Gas/Coal/Water Limitation MW	Machines shut down (MW)		
					Day	Evening	Day	Evening			Probable start-up date
(A) Plants in operation:											
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	200	200	200	200		
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180		
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108	Gas Shortage
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0		
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	294	318	290	290		
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450		
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	387	373	390	390		
11	Siddhirganj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	178	175	190	195		
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	213	215	330	330		
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	300	286	300	300		
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	26	15	25		
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	32	82	32	84		
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	19	19	19		
17	Summit Power(Madhabdi-Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	31	37	40	40		
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	33	33		
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	24	24	24	24		
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	51	8	25		
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	52	88	35	88		
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	82	130	48	130		
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	35	17	35		
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	16x17.076	300	300	115	115	115	115		
25	Kodda 148 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	73	113	70	148		
26	Keraniganj 300 MW PP (AFR)	HSD (IPP)	25x6.14	300	300	150	47	150	250		
27	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	55	35	55		
28	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	35	35	55		
29	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	17	17	17		
30	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	54	108	35	162		
31	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	36	0	30	0		
32	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	34	17	34		
33	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	25	41	25	40		
34	Meghnaghat 100 MW(EL)	HFO (NENP)	12x8.9	100	100	23	32	25	34		
35	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	95	87	96	96		
36	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	22	13	22	22		
Dhaka Zone Total				5904	5722	3168	3411	3273	3867	213	375
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	75	80	80	80	150	Low water level
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	117	122	120	120	58	Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	1	0	5	0		
40	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	25	8	25		
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	18	0	20	0		
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	40	6	47		
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	97	97	97	97		
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	227	225	225	225		
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	122	254	120	300		
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	50	100	37	100		
48	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	50	50	50	50		
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	32	67	40	80		
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	8	11	11	11		
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			3	30	25	35		
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	24	0	20		
52	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17		
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	55	55	54	54		
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	38	82	38	64		
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	47	70	45	70		
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	34	68	34	68		
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	72	143	52	163		
	SS Power Unit-1	Coal (IPP)				0	0	0	0		
	Cox's Bazar Wind PP	(Wind) (IPP)				21	6	25	25		
Chattogram Zone Total				2605	2545	1098	1566	1109	1651	208	330
58	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	0	0	0	0		
59	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1x75	221	221	147	164	180	180		
60	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	265	230	230	230		
61	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	270	270	280	300		
62	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	230	230	230	230		
63	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20'9.73+1'16	195	195	0	0	0	0	195	Gas Shortage
64	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	43	43	43		
65	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	12	115	12	150		
66	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	37	28	44	44		
67	Chandpur 150 MW CCPP	Gas (PDB)	1x106+1x57	163	163	0	0	0	0	163	Under maint.
68	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	51	131	51	100		
69	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	20	20	20		
70	Feni 11 MW PP (Doreen)	Gas (SIPP, PDB)	4x2.90	11	11	10	10	10	10		
71	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	32	33	33		
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	25	43	43	43		
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	20	20	20		
74	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	70	88	17	17		
75	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	28	76	27	75		
76	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17		
77	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	72	72	72	72		
**	Importo (Tripura)	India		160	160	124	124	146	169		
Cumilla Zone Total				2904	2896	1474	1713	1475	1753	195	163
78	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	27	44	30	80	158	Gas Shortage
79	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	16	19	19		
80	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	19	85	18	85		
81	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	70	87	68	88		
82	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0		
83	Sutiakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	32	0	50	0		
84	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	6	6	6	6		
Mymensingh Zone Total				622	614	172	238	193	278	158	0

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	27.07.23 (Yesterday)		28.07.23 (Today)		27.07.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for r Limitation MW			
						Day	Evening	Day	Evening	Machines shut down (MW)	Description/ Remarks		
85	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30		40	GT-1 Under maint.	
86	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	0	0	0			Under maint.	
87	Fenchugonj 51 MW PP (Barakattulah)	Gas (RPP)	19x2.90	51	51	47	50	50	50			ST Under maint.	
88	Kushlari 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	112	112	112	112	112		54		
89	Hobigunj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
90	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	20	51	0	60				
91	Shajbazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
92	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	78	86	80	86				
93	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	115	115	115	115				
94	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	17	17	17	17				
95	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
96	Shajahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	24	25	24	24				
97	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	285	280	300	300				
98	Bibiyan-II 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	405	368	400	400				
99	Bibiyan South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	350	350	350	385				
100	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
101	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12'3.3+5'2	50	50	43	47	48	48				
Sylhet Zone Total						2472	2427	1547	1552	1547	1648	0	524
102	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
103	Bheramara 410 MW CCPP	Gas (NWPGCL)	1 x 278+1 x 132	410	410	95	60	110	110				
104	Fardipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	10	28	20	30				
105	Copalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	22	47	40	55				
106	Khulna 225 MW CCPP	HSD/ Gas (NWPGCL)	1 x 150+1x75	230	230	120	120	120	120				
107	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	35	35	35	35				
108	Madhumati 100 MW PP	HFO (NWPGCL)	6x18.415	105	105	32	105	32	105				
109	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	82	0	100	0				
110	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	62	97	80	95				
111	Noapara 40 MW PP (Khanishan Ali)	HFO (NENP)	5'8.5	40	40	0	32	32	40				
112	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPOL)	1x617	617	617	518	617	500	500				
113	Khulna 330 MW CCPP (GT)	Gas/HSD (PDB)	1x220	220	220	0	79	220	220				
**	Bheramara (H/DC)	India		1000	1000	899	847	930	930				
Khulna Zone Total						3125	3121	1875	2058	2219	2240	0	0
114	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	32	64	48	110				
115	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	22	30	22	34				
116	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	128	120	135	135				
117	Payra 1320 MW TPP	Coal (BCPOL)	2x622	1244	1244	1210	1220	1244	1244				
118	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	17	17	150				
119	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	250	250	250	250				
120	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	223	220	220	220				
Barishal Zone Total						2265	2265	1865	1921	1936	2143	0	0
121	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0			100	Under maint.
122	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	35	34	35	35				
123	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	50	70	200	200				
124	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	24	0	35				
125	Chapainabaganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	45	91	0	93				
126	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	38	38	35	35				
127	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	34	34	34	34				
128	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	25	30	30	35				
129	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGCL)	1x150+1x75	210	210	0	0	0	0		210	Gas Shortage	
130	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGCL)	1x150 + 1x75	220	220	155	202	151	215			HSD	
131	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGCL)	1x141+1x79	220	220	138	139	145	145		82	Gas Shortage	
132	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	314	324	320	340		100	Gas Shortage	
133	Bogra 22 MW PP (GBB)	Gas (RPP)	8x4.0	22	0	0	0	0	0				
134	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8				
135	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x6.92	52	52	8	8	8	8				
136	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6'18.55	113	113	35	55	35	55				
137	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	95	35	95				
138	Ammura 50 MW PPSinha)	HFO (NENP)	7x7.79	50	28	28	21	21	21				
139	Sirajgonj 6.55 MW Solar	Solar (NWPGCL)	1x6	6	6	1	0	6	0				
**	Adani Power Jharkhanda Ltd	Coal (Import)	2x748	1496	1496	761	754	750	750				
Rajshahi Zone Total						3675	3631	1710	1927	1813	2104	463	100
140	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0			85	Under Overhauling
141	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	220	220	180	180		54	Coal Shortage	
142	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
143	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	34	85	34	85				
144	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
145	Majpara, Tatula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	4	0	8	0				
146	Thakurgaon 115MW PP (Energyrac)	HFO (IPP)	6'20	115	115	36	113	35	113				
147	Lalmoinhat 30 MW Solar (Intraco)	Solar (IPP)	1'30	30	30	36	0	30	0				
148	Taista Solar Limited	Solar (IPP)	1 x 200	200	200	178	0	130	0				
Rangpur Zone Total						1030	950	508	418	417	378	139	85
Sub-total: Plants in operation						24602	24171	13417.0	14804	13982	16062	1376	1577
(B) Plants under long term maintenance contract expired													
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
150	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
151	Bosilia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
152	Ashugani 55 MW PP (Precision)	Gas (RPP)	15'4	55	0	0	0	0	0				
Sub-total: Plants under long term maintenance contract expired						309	0	0	0	0	0	0	0
Gross Total						24911	24171	13417	14804	13982	16062	1376	1577
(C)													
Actual data of 27.07.23 (Yesterday) Thursday :													
01.	Max. Demand at eve. peak (Generation end)	:	15160	MW, at =	20:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	14598	MW, at =	20:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	14804	MW, at =	20:00 hrs		MW	MW	MW		MW	MW	MW
04.	Minimum Generation (Generation end)	:	12071	MW, at =	7:00 hrs	Dhaka	5091	5091	0	Mymensingh	1245	1052	193
05.	Day-peak Generation (Generation end)	:	13417	MW, at =	12:00 hrs	Chattoagram	1415	1415	0	Sylhet	607	607	0
06.	Evening-peak Generation (Generation end)	:	14804	MW, at =	20:00 hrs	Khulna	1749	1749	0	Barishal	449	449	0
07.	Evening Peak Load-shed (Sub-station end)	:	340	MW, at =	20:00 hrs	Rajshahi	1616	1616	0	Rangpur	1059	937	122
08.	Minimum Generation Forecast up to 8:00 hrs.	:	11378	MW, at =	5:00 hrs	Cumilla	1368	1343	25				
09.	Generation shortfall at evening peak due to :	:								Total	14598	14258	340
a)	Gas/LF limitation	:	1087	MW		13.	Fuel cost :	(a) Gas = 163348209 Taka	(c) Coal = 306950777 Taka				
b)	Coal supply Limitation	:	139	MW				(b) Oil = 925816223 Taka	Total = 1396115209 Taka				
c)	Low water level in Kaptai lake	:	150	MW									
c)	Plants under shut down/ maintenance	:	1577	MW		14.	Maximum Temperature in Dhaka was : 33.9° C						
10.	Total Energy (Generation + India Import)	:	319.55	MKWh		15.	Export through East-West interconnections :						
	By Gas = 147.556 MKWh	By Oil = 68.750 MKWh					At evening peak-hour	:	13417	MW, at	20:00 hrs		
	By Coal = 73.558 MKWh	By Hydro = 1.794 MKWh					Maximum	:	560	MW, at	21:00 hrs		
	By Solar= 2.903 MKWh						Energy	:	0	MKWh			
11.	Total Gas Supplied	:	1170.26	MMCFD									
(D)													
Forecast of 28.07.23 (Today) Friday :						04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)						
01.	Maximum Demand	:	14500	MW	(Generation end)	05.	Total Generation : 312.99 MKWh						
02.	Maximum Generation	:	16062	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka : 33.9° C						
03.	Reserve / Shortage	:	1562	MW	(Generation end)								