

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564657, 9551095

Month August, 2023						Day : Tuesday				Date : 01.08.23					
Probable Maximum Demand : 15500 MW						Probable Maximum Generation : 15307 MW						Rule Curve = 89.00 ft.			
Water Level of Kaptai Lake at 06:00 AM						Yesterday = 80.30 ft		Today = 79.93 ft.							
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	31.07.23 (Yesterday)		01.08.23 (Today)		31.07.23 (Yesterday)		01.08.23 (Today)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Machines shut down (MW)		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening							
(A) Plants in operation:															
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0			260	Under project work		
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	210	210	210	210						
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180						
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0						
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	12	12	12	12	96			Gas Shortage		
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105			Gas Shortage		
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0						
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	317	317	320	330						
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450						
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0			115	Under Overhauling		
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	360	362	370	370						
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	180	198	195	195						
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	315	326	330	330						
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	0	0	0	0			115	Under maint.		
14	Madangan-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	15	15						
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	50	102	50	102						
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	17	0	17	17						
17	Summit Power, (Madhabdi-Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	38	41	38	41						
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	33	33	33						
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	15	16	16	24						
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	25	8	25						
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	35	105	35	105						
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	64	130	64	130						
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	35	17	34						
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	105	112	112	112						
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	71	144	70	149						
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	63	250	0	200						
27	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	55	35	55						
28	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	35	35						
29	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	50	72	53	72						
30	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	54	162	54	162						
31	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	34	0	35	0						
32	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	0	17	17						
33	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	50	65	50	72						
34	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	50	59	50	64						
35	Madangan 102 PP(Summit)	HFO (NENP)	6x17	102	102	96	51	17	51						
36	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	0	0	0						
Dhaka Zone Total				5904	5722	2933	3562	2888	3592	201	490				
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	115	132	130	130	98			Low water level		
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	118	117	120	120	63			Gas Shortage		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0			180	Under maint.		
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	5	0	5	0						
40	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	25	8	25						
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	13	0	20	0						
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	46	6	46						
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	51	51	51	51						
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0			150	Under maint.		
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	214	225	220	225						
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	121	265	120	300						
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	37	100	50	100						
48	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	34	50	50	50						
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	24	84	40	84						
50	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	10	12	12	12						
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	17	5	25						
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	24	0	24						
52	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	36	36						
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	55	55	54	54						
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	38	88	38	88						
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRRP)	8x13.45	100	100	46	80	46	80						
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	34	68	34	68						
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	17	142	17	142						
	SS Power Unit-1	Coal (IPP)				275	310	450	300						
	Matarbari 2*600 MW (CPGCL)	Coal				150	110	150	0				Test run		
	Cox's Bazar Wind PP	(Wind) (IPP)				0	0	20	10						
Chattogram Zone Total				2605	2545	1390	2018	1682	1970	161	330				
58	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	0	0	5	5	45			Gas Shortage		
59	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	200	207	200	205						
60	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	240	260	260	260	100			Gas Shortage		
61	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	305	280	280	280	80			Gas Shortage		
62	Ashuganj 420 MW CCPP(East)	Gas (APSCL)	1x284+1x116	400	400	230	250	250	250	150			Gas Shortage		
63	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*116	195	195	0	0	0	0	195			Gas Shortage		
64	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	43	43	43						
65	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	6	48	6	60						
66	Titlas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	23	32	44	46						
67	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0			163	Under maint.		
68	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	71	156	51	150						
69	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	7	8	20	20						
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11						
71	Jangalia 33 MW PP (Summit))	Gas (SIPP, PDB)	4x8.73	33	33	25	31	25	33						
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	43	40	43	43						
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	15	0	20	20						
74	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	34	0	106						
75	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	27	57	27	75						
76	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	17	17						
77	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	59	109	72	115						
**	Impoqri (Tripura)	India		160	160	146	112	146	169						
Cumilla Zone Total				2904	2896	1486	1713	1520	1908	570	163				
78	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	33	97	50	98	105			Gas Shortage		
79	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	0	18	18						
80	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	24	84	24	85						
81	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.78	200	200	67	86	68	85						
82	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0						
83	Suliakhali 50 MW Solar PP	Solar (IPP)	1x50	50	50	42	0	50	0						
84	Tangail 22 MW PP(PDGL)	HFO (IPP)	4x6.7	22	22	6	6	6	6						
Mymensingh Zone Total				622	614	190	273	218	292	105	0				

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	31.07.23 (Yesterday)		01.08.23 (Today)		31.07.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Oil/Water Limitation MW		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Machines shut down (MW)			
85	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30		40	GT-1 Under maint.	
86	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	0	0	0			Under maint.	
87	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	42	47	50	50				
88	Kushiera 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	0	0	0		54	ST Under maint.	
89	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	0	11	11				
90	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	0	20	20	30				
91	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
92	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	78	86	80	86				
93	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	181	110	110	115				
94	Sylhet 20 MW GTTP	Gas (PDB)	1x 20	20	20	17	17	17	17				
95	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10				
96	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	24	24				
97	Bibiya-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	280	300	300	300				
98	Bibiya-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	386	367	400	400				
99	Bibiya South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	350	303	350	350				
100	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
101	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.4+5*2	50	50	43	45	48	48				
Sylhet Zone Total						2472	2427	1552	1351	1450	1471	0	524
102	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
103	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	130	135	155	155				
104	Fairdipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	10	22	20	30				
105	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	22	56	40	55				
106	Khulna 225 MW CCPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	120	190	120	190				
107	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	35	35	35	35				
108	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	50	105	50	105				
109	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	63	0	100	0				
110	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	16	16	16	16				
111	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	8	8	32	40				
112	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	0	0	0	0		617	Coal Shortage	
113	Khulna 330 MW CCPP (GT)	Gas/HSD (BDFB)	1x220	220	220	226	234	15	234				
**	Bheramara (HVDC)	India		1000	1000	913	814	928	928				
Khulna Zone Total						3125	3121	1593	1605	1511	1778	617	0
114	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	64	16	110				
115	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	25	34	22	34				
116	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	130	65	120	120				
117	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	1244	1244	1244	1244				
118	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	150	17	150				
119	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	250	150	0	0		157	Coal Shortage	
120	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	218	220	220	220				
Barishal Zone Total						2265	2265	1900	1927	1639	1878	157	0
121	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage	
122	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.	
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	35	0	35				
124	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
125	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	25	0	32				
126	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	48	90	50	90				
127	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	38	35	0	35				
128	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	42	0	0				
129	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	24	0	31				
130	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	0	0	0	0		210	Gas Shortage	
131	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	160	213	214	220				
132	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	143	147	160	181		77	Gas Shortage	
133	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	336	344	414	414				
134	Bogra 22 MW PP (GGB)	Gas (RPP)	6x4.0	22	0	0	0	0	0				
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8				
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	8	8	8				
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	56	35	57				
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	50	75	50	95				
139	Amnura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	21	21	21	21				
140	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	5	0	6	0				
**	Adani Power Jharkhanda Ltd	Coal (Import)	2x748	1496	1496	765	774	750	750				
Rajshahi Zone Total						3675	3631	1617	1897	1716	1977	358	100
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage	
142	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	240	220	220	230		54	Coal Shortage	
144	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	13	0	0				
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	34	98	34	98				
146	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	10	0	0				
147	Majma. Talsia 9 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 9	9	9	7	0	8	0				
148	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6*20	119	115	35	114	35	113				
149	Lalmoharhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	20	0	30	0				
150	Teesa Solar Limited	Solar (IPP)	1 x 200	200	200	201	0	130	0				
Rangpur Zone Total						1030	950	537	455	457	441	139	85
Sub-total: Plants in operation						24602	24171	13198.0	14801	13081	15307	2308	1692
(B) Plants under long term maintenance/ contract expired													
151	Jamelpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
152	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
153	Bosilia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
154	Ashugani 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	0	0	0	0				
Sub-Total: Plants under long term maintenance/ contract expired						309	0	0	0	0	0	0	0
Gross Total						24911	24171	13198	14801	13081	15307	2308	1692
(C) Actual data of 31.07.23 (Yesterday) Monday :													
01.	Max. Demand at eve. peak (Generation end)	:	15220 MW, at =	21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	14391 MW, at =	21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW	
03.	Highest Generation (Generation end)	:	14801 MW, at =	21:00 hrs	Dhaka	4936	4896	40	Mymensingh	1288	1118	170	
04.	Minimum Generation (Generation end)	:	12165 MW, at =	9:00 hrs	Chattogram	1484	1484	0	Sylhet	538	538	0	
05.	Day-peak Generation (Generation end)	:	13198 MW, at =	12:00 hrs	Khulna	1868	1868	0	Barishal	474	474	0	
06.	Evening Peak Generation (Generation end)	:	14801 MW, at =	21:00 hrs	Rajshahi	1575	1515	60	Rangpur	1134	1044	90	
07.	Evening Peak Load-shed (Sub-station end)	:	400 MW, at =	21:00 hrs	Cumilla	1094	1054	40					
08.	Minimum Generation Forecast up to 8:00 hrs.	:	12246 MW, at =	5:00 hrs					Total	14391	13991	400	
09.	Generation shortfall at evening peak due to :	:			13.	Fuel cost :	(a) Gas = 164958993 Taka (b) Oil = 922612182 Taka	(c) Coal = 309892790 Taka Total = 1397463965 Taka					
a) Gas/LF limitation	:	2071 MW			14.	Maximum Temperature in Dhaka was :	37.1° C						
d) Coal supply Limitation	:	139 MW			15.	Export through East-West interconnections :							
b) Low water level in Kaptai lake	:	98 MW			At evening peak-hour	:	13198 MW, at	21:00 hrs					
c) Plants under shut down/ maintenance	:	1692 MW			Maximum	:	390 MW, at	22:00 hrs					
10.	Total Energy (Generation + India Import)	:	317.96 MMCFD		Energy	:	0 MKWh						
	By Gas = 149.123 MKWh By Coal = 69.277 MKWh By Solar= 3.042 MKWh		By Oil = 68.534 MKWh By Hydro = 2.821 MKWh										
11.	Total Gas Supplied	:	1124.55 MMCFD										
(D) Forecast of 01.08.23 (Today) Tuesday :													
01.	Maximum Demand	:	15500 MW (Generation end)		04.	Maximum Load-shed	:	178 MW At evening peak (Sub-station end)					
02.	Maximum Generation	:	15307 MW (Generation end)		05.	Total Generation	:	332.98 MKWh					
03.	Reserve / Shortage	:	-193 MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	37.1° C						

#Remarks: Highest Generation 15648 MW on 19-04-2023 at