

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564657, 9551095

Month August, 2023				Day : Thursday				Date : 03.08.23				
Probable Maximum Demand : 14500 MW				Probable Maximum Generation : 15448 MW								
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 79.53 ft		Today = 79.13 ft		Rule Curve = 89.64 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	02.08.23 (Yesterday)		03.08.23 (Today)		02.08.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)	Probable Peak Generation (MW)	Gen. shortfall for : Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date		
											Day	Evening
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	130	158	210	210			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180			
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0			
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	12	12	12	12	96	Gas Shortage	
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage	
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	333	341	325	330			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450			
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	400	399	360	360			
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	153	130	195	195			
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	329	332	330	330			
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	115	Under maint.	
14	Madangan-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	15	15			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	50	102	102	102			
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	19	17	17			
17	Summit Power, Madhabdi-Ashulia	Gas (SIPP, REB)	6x3.67+3x8.73	80	80	31	36	38	41			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	33	33			
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	23	24	30	30			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	25	8	25			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	35	105	35	105			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	64	130	64	130			
23	Kamalaghat 54 MW PP (Barco Energy)	HFO (IPP)	3x18.69	54	54	17	35	17	34			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	112	112	112	112			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	71	149	70	149			
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	13	0	150			
27	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	35	35	55			
28	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	35	35			
29	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	53	72	53	72			
30	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	54	144	54	162			
31	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	26	0	35	0			
32	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	34	17	17			
33	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	50	60	50	75			
34	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	37	33	42	50			
35	Madangan 102 PP(Summit)	HFO (NENP)	6x17	102	102	17	51	17	51			
36	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	13	49	50	50			
Dhaka Zone Total			5904	5722	2759	3305	2991	3577	201	490		
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	130	130	130	130	100	Low water level	
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	115	120	120	120	60	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	2	0	5	0			
40	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	13	25	17	25			
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	3	0	20	0			
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	39	6	46			
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	34	51	51	51			
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	221	226	220	225			
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	138	256	120	300			
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	75	25	100			
48	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	50	50	50	50			
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	25	8	24	40			
50	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	12	12	12			
*	Malancha, Cig EPZ (United)	Gas	5x8.73+3x9.34			10	26	2	30			
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	75	12	80			
52	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	36	36			
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	44	70	54	55			
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	38	76	38	88			
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRRP)	8x13.45	100	100	46	68	59	80			
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	34	51	34	68			
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	53	142	54	144			
	SS Power Unit-1	Coal (IPP)				0	0	0	0			
	Matarbari 2*600 MW (CPGCL)	Coal				0	0	0	0		Test run	
	Cox's Bazar Wind PP	(Wind) (IPP)				21	17	22	22			
Chattogram Zone Total			2605	2545	1025	1534	1111	1702	160	330		
58	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	0	0	0	0	45	Gas Shortage	
59	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	168	152	170	180			
60	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	240	240	260	260	120	Gas Shortage	
61	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	270	270	280	280	90	Gas Shortage	
62	Ashuganj 420 MW CCPP(East)	Gas (APSCL)	1x284+1x116	400	400	230	230	250	250	170	Gas Shortage	
63	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*116	195	195	8	8	0	0	187	Gas Shortage	
64	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	43	43	43			
65	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	5	41	6	60			
66	Titlas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	39	33	44	46			
67	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under maint.	
68	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	70	134	68	155			
69	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	20	20			
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11			
71	Jangalia 33 MW PP (Summit))	Gas (SIPP, PDB)	4x8.73	33	33	33	32	32	33			
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	34	43	43	43			
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	15	20	20	20			
74	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	52	106	52	106			
75	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	0	0	0	0			
76	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17			
77	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	72	115	72	115			
**	Import (Tripura)	India		160	160	140	138	146	163			
Cumilla Zone Total			2904	2896	1466	1652	1534	1802	612	163		
78	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	30	64	50	98	138	Gas Shortage	
79	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	14	17	18	18			
80	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	18	84	18	85			
81	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	68	88	68	85			
82	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0			
83	Sulakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	49	0	50	0			
84	Tangail 22 MW PP(PPLGL)	HFO (IPP)	4x6.7	22	22	6	6	6	6			
Mymensingh Zone Total			622	614	186	259	212	292	138	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	02.08.23 (Yesterday)		03.08.23 (Today)		02.08.23 (Yesterday)		Status of Machines under shut-down/ Maintenance				
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date			
						Day	Evening	Day	Evening	Gas/Coal/Water Limitation MW	Machines shut down (MW)					
85	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30		40	GT-1 Under maint.				
86	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	20	30	30	30			Under maint.				
87	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	47	50	50	50							
88	Kushiera 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	80	112	112		54	ST Under maint.				
89	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	8	11	11							
90	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	20	28	30	30							
91	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.				
92	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	75	86	80	86							
93	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	111	111	112	112							
94	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	17	17	17	17							
95	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	7	9	10	10							
96	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	22	24	24	24							
97	Bibiya-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	270	300	300							
98	Bibiya-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	385	400	400	400							
99	Bibiya South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	355	335	350	350							
100	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work				
101	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.4+5*2	50	50	46	47	48	48							
Sylhet Zone Total						2472	2427	1552	1525	1604	1610	0	524			
102	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0							
103	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	120	115	130	120							
104	Fairdipor 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	41	0	41							
105	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	67	40	67							
106	Khulna 225 MW CAPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	116	115	120	120							
107	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	53	40	53	53							
108	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	15	105	50	105							
109	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	41	0	100	0							
110	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	61	16	16							
111	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	16	32	40							
112	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	0	0	0	0		617	Coal Shortage				
113	Khulna 330 MW CAPP (GT)	Gas/HSD (BDFB)	1x220	220	220	119	120	120	120							
**	Bheramara (HVDC)	India		1000	1000	899	899	906	906							
Khulna Zone Total						3125	3121	1363	1579	1567	1588	617	0			
114	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	64	16	110							
115	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	15	25	22	34							
116	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	132	132	132	132							
117	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	1060	1190	1244	1244							
118	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	136	17	150							
119	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	0	0	0	0		307	Coal Shortage				
120	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	222	220	220	220							
Barishal Zone Total						2265	2265	1462	1767	1651	1890	307	0			
121	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage				
122	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.				
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	35	0	35							
124	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0							
125	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	10	0	32							
126	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	92	50	90							
127	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	22	39	36	35							
128	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	25	34	34							
129	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	30	30	20	33							
130	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0		210	Gas Shortage				
131	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	140	170	214	220			HSD				
132	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	141	140	160	181		79	Gas Shortage				
133	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	330	349	414	414		84	Gas Shortage				
134	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	0	0	0	0	0							
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8							
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	8	8							
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	56	95	113	113							
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	50	110	113	113							
139	Ammura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	21	21							
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	2	0	6	0							
**	Adani Power Jharkhanda Ltd	Coal (Import)	2x748	1496	1496	1142	1211	1200	1200							
Rajshahi Zone Total						3675	3631	1921	2322	2397	2537	444	100			
140	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage				
141	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling				
141	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	210	220	230		64	Coal Shortage				
142	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0							
143	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	70	105	105	105							
144	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0							
145	Majma. Talsia 9 MW Solar PP (Syma Power)	Solar (IPP)	1 x 9	9	9	0	0	8	0							
146	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6*20	115	115	75	115	115	115							
147	Lalmoharhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	29	0	30	0							
148	Teesa Solar Limited	Solar (IPP)	1 x 200	200	200	88	0	130	0							
Rangpur Zone Total						1030	950	462	430	608	450	149	85			
Sub-total: Plants in operation						24602	24171	12196.0	14373	13675	15448	2628	1692			
(B) Plants under long term maintenance/ contract expired																
149	Jamelpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0							
150	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0							
151	Bosilla 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0							
152	Ashugani 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	0	0	0	0							
Sub-Total: Plants under long term maintenance/ contract expired						309	0	0	0	0	0	0	0			
Gross Total						24911	24171	12196	14373	13675	15448	2628	1692			
(C) Actual data of 02.08.23 (Yesterday) Wednesday :																
01.	Max. Demand at eve. peak (Generation end)	:	14600 MW, at =	20:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :										
02.	Max. Demand at eve. peak (Sub-station end)	:	13953 MW, at =	20:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed				
03.	Highest Generation (Generation end)	:	14373 MW, at =	20:00 hrs	Dhaka	4915	4915	0	Mymensingh	1196	1091	105				
04.	Minimum Generation (Generation end)	:	11306 MW, at =	7:00 hrs	Chattogram	1359	1359	0	Sylhet	605	543	62				
05.	Day-peak Generation (Generation end)	:	12196 MW, at =	12:00 hrs	Khulna	1629	1629	0	Barishal	411	411	0				
06.	Evening-peak Generation (Generation end)	:	14373 MW, at =	20:00 hrs	Rajshahi	1528	1508	20	Rangpur	1002	1002	0				
07.	Evening Peak Load-shed (Sub-station end)	:	217 MW, at =	20:00 hrs	Cumilla	1308	1278	30								
08.	Minimum Generation Forecast up to 8:00 hrs.	:	11412 MW, at =	5:00 hrs					Total	13953	13736	217				
09.	Generation shortfall at evening peak due to :	:														
	a) Gas/LF limitation	:	2379 MW													
	d) Coal supply Limitation	:	149 MW													
	b) Low water level in Kaptai lake	:	100 MW													
	c) Plants under shut down/ maintenance	:	1692 MW													
10.	Total Energy (Generation + India Import)	:	300.18 MMCFD													
	By Gas =	142.213 MKWH	By Oil =	65.557 MKWH												
	By Coal =	62.394 MKWH	By Hydro =	2.999 MKWH												
	By Solar=	1.879 MKWH														
11.	Total Gas Supplied	:	1174.50 MMCFD													
(D) Forecast of 03.08.23 (Today) Thursday :																
01.	Maximum Demand	:	14500 MW (Generation end)		04.	Maximum Load-shed	:	0 MW	At evening peak (Sub-station end)							
02.	Maximum Generation	:	15448 MW (Generation end)		05.	Total Generation	:	302.83 MKWh								
03.	Reserve / Shortage	:	948 MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	:	30.5° C								

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21