

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564657, 9551095

Month August, 2023					Day : Friday				Date : 04.08.23					
Probable Maximum Demand : 14200 MW					Probable Maximum Generation : 15162 MW									
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 79.13 ft	Today = 79.53 ft				Rule Curve = 89.96 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	03.08.23 (Yesterday)		04.08.23 (Today)		03.08.23 (Yesterday)		04.08.23 (Today)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Oil/Water Limitation MW		Machines shut down (MW)			
					Day	Evening	Day	Evening			Description/ Remarks	Probable start-up date		
(A) Plants in operation:														
1	Ghorasal Repowered CAPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0			260	Under project work	
2	a) Ghorasal Repowered CAPP Unit-4	Gas (PDB)	1 x 210	210	180	192	185	180	180					
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180					
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0					
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	12	12	12	12	96			Gas Shortage	
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105			Gas Shortage	
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0					
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	332	336	325	330					
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450					
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0			115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	401	399	400	400					
11	Siddhirganj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	186	197	190	190					
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	325	333	330	330					
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0			115	Under maint.	
14	Madangan-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	30	15	15					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	42	102	102	102					
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	17	20	17	17					
17	Summit Power, (Madhabdi-Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	33	36	39	41					
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33					
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	24	24	33	33					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	25	8	25					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	35	105	35	105					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	64	130	64	130					
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	35	17	34					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	77	98	96	96					
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	82	149	35	149					
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	145	0	0	150					
27	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	35	35	35					
28	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	35	35					
29	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	50	72	53	72					
30	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	54	90	54	108					
31	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	27	0	35	0					
32	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	17					
33	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	32	50	55	55					
34	Meghnaghat 100 MW(EL)	HFO (NENP)	12x8.9	100	100	43	50	42	50					
35	Madangan 102 PP(Summit)	HFO (NENP)	6x17	102	102	17	17	17	17					
36	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	31	68	75	75					
Dhaka Zone Total				5904	5722	3011	3313	2979	3466	201	490			
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	70	104	100	100	126			Low water level	
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	118	117	120	120	63			Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0			180	Under maint.	
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	1	0	5	0					
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	25	8	25					
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	7	0	20	0					
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	46	6	46					
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	51	34	17	17					
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150			Under maint.	
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	219	227	225	225					
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	125	281	120	300					
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	86	85	85					
48	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	50	50	50	50					
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	16	50	25	40					
50	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	12	12	12	12					
*	Malancha, Cig EPZ (United)	Gas	5x8.73+3x9.34			2	30	30	30					
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	17	37	12	50					
52	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	36	17	17					
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	55	55	55	55					
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	38	88	38	88					
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRRP)	8x13.45	100	100	70	80	70	80					
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	34	51	34	51					
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	53	142	54	144					
	SS Power Unit-1	Coal (IPP)				0	0	0	0					
	Matarbari 2*600 MW (CPGCL)	Coal				0	0	0	0				Test run	
	Cox's Bazar Wind PP	(Wind) (IPP)				0	20	22	22					
Chattogram Zone Total				2605	2545	994	1571	1125	1557	189	330			
58	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	0	0	0	0	45			Gas Shortage	
59	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	167	178	170	180					
60	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	220	220	260	260	140			Gas Shortage	
61	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	260	260	280	280	100			Gas Shortage	
62	Ashuganj 420 MW CCPP(East)	Gas (APSCL)	1x284+1x116	400	400	230	230	230	230	170			Gas Shortage	
63	Ashuganj 195MW PP (APSC-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	0	0	187			Gas Shortage	
64	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	43	43	43					
65	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	5	65	6	60					
66	Titlas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	24	24	25	25					
67	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163			Under maint.	
68	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	70	152	68	155					
69	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	19	20	20					
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11					
71	Jangalia 33 MW PP (Summit))	Gas (SIPP, PDB)	4x8.73	33	33	33	33	32	33					
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	25	43	43	43					
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	20	20	20					
74	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	106	106	17	106					
75	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	0	56	9	56					
76	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17					
77	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	71	114	72	115					
**	Import (Tirupura)	India		160	160	122	148	146	163					
Cumilla Zone Total				2904	2896	1448	1747	1469	1817	642	163			
78	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	31	82	35	85	120			Gas Shortage	
79	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	14	17	18	18					
80	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	19	85	18	85					
81	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	68	88	68	85					
82	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0					
83	Suliakhali 50 MW Solar PP	Solar (IPP)	1x50	50	50	9	0	50	0					
84	Tangail 22 MW PP(MPGL)	HFO (IPP)	4x6.7	22	22	6	0	6	6					
Mymensingh Zone Total				622	614	148	272	197	279	120	0			

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	03.08.23 (Yesterday)		04.08.23 (Today)		03.08.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)		
85	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	43	43	43		27	GT-1 Under maint.	
86	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	30	30	30			Under maint.	
87	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	47	45	50	50				
88	Kushiera 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	112	112		54	ST Under maint.	
89	Hobigari 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11				
90	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	25	28	30	30				
91	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
92	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	75	86	80	86				
93	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	112	112	80	220				
94	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	17	17	17	17				
95	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10				
96	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	24	24	24	24				
97	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	305	285	300	300				
98	Bibiya-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	402	402	400	400				
99	Bibiya South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	355	326	355	355				
100	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
101	Fenchuganji 44MW (Energyprima)	Gas (NENP)	12*3.4+5*2	50	50	40	48	48	48				
Sylhet Zone Total						2472	2427	1591	1576	1590	1736	0	511
102	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
103	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	100	150	150	150		260	Gas Shortage	
104	Fairdipor 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	25	0	41				
105	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	22	60	40	67				
106	Khulna 225 MW CAPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	115	115	120	120				
107	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	35	35	35	35				
108	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	32	85	15	85				
109	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	58	0	100	0				
110	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	48	66	32	66				
111	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	8	8	32	40				
112	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	0	0	0	0		617	Coal Shortage	
113	Khulna 330 MW CAPP (GT)	Gas/HSD (BFDDB)	1x220	220	220	120	106	120	120				
**	Bheramara (HVDC)	India		1000	1000	889	894	924	924				
Khulna Zone Total						3125	3121	1427	1544	1568	1648	877	0
114	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	48	16	64				
115	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	19	33	22	34				
116	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	132	124	132	132				
117	Payra 1320 MW TTP	Coal (BCPCL)	2x622	1244	1244	1222	1244	1244	1244				
118	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	150	17	150				
119	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	0	0	0	0		307	Coal Shortage	
120	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	222	220	220	220				
Barishal Zone Total						2265	2265	1628	1819	1651	1844	307	0
121	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage	
122	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.	
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	35	0	35				
124	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
125	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	32	0	32				
126	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	92	50	90				
127	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	28	35	36	35				
128	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	34	42	42	42				
129	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	30	20	33				
130	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0		210	Gas Shortage	
131	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	216	180	200	220			HSD	
132	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	133	139	160	160		87	Gas Shortage	
133	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	282	414	414	414		132	Gas Shortage	
134	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	0	0	0	0				
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8				
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	8	8				
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	55	55	35	55				
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	94	35	50				
139	Ammura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	28	0	28	28				
139	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6	0				
**	Adani Power Jharkhanda Ltd	Coal (Import)	2x748	1496	1496	1214	1210	1200	1200				
Rajshahi Zone Total						3675	3631	2037	2374	2242	2410	500	100
140	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage	
141	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
141	Barapukuria 275 MW TTP Unit-3	Coal (PDB)	1 x 274	274	274	230	200	190	190		74	Coal Shortage	
142	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
143	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	34	92	35	100				
144	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
145	Majmaera, Talsia 9 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 9	9	9	5	0	8	0				
146	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6*20	119	115	36	115	35	115				
147	Lalmohini 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	22	0	30	0				
148	Teesa Solar Limited	Solar (IPP)	1 x 200	200	200	118	0	130	0				
Rangpur Zone Total						1030	950	445	407	428	405	159	85
Sub-total: Plants in operation						24602	24171	12729.0	14623	13249	15162	2995	1679
(B) Plants under long term maintenance/ contract expired													
149	Jamailpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
150	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
151	Bosilia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
152	Ashugani 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	0	0	0	0				
Sub-Total: Plants under long term maintenance/ contract expired						309	0	0	0	0	0	0	0
Gross Total						24911	24171	12729	14623	13249	15162	2995	1679
(C) Actual data of 03.08.23 (Yesterday) Thursday :													
01.	Max. Demand at eve. peak (Generation end)	:	14842 MW, at =	21:00 hrs	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :								
02.	Max. Demand at eve. peak (Sub-station end)	:	14133 MW, at =	21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW	
03.	Highest Generation (Generation end)	:	14623 MW, at =	21:00 hrs	Dhaka	4899	4889	10	Mymensingh	1217	1133	84	
04.	Minimum Generation (Generation end)	:	11412 MW, at =	8:00 hrs	Chattogram	1300	1300	0	Sylhet	593	546	47	
05.	Day-peak Generation (Generation end)	:	12729 MW, at =	12:00 hrs	Khulna	1749	1749	0	Barishal	439	439	0	
06.	Evening-peak Generation (Generation end)	:	14623 MW, at =	21:00 hrs	Rajshahi	1576	1528	48	Rangpur	1015	1015	0	
07.	Evening Peak Load-shed (Sub-station end)	:	209 MW, at =	21:00 hrs	Cumilla	1345	1325	20					
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10956 MW, at =	5:00 hrs									
09.	Generation shortfall at evening peak due to :	:			Total								
a)	Gas/LF limitation	:	2710 MW		Total								
d)	Coal supply Limitation	:	159 MW		Total =								
b)	Low water level in Kaptai lake	:	126 MW		Total =								
c)	Plants under shut down/ maintenance	:	1679 MW		Total =								
10.	Total Energy (Generation + India Import)	:	307.91 MKWh		Total =								
	By Gas =	147.940 MKWh	By Oil =	64.912 MKWh									
	By Coal =	65.390 MKWh	By Hydro =	2.200 MKWh									
	By Solar=	1.957 MKWh											
11.	Total Gas Supplied	:	1158.06 MMCFD										
(D) Forecast of 04.08.23 (Today) Friday :													
01.	Maximum Demand	:	14200 MW	(Generation end)	04.	Maximum Load-shed	:	0 MW	At evening peak (Sub-station end)				
02.	Maximum Generation	:	15162 MW	(Generation end)	05.	Total Generation	:	299.00 MKWh					
03.	Reserve / Shortage	:	962 MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	31.7° C					

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation