

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564657, 9551095

Month August, 2023				Day : Saturday				Date : 05.08.23					
Probable Maximum Demand : 14500 MW				Probable Maximum Generation : 14855 MW									
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 79.53 ft		Today = 80.57 ft		Rule Curve = 90.28 ft					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	04.08.23 (Yesterday)		05.08.23 (Today)		04.08.23 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)	Probable Peak Generation (MW)	Gen. shortfall for : Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date			
											Day	Evening	Day
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work		
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	140	210	160	180				
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180				
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0				
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	12	12	12	12	96	Gas Shortage		
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage		
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0				
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	332	342	325	340				
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	420	450	450	450				
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling		
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	357	393	390	393				
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	123	197	190	190				
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	328	331	330	330				
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	115	Under maint.		
14	Madangan-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	15	15				
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	25	102	102				
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	10	20	17	20				
17	Summit Power, (Madhabdi-Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	41	38	39	41				
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	25	25	25				
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	16	30	30	30				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	25	8	25				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	35	105	35	105				
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	64	130	64	130				
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	35	17	35				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	15	30	96	96				
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	35	116	35	116				
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	0	100				
27	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	35	35	35				
28	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	20	35	35	35				
29	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	25	72	53	72				
30	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	54	54	54	108				
31	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	10	0	35	0				
32	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	30	17	30				
33	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	9	32	55	55				
34	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	0	9	42	50				
35	Madangan 102 PP(Summit)	HFO (NENP)	6x17	102	102	17	12	17	50				
36	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	57	60	60				
Dhaka Zone Total			5904	5722	2324	3045	2923	3410	201	490			
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	106	104	100	104	126	Low water level		
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	116	115	120	120	65	Gas Shortage		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.		
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	1	0	5	0				
40	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	25	8	25				
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	11	0	20	0				
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	6	6	45				
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	17	17	17				
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.		
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	224	222	225	225				
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	66	100	120	300				
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	86	85	85				
48	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	34	49	50	50				
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	25	50	25	50				
50	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	12	11	12	12				
*	Malancha, Cig EPZ (United)	Gas	5x8.73+3x9.34			16	38	10	25				
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	37	12	37				
52	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17				
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	42	54	55	55				
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	32	25	38	88				
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRRP)	8x13.45	100	100	12	25	70	80				
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	34	34	34	34				
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	43	17	54	144				
	SS Power Unit-1	Coal (IPP)				0	0	0	0				
	Matarbari 2*600 MW (CPGCL)	Coal				150	150	0	0		Test run		
	Cox's Bazar Wind PP	(Wind) (IPP)				22	7	22	22				
Chattogram Zone Total			2605	2545	1013	1189	1105	1535	191	330			
58	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	0	0	0	0	45	Gas Shortage		
59	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	168	185	180	180				
60	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	240	230	230	230	130	Gas Shortage		
61	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	275	270	270	270	90	Gas Shortage		
62	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	230	220	230	230	180	Gas Shortage		
63	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*116	195	195	0	0	0	0	195	Gas Shortage		
64	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	43	43	43				
65	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	5	60	6	60				
66	Titlas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	25	25	25	25				
67	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under maint.		
68	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	70	100	68	150				
69	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	20	22				
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	6	11	11	11				
71	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	32	33				
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	8	8	42				
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	21	20	21				
74	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	34	17	17				
75	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	59	9	60				
76	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17				
77	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	46	112	72	115				
**	Import (Tirupura)	India		160	160	132	154	146	160				
Cumilla Zone Total			2904	2896	1338	1601	1404	1686	640	163			
78	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	33	83	35	85	119	Gas Shortage		
79	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	17	17	17				
80	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	19	85	18	85				
81	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	68	88	68	88				
82	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0				
83	Sulakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	11	0	50	0				
84	Tangail 22 MW PP(PPLGL)	HFO (IPP)	4x6.7	22	22	6	6	6	6				
Mymensingh Zone Total			622	614	156	279	196	281	119	0			

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	04.08.23 (Yesterday)		05.08.23 (Today)		04.08.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)		
85	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.	
86	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	20	40	40	40		50	GT-4 Under maint.	
87	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	47	50	50	50				
88	Kushiera 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	112	112		54	ST Under maint.	
89	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8				
90	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	25	25	30	30				
91	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
92	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	78	86	80	86				
93	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	65	130	80	130				
94	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	17	17	17	17				
95	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
96	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	24	24	24				
97	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	295	295	300	300				
98	Bibiana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	366	403	400	400				
99	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	355	355	355	355				
100	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
101	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.4+5*2	50	50	46	46	48	48				
Sylhet Zone Total						2472	2427	1503	1644	1597	1653	0	561
102	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
103	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	100	270	200	250		140	Gas Shortage	
104	Fairdipor 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	40				
105	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	40	70				
106	Khulna 225 MW CCPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	115	115	120	120				
107	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	35	35	35				
108	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	5	15	15	85				
109	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	36	0	100	0				
110	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	5	16	32	66				
111	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	8	8	8	8				
112	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	0	0	0	0		617	Coal Shortage	
113	Khulna 330 MW CCPP (GT)	Gas/HSD (BFDDB)	1x220	220	220	105	105	120	120				
**	Bheramara (HVDC)	India		1000	1000	905	851	910	910				
Khulna Zone Total						3125	3121	1279	1415	1580	1704	757	0
114	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	16	64				
115	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	20	30	22	30				
116	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	132	132	132	132				
117	Payra 1320 MW TTP	Coal (BCPCL)	2x622	1244	1244	1244	1244	1244	1244				
118	Potukhalhi 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	17	17	150				
119	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	0	0	0	0		307	Coal Shortage	
120	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	225	220	220	220				
Barishal Zone Total						2265	2265	1621	1659	1651	1840	307	0
121	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage	
122	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.	
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	0				
124	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
125	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	16	0	30				
126	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	92	50	92				
127	Katakhal 50 MW Peaking PP	HFO (QRPP)	6x8.9	50	50	0	8	42	42				
128	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	30	20	30				
129	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	0	0	0	0		210	Gas Shortage	
130	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	140	140	200	220			HSD	
131	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	170	158	160	160		50	Gas Shortage	
132	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	320	414	414	414		94	Gas Shortage	
133	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	0	0	0	0				
134	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8				
135	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	8	8				
136	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	55	35	55				
137	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	50	35	50				
138	Amnura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	0	0				
139	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	1	0	6	0				
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	1211	1209	1200	1200				
Rajshahi Zone Total						3675	3631	1920	2218	2208	2339	425	100
140	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage	
141	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
142	Barapukuria 275 MW TTP Unit-3	Coal (PDB)	1 x 274	274	274	200	200	200	200		74	Coal Shortage	
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	34	70	35	92				
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Mapara Taluk 9 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 9	9	9	1	0	8	0				
147	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	75	35	115				
148	Lalmoharhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	32	0	30	0				
149	Teesa Solar Limited	Solar (IPP)	1 x 200	200	200	205	0	130	0				
Rangpur Zone Total						1030	950	472	345	438	407	159	85
Sub-total: Plants in operation						24602	24171	11626.0	13395	13102	14855	2799	1729
(B) Plants under long term maintenance/ contract expired													
150	Jamailpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
151	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
152	Bosilia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
153	Ashugani 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	0	0	0	0				
Sub-Total: Plants under long term maintenance/ contract expired						309	0	0	0	0	0	0	0
Gross Total						24911	24171	11626	13395	13102	14855	2799	1729
(C) Actual data of 04.08.23 (Yesterday) Friday :													
01.	Max. Demand at eve. peak (Generation end)	:	13395 MW, at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :								
02.	Max. Demand at eve. peak (Sub-station end)	:	12804 MW, at =	21:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed	
03.	Highest Generation (Generation end)	:	13554 MW, at =	23:00 hrs		MW	MW	MW		MW	MW	MW	
04.	Minimum Generation (Generation end)	:	10838 MW, at =	9:00 hrs	Dhaka	4210	4210	0	Mymensingh	1129	1129	0	
05.	Day-peak Generation (Generation end)	:	11626 MW, at =	12:00 hrs	Chattogram	1241	1241	0	Sylhet	545	545	0	
06.	Evening-peak Generation (Generation end)	:	13395 MW, at =	21:00 hrs	Khulna	1620	1620	0	Barishal	408	408	0	
07.	Evening Peak Load-shed (Sub-station end)	:	0 MW, at =	21:00 hrs	Rajshahi	1539	1539	0	Rangpur	877	877	0	
08.	Minimum Generation Forecast up to 8:00 hrs.	:	11130 MW, at =	5:00 hrs	Cumilla	1236	1236	0					
09.	Generation shortfall at evening peak due to :	:			Total								
a) Gas/LF limitation	:	2514 MW			Total								
b) Coal supply Limitation	:	159 MW			Total =								
c) Low water level in Kaptai lake	:	126 MW			Total =								
d) Plants under shut down/ maintenance	:	1729 MW			Total =								
10.	Total Energy (Generation + India Import)	:	285.30 MKWh		Total =								
	By Gas = 144.645 MKWh		By Oil = 47.566 MKWh		Total =								
	By Coal = 65.058 MKWh		By Hydro = 0.901 MKWh		Total =								
	By Solar= 2.028 MKWh				Total =								
11.	Total Gas Supplied	:	1125.55 MMCFD		Total =								
(D) Forecast of 05.08.23 (Today) Saturday :													
01.	Maximum Demand	:	14500 MW (Generation end)		04.	Maximum Load-shed	:	0 MW	At evening peak (Sub-station end)				
02.	Maximum Generation	:	14855 MW (Generation end)		05.	Total Generation	:	305.21 MKWh					
03.	Reserve / Shortage	:	355 MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	:	31.8° C					

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation