

Bangladesh Power Development Board
DAY1 ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564657, 9551095

Month August, 2023				Day : Sunday				Date : 06.08.23						
Probable Maximum Demand : 14500 MW				Probable Maximum Generation : 14542 MW										
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 80.57 ft		Today = 82.62 ft		Rule Curve = 90.60 ft.						
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	05.08.23 (Yesterday)		06.08.23 (Today)		05.08.23 (Yesterday)		Status of Machines under shut-down/ Maintenance			
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Machines shut down (MW)		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening						
(A) Plants in operation:														
1	Ghorasal Repowered CAPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work		
2	a) Ghorasal Repowered CAPP Unit-4	Gas (PDB)	1 x 210	210	180	190	210	210	210					
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180					
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0					
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	12	12	12	12	96		Gas Shortage		
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage		
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0					
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	326	332	320	330					
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450					
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling		
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	398	396	390	393					
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	181	195	190	190					
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	314	329	330	330					
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0		115	Under maint.		
14	Madangan-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	15	15					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	33	32	74					
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	18	18	20					
17	Summit Power, Madhabdi-Ashulia	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	29	33	39	41					
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33					
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	22	22	30	30					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	16	25	8	25					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	105	35	105					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	64	130	64	130					
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	35	17	35					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	47	97	50	100					
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	34	114	35	116					
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	51	13	0	100					
27	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	35	35	35					
28	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	35	35					
29	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	35	53	35	54					
30	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	54	108	54	108					
31	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	10	0	35	0					
32	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	17	17	17					
33	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	12	50	55	55					
34	Meghnaghat 100 MW(EL)	HFO (NENP)	12x8.9	100	100	2	25	50	50					
35	Madangan 102 PP(Summit)	HFO (NENP)	6x17	102	102	17	49	17	50					
36	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	12	43	50	50					
Dhaka Zone Total				5904	5722	2583	3192	2841	3373	201	490			
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	140	134	131	131	96		Low water level		
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	111	120	120	120	60		Gas Shortage		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.		
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	1	0	5	0					
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	25	8	25					
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	7	0	20	0					
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	45	6	45					
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	17	17	17					
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.		
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	226	227	225	225					
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	94	257	66	300					
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	100	85	100					
48	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	34	50	50	50					
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	17	16	16	16					
50	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	12	12	12	12					
*	Malancha, Cig EPZ (United)	Gas	5x8.73+3x9.34			5	16	7	25					
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	17	37	12	37					
52	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	36	17	17					
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	55	55	55	55					
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	38	88	38	88					
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRRP)	8x13.45	100	100	80	80	80	80					
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	18	34	34	34					
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	53	125	54	144					
	SS Power Unit-1	Coal (IPP)				0	0	0	0					
	Matarbari 2*600 MW (CPGCL)	Coal				150	0	0	0			Test run		
	Cox's Bazar Wind PP	(Wind) (IPP)				26	23	22	22					
Chattogram Zone Total				2605	2545	1157	1497	1080	1543	156	330			
58	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	0	0	0	0	45		Gas Shortage		
59	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	198	193	180	190					
60	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	240	240	230	230	120		Gas Shortage		
61	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	270	270	300	300	90		Gas Shortage		
62	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	220	230	220	220	170		Gas Shortage		
63	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*116	195	195	0	8	0	0	187		Gas Shortage		
64	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	51	51					
65	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	5	58	6	60					
66	Titlas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	50	50	25	25					
67	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163	Under maint.		
68	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	67	157	68	150					
69	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	18	20	22					
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11					
71	Jangalia 33 MW PP (Summit))	Gas (SIPP, PDB)	4x8.73	33	33	25	33	33	33					
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	34	34	8	42					
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	20	20	21					
74	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	17	17	17					
75	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	57	9	60					
76	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17					
77	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	72	114	72	115					
**	Import (Tirupura)	India		160	160	154	160	146	163					
Cumilla Zone Total				2904	2896	1468	1738	1433	1727	612	163			
78	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	33	81	40	80	121		Gas Shortage		
79	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	17	17	17					
80	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	18	74	18	85					
81	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	65	96	68	88					
82	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0					
83	Sulakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	19	0	50	0					
84	Tangail 22 MW PP(PPLG)	HFO (IPP)	4x6.7	22	22	6	6	6	6					
Mymensingh Zone Total				622	614	160	274	201	276	121	0			

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	05.08.23 (Yesterday)		06.08.23 (Today)		05.08.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)		
85	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43	27	GT-1 Under maint.		
86	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	40	40	40	40	50	GT-4 Under maint.		
87	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	45	50	50	50				
88	Kushiera 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	0	0	0	54	ST Under maint.		
89	Hobigunj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	8	8				
90	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	28	25	30	30				
91	Shajibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	330	Under maint.		
92	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	75	86	80	86				
93	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	179	180	180	180				
94	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	17	17	17	17				
95	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
96	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	24	24	24	24				
97	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	310	270	300	300				
98	Bibiyan-IIII 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	368	402	400	400				
99	Bibiyan South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	355	347	355	355				
100	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0	100	Under project work		
101	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.4+5*2	50	50	42	45	45	45				
Sylhet Zone Total						2472	2427	1659	1550	1582	1588	0	561
102	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
103	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	125	95	130	120	315	Gas Shortage		
104	Fairdipor 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	21	0	40				
105	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	52	40	70				
106	Khulna 225 MW CCPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	115	115	120	120				
107	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	17	17	17				
108	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	15	85	15	85				
109	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	10	0	100	0				
110	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	21	48	32	66				
111	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	8	8	8	8				
112	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	0	0	0	0	617	Coal Shortage		
113	Khulna 330 MW CCPP (GT)	Gas/HSD (BFDDB)	1x220	220	220	105	106	120	120				
**	Bheramara (HVDC)	India		1000	1000	891	823	911	911				
Khulna Zone Total						3125	3121	1307	1370	1493	1557	932	0
114	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	110	16	64				
115	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	19	30	22	30				
116	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	132	132	132	132				
117	Payra 1320 MW TTP	Coal (BCPCL)	2x622	1244	1244	1244	1244	1244	1244				
118	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	133	17	150				
119	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	0	0	0	0	307	Coal Shortage		
120	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	223	220	220				
Barishal Zone Total						2265	2265	1648	1872	1651	1840	307	0
121	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage		
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Under maint.		
122	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	0				
123	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
124	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	22	0	30				
125	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	28	92	50	92				
126	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	30	30				
127	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	25	0	0	0				
128	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	30	20	30				
129	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	0	0	0	0	210	Gas Shortage		
130	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	150	195	200	220		HSD		
131	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	144	145	150	150	76	Gas Shortage		
132	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	360	338	380	380	54	Gas Shortage		
133	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	0	0	0	0	0				
134	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8				
135	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	8	8				
136	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	55	35	55				
137	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	50	35	50				
138	Amnura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	0	0				
139	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	3	0	6	0	0				
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	1210	1197	1200	1200				
Rajshahi Zone Total						3675	3631	1998	2172	2122	2253	411	100
140	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Coal Shortage		
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overhauling		
141	Barapukuria 275 MW TTP Unit-3	Coal (PDB)	1 x 274	274	274	180	200	200	200	74	Coal Shortage		
142	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
143	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	35	70	35	70				
144	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
145	Majma. Talsia 9 MW Solar PP (Syma Power)	Solar (IPP)	1 x 9	9	4	0	8	0	0				
146	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6*20	119	115	0	114	35	115				
147	Lalmoharhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	26	0	30	0				
148	Teesa Solar Limited	Solar (IPP)	1 x 200	200	200	170	0	130	0				
Rangpur Zone Total						1030	950	415	384	438	385	159	85
Sub-total: Plants in operation						24602	24171	12395.0	14049	12841	14542	2899	1729
(B) Plants under long term maintenance/ contract expired													
149	Jamailpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
150	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
151	Bosilia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
152	Ashugani 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	0	0	0	0				
Sub-Total: Plants under long term maintenance/ contract expired						309	0	0	0	0	0	0	0
Gross Total						24911	24171	12395	14049	12841	14542	2899	1729
(C) Actual data of 05.08.23 (Yesterday) Saturday :													
01.	Max. Demand at eve. peak (Generation end)	:	14217 MW, at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :								
02.	Max. Demand at eve. peak (Sub-station end)	:	13624 MW, at =	21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW	
03.	Highest Generation (Generation end)	:	14049 MW, at =	21:00 hrs	Dhaka	4788	4773	15	Mymensingh	1155	1080	75	
04.	Minimum Generation (Generation end)	:	11130 MW, at =	7:00 hrs	Chatogram	1189	1189	0	Sylhet	576	576	0	
05.	Day-peak Generation (Generation end)	:	12395 MW, at =	12:00 hrs	Khulna	1709	1709	0	Barishal	415	415	0	
06.	Evening-peak Generation (Generation end)	:	14049 MW, at =	21:00 hrs	Rajshahi	1501	1468	33	Rangpur	997	975	22	
07.	Evening Peak Load-shed (Sub-station end)	:	160 MW, at =	21:00 hrs	Cumilla	1294	1279	15					
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10988 MW, at =	5:00 hrs					Total	13624	13464	160	
09.	Generation shortfall at evening peak due to :	:											
	a) Gas/LF limitation	:	2644 MW										
	d) Coal supply Limitation	:	159 MW										
	b) Low water level in Kaptai lake	:	96 MW										
	c) Plants under shut down/ maintenance	:	1729 MW										
10.	Total Energy (Generation + India Import)	:	298.48 MWh										
	By Gas = 148.573 MKWH	By Oil =	54.169 MKWH										
	By Coal = 65.675 MKWH	By Hydro =	2.888 MKWH										
	By Solar= 1.785 MKWH												
11.	Total Gas Supplied	:	1138.84 MMCFD										
(D) Forecast of 06.08.23 (Today) Sunday :													
01.	Maximum Demand	:	14500 MW (Generation end)		04.	Maximum Load-shed	:	0 MW	At evening peak (Sub-station end)				
02.	Maximum Generation	:	14542 MW (Generation end)		05.	Total Generation	:	308.06 MKWh					
03.	Reserve / Shortage	:	42 MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	:	32.8° C					

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation