

Bangladesh Power Development Board
DAY1 ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564657, 9551095

Month August, 2023				Day : Monday				Date : 07.08.23					
Probable Maximum Demand : 14000 MW				Probable Maximum Generation : 15141 MW									
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 82.62 ft		Today = 85.70 ft		Rule Curve = 90.92 ft					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	06.08.23 (Yesterday)		07.08.23 (Today)		06.08.23 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)	Probable Peak Generation (MW)	Probable Peak Generation (MW)	Gen. shortfall for : Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date		
												Day	Evening
(A) Plants in operation:													
1	Ghorasal Repowered CAPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work		
2	a) Ghorasal Repowered CAPP Unit-4	Gas (PDB)	1 x 210	210	180	150	180	180	180				
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180				
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0				
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	12	12	12	12	96	Gas Shortage		
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage		
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0				
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	337	342	330	330				
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	420	450	450	450				
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling		
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	397	351	400	400				
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	190	119	190	190				
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	330	330	330	330				
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	115	Under maint.		
14	Madangan-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	15	30				
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	24	50	24	48				
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	18	18	18	20				
17	Summit Power, (Madhabdi-Ashulia)	Gas (SIPP, REB)	6x3.67+3x8.73	80	80	33	39	39	41				
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	25	33	33				
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	22	26	30	30				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	25	8	25				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	35	72	35	88				
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	64	148	64	149				
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	35	17	35				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	47	97	45	95				
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	35	134	35	149				
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	0	150				
27	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	35	35	35				
28	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	35	35				
29	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	28	36	35	54				
30	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	54	108	54	108				
31	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	6	0	35	0				
32	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	17				
33	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	40	48	40	40				
34	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	0	49	50	50				
35	Madangan 102 PP(Summit)	HFO (NENP)	6x17	102	102	17	34	17	17				
36	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	45	58	56	56				
Dhaka Zone Total				5904	5722	2609	3068	2809	3377	201	490		
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	118	0	105	105			Cleaning works ongoing	
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	115	115	115	115	65	Gas Shortage		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.		
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	0	0	5	0				
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	8	8	25				
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	3	0	20	0				
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	40	6	47				
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	19	34	34	34				
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.		
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	223	227	225	225				
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	66	170	66	300				
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	40	25	88				
48	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	50	50	50				
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	16	8	24	24				
50	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	12	12	12	12				
*	Malancha, Cig EPZ (United)	Gas	5x8.73+3x9.34			2	18	5	25				
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	11	25	12	95				
52	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17				
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	72	55	51	51				
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	38	25	25	88				
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRRP)	8x13.45	100	100	46	24	46	70				
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	34	34	34	34				
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	53	53	53	144				
	SS Power Unit-1	Coal (IPP)				0	144	400	400				
	Matarbari 2*600 MW (CPGCL)	Coal				0	0	0	0		Test run		
	Cox's Bazar Wind PP	(Wind) (IPP)				16	17	22	22				
Chattogram Zone Total				2605	2545	900	1116	1360	1971	65	330		
58	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	0	0	0	0	45	Gas Shortage		
59	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	199	207	180	200				
60	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	230	230	230	230	130	Gas Shortage		
61	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	270	270	300	300	90	Gas Shortage		
62	Ashuganj 420 MW CCPP(East)	Gas (APSCL)	1x284+1x116	400	400	230	230	220	220	170	Gas Shortage		
63	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	0	0	187	Gas Shortage		
64	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	51	51				
65	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	5	23	6	30				
66	Titlas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	26	24	25	25				
67	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under maint.		
68	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	68	156	68	155				
69	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	20	22				
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	11	11	11				
71	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	33	33	33				
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	34	8	42				
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	20	20	21				
74	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	34	34	34				
75	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	57	9	60				
76	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	35	17	35				
77	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	72	113	72	115				
**	Import (Tirupura)	India		160	160	132	154	146	163				
Cumilla Zone Total				2904	2896	1398	1709	1450	1747	622	163		
78	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	31	73	40	70	129	Gas Shortage		
79	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	17	17	17				
80	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	28	84	18	85				
81	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	68	88	68	88				
82	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0				
83	Sulakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	24	0	50	0				
84	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	6	6	6	6				
Mymensingh Zone Total				622	614	175	268	201	266	129	0		

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	06.08.23 (Yesterday)		07.08.23 (Today)		06.08.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Machines shut down (MW)			
85	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43	27	GT-1 Under maint.	
86	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	40	40	40	40	50	GT-4 Under maint.	
87	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	47	50	50	50			
88	Kushiera 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	10	112	112	54	ST Under maint.	
89	Hobgiri 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11			
90	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	25	20	20	20			
91	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	330	Under maint.	
92	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	78	86	80	86			
93	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	182	182	180	180			
94	Sylhet 20 MW GTTP	Gas (PDB)	1x 20	20	20	17	17	17	17			
95	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10			
96	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	24	24	24	24			
97	Bibiya-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	280	300	300			
98	Bibiya-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	384	367	400	400			
99	Bibiya South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	355	355	355	355			
100	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0	100	Under project work	
101	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.4+5*2	50	50	46	43	45	45			
Sylhet Zone Total					2472	2427	1562	1538	1687	1693	0	561
102	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
103	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	100	80	130	130	330	Gas Shortage	
104	Fairdipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	19	0	40			
105	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	58	40	70			
106	Khulna 225 MW CCPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	115	115	115	115			
107	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	4	17	17	17			
108	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	11	85	15	85			
109	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	8	0	100	0			
110	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	3	71	32	66			
111	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	8	8	8			
112	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	0	0	0	0	617	Coal Shortage	
113	Khulna 330 MW CCPP (GT)	Gas/HSD (BDFD)	1x220	220	220	104	105	120	120			
**	Bheramara (HVDC)	India		1000	1000	893	889	912	912			
Khulna Zone Total					3125	3121	1238	1447	1489	1563	947	0
114	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	96	16	110			
115	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	18	27	22	30			
116	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	132	130	132	132			
117	Payra 1320 MW TTP	Coal (BCPCL)	2x622	1244	1244	1244	1244	1244	1244			
118	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	150	17	150			
119	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	0	0	0	0	307	Coal Shortage	
120	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	223	220	220			
Barishal Zone Total					2265	2265	1631	1870	1651	1886	307	0
121	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage	
122	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Under maint.	
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	35	0	0			
124	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0			
125	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	19	0	30			
126	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	7	92	50	92			
127	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	39	30	30			
128	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	0			
129	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	0	30			
130	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	0	0	0	0	210	Gas Shortage	
131	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	140	150	200	220		HSD	
132	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	147	143	150	150	73	Gas Shortage	
133	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	363	330	380	380	51	Gas Shortage	
134	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	0	0	0	0	0			
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8			
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	0	8			
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	55	35	55			
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	50	35	50			
139	Amnura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	0	0			
140	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	3	0	6	0	0			
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	1194	1210	1200	1200			
Rajshahi Zone Total					3675	3631	1932	2171	2094	2253	405	100
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Coal Shortage	
142	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overhauling	
143	Barapukuria 275 MW TTP Unit-3	Coal (PDB)	1 x 274	274	274	180	170	200	200	104	Coal Shortage	
144	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	28	70	35	70			
146	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
147	Majma. Talsia 9 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 9	9	8	4	0	8	0			
148	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6*20	119	115	0	74	35	115			
149	Lalmoharhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	28	0	30	0			
150	Teesa Solar Limited	Solar (IPP)	1 x 200	200	200	101	0	130	0			
Rangpur Zone Total					1030	950	341	314	438	385	189	85
Sub-total: Plants in operation					24602	24171	11786.0	13501	13179	15141	2865	1729
(B) Plants under long term maintenance/ contract expired												
151	Jamailpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			
152	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			
153	Bosilia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			
154	Ashugani 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	0	0	0	0			
Sub-Total: Plants under long term maintenance/ contract expired					309	0	0	0	0	0	0	0
Gross Total					24911	24171	11786	13501	13179	15141	2865	1729
(C) Actual data of 06.08.23 (Yesterday) Sunday :												
01.	Max. Demand at eve. peak (Generation end)	:	13640 MW, at =	21:00 hrs	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	13140 MW, at =	21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	13501 MW, at =	21:00 hrs	Dhaka	4665	4640	25	Mymensingh	1122	1107	15
04.	Minimum Generation (Generation end)	:	10988 MW, at =	7:00 hrs	Chattogram	1139	1114	25	Sylhet	496	496	0
05.	Day-peak Generation (Generation end)	:	11786 MW, at =	12:00 hrs	Khulna	1638	1638	0	Barishal	400	400	0
06.	Evening-peak Generation (Generation end)	:	13501 MW, at =	21:00 hrs	Rajshahi	1484	1454	30	Rangpur	996	958	38
07.	Evening Peak Load-shed (Sub-station end)	:	133 MW, at =	21:00 hrs	Cumilla	1199	1199	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10104 MW, at =	5:00 hrs					Total	13140	13007	133
09.	Generation shortfall at evening peak due to :	:			13.	Fuel cost :	(a) Gas = 156994435 Taka (b) Oil = 626390314 Taka	(c) Coal = 307313251 Taka Total = 1090698001 Taka				
	a) Gas/LF limitation	:	2676 MW									
	d) Coal supply Limitation	:	189 MW									
	b) Low water level in Kaptai lake	:	0 MW									
	c) Plants under shut down/ maintenance	:	1729 MW									
10.	Total Energy (Generation + India Import)	:	287.79 MMWh		14.	Maximum Temperature in Dhaka was :	28.6° C					
	By Gas = 144.261 MKWH	By Oil =	48.713 MKWh		15.	Export through East-West interconnections :						
	By Coal = 66.153 MKWH	By Hydro =	2.120 MKWh			At evening peak-hour	:	11786 MW, at	21:00 hrs			
	By Solar= 1.052 MKWH					Maximum	:	770 MW, at	19:00 hrs			
						Energy	:	0 MKWh				
11.	Total Gas Supplied	:	1118.20 MMCFD		06.	Probable Max. Temperature in Dhaka :	28.6° C					
(D) Forecast of 07.08.23 (Today) Monday :												
01.	Maximum Demand	:	14000 MW (Generation end)		04.	Maximum Load-shed	:	0 MW	At evening peak (Sub-station end)			
02.	Maximum Generation	:	15141 MW (Generation end)		05.	Total Generation	:	298.43 MKWh				
03.	Reserve / Shortage	:	1141 MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	28.6° C					

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation