

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564657, 9551095

Month August, 2023						Day : Wednesday				Date : 09.08.23					
Probable Maximum Demand :						14200 MW		Probable Maximum Generation :						14777 MW	
Water Level of Kaptai Lake at 06:00 AM						Yesterday = 90.06 ft		Today = 94.37 ft		Rule Curve = 91.56 ft					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Dated/ Present Capacity (MW)	08.08.23 (Yesterday)		09.08.23 (Today)		08.08.23 (Yesterday)		09.08.23 (Today)		Status of Machines under shut-down/ Maintenance	Probable start-up date	
					Actual Peak Generation (MW)	Probable Peak Generation (MW)	Gen. shortfall for : Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)	Description/ Remarks						
										Day	Evening	Day			Evening
(A) Plants in operation:															
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0			260	Under project work		
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	170	200	180	180						
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180						
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0						
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	12	12	12	12			96	Gas Shortage		
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0			105	Gas Shortage		
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0						
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	336	303	300	320						
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	420	420	450	450						
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0			115	Under Overhauling		
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	383	399	400	400						
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	186	158	60	60						
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	322	280	330	330						
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0			115	Under maint.		
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	25	0	15						
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	58	20	48						
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	19	18	20						
17	Summit Power, (Madhabdi-Ashulia)	Gas (SIPP, REB)	6x3.67+3x8.73	80	80	41	40	39	41						
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25						
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	28	25	25	25						
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	25	8	25						
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	35	88	35	88						
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	147	64	149						
23	Kamalaghat 54 MW PP (Barco Energy)	HFO (IPP)	3x18.69	54	54	0	0	0	35						
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	97	45	95						
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	95	100	35	149						
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	0	150						
27	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	35	35	35						
28	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	35	35	35						
29	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	68	35	53						
30	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	54	162	54	162						
31	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	5	0	35	0						
32	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	34	17	34						
33	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	24	32	50						
34	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	0	33	50	50						
35	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	17	30	17	34						
36	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	0	56	60						
Dhaka Zone Total				5904	5722	2369	3022	2592	3310	201	490				
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	174	110	170	174						
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	115	115	115	115			65	Gas Shortage		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0			180	Under maint.		
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	1	0	5	0						
40	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	25	8	25						
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	3	0	20	0						
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	6	6	47						
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	17	34	51						
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0			150	Under maint.		
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	150	225						
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	30	210	66	300						
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	26	100	25	100						
48	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	0	50	50						
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	24	24	24						
50	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	10	10	12	12						
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			3	2	5	20						
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	55	12	95						
52	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	34						
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	34	17	51	51						
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	12	88	25	88						
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRRP)	8x13.45	100	100	0	46	46	80						
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	34	34	34	34						
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	0	143	53	144						
	SS Power Unit-1	Coal (IPP)				333	460	0	0						
	Matarbari 2*600 MW (CPGCL)	Coal				0	150	0	0				Test run		
	Cox's Bazar Wind PP	(Wind) (IPP)				7	6	22	22						
Chattogram Zone Total				2605	2545	822	1635	950	1691	65	330				
58	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	0	0	0	0			45	Gas Shortage		
59	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	157	171	180	180						
60	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	270	240	230	240			120	Gas Shortage		
61	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	300	280	300	300			80	Gas Shortage		
62	Ashuganj 420 MW CCPP(East)	Gas (APSCL)	1x284+1x116	400	400	250	230	230	230			170	Gas Shortage		
63	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	0	0	0	0			195	Gas Shortage		
64	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	51	51						
65	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	6	30	6	30						
66	Titlas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	23	48	40	48						
67	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0			163	Under maint.		
68	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	68	130	68	155						
69	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	18	20	22						
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	0	11	11						
71	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	33	33	33						
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	16	8	52	52						
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	14	14	14	14						
74	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	70	17	34						
75	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	4	28	9	28						
76	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17						
77	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	72	115	72	115						
**	Impoqot (Tripura)	India		160	160	118	144	146	163						
Cumilla Zone Total				2904	2896	1417	1627	1496	1723	610	163				
78	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	31	46	32	60			156	Gas Shortage		
79	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	16	17	17						
80	Jamailpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	19	83	18	85						
81	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	55	86	68	86						
82	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0						
83	Suliakhali 50 MW Solar PP	Solar (IPP)	1x50	50	50	16	0	50	0						
84	Tangail 22 MW PP(PPGCL)	HFO (IPP)	4x6.7	22	22	6	6	6	6			156	0		
Mymensingh Zone Total				622	614	144	237	193	254	156	0				

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	08.08.23 (Yesterday)		09.08.23 (Today)		08.08.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Machines shut down (MW)			
85	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43	27	GT-1 Under maint.	
86	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	41	42	42	42	48	GT-4 Under maint.	
87	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	42	47	50	50			
88	Kushiera 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	112	112	54	ST Under maint.	
89	Hobgiri 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11			
90	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	25	20	20	20			
91	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	330	Under maint.	
92	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	78	86	80	86			
93	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	182	182	180	180			
94	Sylhet 20 MW GTPP	Gas (PDB)	1x 20	20	20	17	17	17	17			
95	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10			
96	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	24	24	24	24			
97	Bibiya-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	255	280	280			
98	Bibiya-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	398	367	400	400			
99	Bibiya South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	355	355	355	355			
100	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0	100	Under project work	
101	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.4+5*2	50	50	49	47	45	47			
Sylhet Zone Total					2472	2427	1677	1618	1669	0	559	
102	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
103	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	140	115	150	150	295	Gas Shortage	
104	Fairdipor 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	40			
105	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	33	40	70			
106	Khulna 225 MW CAPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	115	115			
107	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	17	17	17			
108	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	67	15	105			
109	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	43	0	100	0			
110	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	64	60	98			
111	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	8	8	8			
112	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	0	0	0	0	617	Coal Shortage	
113	Khulna 330 MW CAPP (GT)	Gas/HSD (BDFB)	1x220	220	220	0	0	0	120			
**	Bheramara (HVDC)	India		1000	1000	904	862	922	922			
Khulna Zone Total					3125	3121	1087	1166	1427	1645	912	0
114	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	16	64			
115	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	20	27	22	30			
116	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	132	126	132	132			
117	Payra 1320 MW TWP	Coal (BCPCL)	2x622	1244	1244	960	1140	1244	1244			
118	Potukhal 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	100	17	150			
119	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	0	0	0	0	307	Coal Shortage	
120	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	219	220	220			
Barishal Zone Total					2265	2265	1332	1612	1651	1840	307	0
121	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage	
122	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Under maint.	
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	35	0	35			
124	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0			
125	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	4	0	30			
126	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	50	50	90			
127	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	36	30	36			
128	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	0			
129	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	27	0	30			
130	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210	Gas Shortage	
131	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	200	220	220	Gas Shortage	
132	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	160	147	150	150	60	Gas Shortage	
133	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	366	380	380			
134	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	0	0	0	0			
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	5	8	8			
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	0	8			
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	55	35	55			
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	50	35	50			
139	Amnura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	0	0			
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	1	0	6	0			
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	1210	1213	1200	1200			
Rajshahi Zone Total					3675	3631	1793	1996	2094	2292	561	100
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Coal Shortage	
142	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overhauling	
143	Barapukuria 275 MW TWP Unit-3	Coal (PDB)	1 x 274	274	274	220	180	200	200	94	Coal Shortage	
144	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	0	80	35	70			
146	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
147	Majma. Talsia 9 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 9	9	9	2	0	8	0			
148	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	80	35	75			
149	Lalmohini 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	24	0	30	0			
150	Teesa Solar Limited	Solar (IPP)	1 x 200	200	200	34	0	130	0			
Rangpur Zone Total					1030	950	280	340	438	345	179	85
Sub-total: Plants in operation					24602	24171	10921.0	13253	12510	14777	2991	1727
(B) Plants under long term maintenance/ contract expired												
151	Jamelpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			
152	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			
153	Bosilia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			
154	Ashugani 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	0	0	0	0			
Sub-Total: Plants under long term maintenance/ contract expired					309	0	0	0	0	0	0	0
Gross Total					24911	24171	10921	13253	12510	14777	2991	1727
(C) Actual data of 08.08.23 (Yesterday) Tuesday :												
01.	Max. Demand at eve. peak (Generation end)	:	13253 MW, at =	19:30 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	12587 MW, at =	19:30 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	13253 MW, at =	19:30 hrs	Dhaka	4653	4653	0	Mymensingh	1087	1087	0
04.	Minimum Generation (Generation end)	:	9525 MW, at =	7:00 hrs	Chattogram	981	981	0	Sylhet	509	509	0
05.	Day-peak Generation (Generation end)	:	10921 MW, at =	12:00 hrs	Khulna	1562	1562	0	Barishal	384	384	0
06.	Evening-peak Generation (Generation end)	:	13253 MW, at =	19:30 hrs	Rajshahi	1302	1302	0	Rangpur	896	896	0
07.	Evening Peak Load-shed (Sub-station end)	:	0 MW, at =	19:30 hrs	Cumilla	1214	1214	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10285 MW, at =	5:00 hrs					Total	12587	12587	0
09.	Generation shortfall at evening peak due to :	:			13.	Fuel cost :	(a) Gas = 155186100 Taka (b) Oil = 405404238 Taka	(c) Coal = 261618917 Taka Total = 822209255 Taka				
	a) Gas/LF limitation	:	2812 MW									
	d) Coal supply Limitation	:	179 MW									
	b) Low water level in Kaptai lake	:	0 MW									
	c) Plants under shut down/ maintenance	:	1727 MW		14.	Maximum Temperature in Dhaka was :	29.4° C					
10.	Total Energy (Generation + India Import)	:	272.32 MKWh		15.	Export through East-West interconnections :						
	By Gas = 141.915 MKWh	By Oil =	31.278 MKWh			At evening peak-hour	:	10921 MW, at	19:30 hrs			
	By Coal = 69.867 MKWh	By Hydro =	3.532 MKWh			Maximum	:	710 MW, at	6:00 hrs			
	By Solar= 1.014 MKWh					Energy	:	0 MKWh				
11.	Total Gas Supplied	:	1103.94 MMCFD									
(D) Forecast of 09.08.23 (Today) Wednesday :												
01.	Maximum Demand	:	14200 MW (Generation end)		04.	Maximum Load-shed	:	0 MW	At evening peak (Sub-station end)			
02.	Maximum Generation	:	14777 MW (Generation end)		05.	Total Generation	:	291.78 MKWh				
03.	Reserve / Shortage	:	577 MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	29.4° C					

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation