

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564657, 9551095

Month August, 2023					Day : Thursday				Date : 10.08.23					
Probable Maximum Demand : 14400 MW					Probable Maximum Generation : 14472 MW					Rule Curve = 91.88 ft.				
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 94.37 ft		Today = 97.12 ft		10.08.23		09.08.23			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Dated/ Present Capacity (MW)	09.08.23 (Yesterday)		10.08.23 (Today)		09.08.23 (Yesterday)		Status of Machines under shut-down/ Maintenance		Probable start-up date	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)	Description/ Remarks			
					Day	Evening	Day	Evening						
(A) Plants in operation:														
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work		
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	200	190	190	190					
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180					
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0					
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	12	12	12	12	96		Gas Shortage		
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage		
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0					
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	332	331	300	330					
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450					
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling		
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	406	396	400	400					
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	91	147	60	100					
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	321	328	330	330					
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0		115	Under maint.		
14	Madangan-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	0	15					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	16	33	20	33					
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	19	18	20					
17	Summit Power, Madhabdi-Ashulia	Gas (SIPP, REB)	6x3.67+3x8.73	80	80	40	39	39	39					
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	33	33	33					
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	18	19	22	22					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	10	25	8	25					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	52	88	35	88					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	64	148	64	149					
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	35	0	35					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	47	97	45	95					
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	149	95	35	149					
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	109	97	0	0					
27	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	55	35	55					
28	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	35	35					
29	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	53	35	53					
30	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	54	162	54	162					
31	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	11	0	35	0					
32	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	17					
33	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	32	57	32	60					
34	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	32	41	50	50					
35	Madangan 102 PP(Summit)	HFO (NENP)	6x17	102	102	17	51	17	17					
36	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	9	50	56	60					
Dhaka Zone Total				5904	5722	2778	3298	2607	3204	201	490			
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	192	202	170	202					
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	120	120	115	120	60		Gas Shortage		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.		
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	0	0	5	0					
40	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	25	8	25					
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	1	0	20	0					
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	6	6	20					
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	34	34	34	34					
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.		
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	223	227	150	225					
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	69	262	66	270					
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	50	25	50					
48	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	0	0	0					
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	17	17	17	17					
50	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	10	10	10	10					
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			6	24	5	24					
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	50	12	90					
52	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	36	17	17					
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	55	74	51	51					
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	50	25	50					
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRRP)	8x13.45	100	100	46	58	46	55					
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	34	34	34	34					
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	53	107	53	144					
	SS Power Unit-1	Coal (IPP)				0	0	0	0					
	Matarbari 2*600 MW (CPGCL)	Coal				180	0	0	0			Test run		
	Cox's Bazar Wind PP	(Wind) (IPP)				10	4	22	22					
Chattogram Zone Total				2605	2545	1131	1390	891	1460	60	330			
58	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	0	0	0	0	45		Gas Shortage		
59	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	175	184	180	180					
60	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	230	230	230	230	130		Gas Shortage		
61	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	275	270	270	270	90		Gas Shortage		
62	Ashuganj 420 MW CCPP(East)	Gas (APSCL)	1x284+1x116	400	400	230	230	230	230	170		Gas Shortage		
63	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*116	195	195	0	0	0	0	195		Gas Shortage		
64	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51					
65	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	5	28	6	30					
66	Tilas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	48	47	40	48					
67	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163	Under maint.		
68	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	68	157	68	155					
69	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	12	20	20	22					
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	11	11	11					
71	Jangalia 33 MW PP (Summit))	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33					
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	43	43	52	52					
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	14	20	14	20					
74	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	34	17	17					
75	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	29	9	28					
76	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17					
77	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	72	114	72	115					
**	Import (Tirupura)	India		160	160	148	160	146	163					
Cumilla Zone Total				2904	2896	1447	1678	1466	1672	630	163			
78	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	29	52	32	60	150		Gas Shortage		
79	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	16	16	16					
80	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	18	94	18	90					
81	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	74	88	68	88					
82	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0					
83	Sulakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	31	0	50	0					
84	Tangail 22 MW PP(PPLG)	HFO (IPP)	4x6.7	22	22	6	4	6	6					
Mymensingh Zone Total				622	614	176	254	192	260	150	0			

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	09.08.23 (Yesterday)		10.08.23 (Today)		09.08.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)		
85	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.	
86	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42	42		48	GT-4 Under maint.	
87	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)		19x2.90	51	51	47	47	50	50			
88	Kushiera 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	112	112		54	ST Under maint.	
89	Hobigari 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	5	5	5				
90	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	25	20	20	20				
91	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
92	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	78	86	80	86				
93	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	183	181	180	180				
94	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	17	17	17	17				
95	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	9	10	10				
96	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	24	16	24	24				
97	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	285	280	280	280				
98	Bibiya-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	377	367	400	400				
99	Bibiya South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	355	360	355	360				
100	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	55	0	0	0		100	Under project work	
101	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.4+5*2	50	50	47	43	45	47				
Sylhet Zone Total						2472	2427	1711	1628	1663	1676	0	559
102	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
103	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	85	60	120	200	350	Gas Shortage		
104	Fairdipor 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	21	0	40				
105	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	20	40	70				
106	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	120	120				
107	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	17	17	17				
108	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	15	50	15	105				
109	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	63	0	100	0				
110	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	57	17	60	98				
111	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	8	8	8				
112	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	0	0	0	0	617	Coal Shortage		
113	Khulna 330 MW CCPP (GT)	Gas/HSD (BDFB)	1x220	220	220	0	30	120	120				
**	Bheramara (HVDC)	India		1000	1000	914	798	922	922				
Khulna Zone Total						3125	3121	1151	1021	1522	1700	967	0
114	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	64	16	64				
115	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	22	29	22	30				
116	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	130	132	132	132				
117	Payra 1320 MW TTP	Coal (BCPCL)	2x622	1244	1244	1244	1244	1244	1244				
118	Potukhalhi 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	100	17	150				
119	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	0	0	0	0	307	Coal Shortage		
120	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	223	225	220	220				
Barishal Zone Total						2265	2265	1652	1794	1651	1840	307	0
121	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage		
122	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Under maint.		
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	34	0	35				
124	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
125	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	14	0	30				
126	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	26	50	90				
127	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	15	30	30	30				
128	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	8	8	34				
129	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	30	0	30				
130	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210	Gas Shortage		
131	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	138	200	220	82	Gas Shortage		
132	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	138	134	150	150	86	Gas Shortage		
133	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	326	337	350	350	77	Gas Shortage		
134	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	0	0	0	0	0				
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8				
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	0	0	8				
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	55	35	55				
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	50	35	50				
139	Amnura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	0	0				
139	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	3	0	6	0				
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	1257	1364	1200	1200				
Rajshahi Zone Total						3675	3631	1825	2228	2072	2290	526	100
140	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Coal Shortage		
141	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overhauling		
141	Barapukuria 275 MW TTP Unit-3	Coal (PDB)	1 x 274	274	274	220	220	200	220	54	Coal Shortage		
142	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
143	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	34	55	35	55				
144	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
145	Majpara, Taluk 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	3	0	8	0				
146	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	95	35	95				
147	Lalmoharhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	14	0	30	0				
148	Teesa Solar Limited	Solar (IPP)	1 x 200	200	200	116	0	130	0				
Rangpur Zone Total						1030	950	387	370	438	370	139	85
Sub-total: Plants in operation						24602	24171	12258.0	13661	12502	14472	2980	1727
(B) Plants under long term maintenance/ contract expired													
149	Jamailpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
150	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
151	Bosilia 108MW PP(PLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
152	Ashugani 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	0	0	0	0				
Sub-Total: Plants under long term maintenance/ contract expired						309	0	0	0	0	0	0	0
Gross Total						24911	24171	12258	13661	12502	14472	2980	1727
(C) Actual data of 09.08.23 (Yesterday) Wednesday :													
01.	Max. Demand at eve. peak (Generation end)	:	13776 MW, at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :								
02.	Max. Demand at eve. peak (Sub-station end)	:	13181 MW, at =	21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW	
03.	Highest Generation (Generation end)	:	13661 MW, at =	21:00 hrs	Dhaka	4725	4665	60	Mymensingh	1158	1108	50	
04.	Minimum Generation (Generation end)	:	10285 MW, at =	7:00 hrs	Chattogram	1083	1083	0	Sylhet	527	527	0	
05.	Day-peak Generation (Generation end)	:	12258 MW, at =	12:00 hrs	Khulna	1618	1618	0	Barishal	394	394	0	
06.	Evening-peak Generation (Generation end)	:	13661 MW, at =	21:00 hrs	Rajshahi	1412	1412	0	Rangpur	947	947	0	
07.	Evening Peak Load-shed (Sub-station end)	:	110 MW, at =	21:00 hrs	Cumilla	1318	1318	0					
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10895 MW, at =	5:00 hrs					Total	13181	13071	110	
09.	Generation shortfall at evening peak due to :	:											
a)	Gas/LF limitation	:	2841 MW										
b)	Coal supply Limitation	:	139 MW										
c)	Low water level in Kaptai lake	:	0 MW										
d)	Plants under shut down/ maintenance	:	1727 MW										
10.	Total Energy (Generation + India Import)	:	289.76 MKWh										
	By Gas =	142.466 MKWh	By Oil =	46.284 MKWh									
	By Coal =	69.601 MKWh	By Hydro =	4.297 MKWh									
	By Solar =	2.221 MKWh											
11.	Total Gas Supplied	:	1128.72 MMCFD										
(D) Forecast of 10.08.23 (Today) Thursday :													
01.	Maximum Demand	:	14400 MW (Generation end)		04.	Maximum Load-shed	:	0 MW	At evening peak (Sub-station end)				
02.	Maximum Generation	:	14472 MW (Generation end)		05.	Total Generation	:	305.44 MKWh					
03.	Reserve / Shortage	:	72 MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	:	33.8° C					

#Remarks: Highest Generation 15648 MW on 19