

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

| Date :                |                                         | 10-Aug-23      |                     |                  |                      | Page - 2         |                   |
|-----------------------|-----------------------------------------|----------------|---------------------|------------------|----------------------|------------------|-------------------|
| Sl. No.               | Name of the Power Stations              | Producer       | Installed Capacity  | Present Capacity | Peak Hour Generation | Enerov Generated | Remarks           |
|                       |                                         |                | Unit No. X Capacity | MW               | MW                   | KWH              |                   |
| 1                     | Ghorasal Repowered CCPP-Unit-3 (GT      | PDB            | 1*260               | 260              | 0                    | 0                | Under maint.      |
| 2                     | Ghorasal Repowered CCPP Unit-4          | PDB            | 1*210               | 180              | 190                  | 4073750          |                   |
|                       | Ghorasal TPP Unit-5                     | PDB            | 1*210               | 190              | 180                  | 4347000          |                   |
| 3                     | Ghorasal 365 MW CCPP Unit-7             | PDB            | 1*243+1*122         | 365              | 0                    | 0                | Under maint.      |
|                       | Ghorasal 78.5 MW PP(MAX)                | QRPP           | 2*40                | 0                | 0                    | 0                | Contract Expired  |
| 4                     | Ghorasal 108 MW PP (Regent)             | IPP            | 3*4*35              | 108              | 12                   | 291681           | Gas shortage      |
| 5                     | Haripur GTTP                            | SBU, PDB       | 2*32                | 20               | 0                    | 0                | Under maint.      |
| 6                     | Haripur 412 MW CCPP                     | EGCB           | 1*273+1*139         | 412              | 397                  | 9631740          |                   |
| 7                     | Haripur 360 MW CCPP(HPL)                | IPP            | 1*235+1*125         | 360              | 347                  | 7940000          |                   |
| 8                     | Meghnaghat 450 MW CCPP(MPL)             | IPP            | 2*150+1*150         | 450              | 450                  | 9759800          |                   |
| 9                     | Meghnaghat 100 MW(IEEL)                 | NENP           | 12*8.9              | 100              | 42                   | 612480           | Fuel shortage     |
| 10                    | Meghnaghat CCPP(Summit)                 | IPP            | 2*110+1*110         | 335              | 0                    | 0                | Under maint.      |
| 11                    | Madanganj 102 PP(Summit)                | NENP           | 6*17                | 102              | 17                   | 390722           | Fuel shortage     |
| 12                    | Madanganj-55 MW PP(Summit)              | IPP            | 3*17.08+1*11.3      | 55               | 30                   | 440855           | Fuel shortage     |
| 13                    | Keraniganj 100 MW PP (Powerpac)         | NENP           | 8*13.45             | 75               | 22                   | 615210           | Fuel shortage     |
| 14                    | Narshingdi 22 MW PP (Doreen)            | SIPP, REB      | 8*2.90              | 22               | 22                   | 423288           |                   |
| 15                    | 210 MW Siddhirganj TPP                  | PDB            | 1*210               | 115              | 0                    | 0                | Under maint.      |
| 16                    | Siddhirganj 2*120 MW GTTP               | EGCB           | 2*105               | 210              | 97                   | 1964000          | Gas shortage      |
| 17                    | Siddhirganj 100 PP(Dutch Bangla)        | NENP           | 12*8.9              | 100              | 40                   | 574080           | Fuel shortage     |
| 18                    | Siddhirganj 335 MW CCPP                 | EGCB           | 1*217+1*18          | 335              | 332                  | 7525394          |                   |
| 19                    | Gagnagar 102 MW PP (Digital Power)      | IPP            | 12*8.924            | 102              | 67                   | 610560           | Fuel shortage     |
| 20                    | Katpotti 52 MW PP (Sinha)               | IPP            | 7*7.9               | 0                | 0                    | 0                | Fuel shortage     |
| 21                    | Kamalaghat 54 MW PP(Banco Energy)       | IPP            | 3*18                | 54               | 35                   | 387720           | Fuel shortage     |
| 22                    | Kodda 150 MW PP                         | BPDB-RPCL      | 9*17.06             | 149              | 130                  | 1860960          | Engine problem    |
| 23                    | Manikganj 55 MW PP (Northern)           | IPP            | 3*19.3              | 55               | 35                   | 441275           | Fuel shortage     |
| 24                    | Nababganj 55 MW PP (Southern power)     | IPP            | 3*19.3              | 55               | 55                   | 438824           |                   |
| 25                    | Bosila 108 MW PP(CLC)                   | IPP            | 12*8.775+1*3.5      | 0                | 0                    | 0                |                   |
| 26                    | Summit Power,(Madhabdi+Ashulia)         | SIPP, REB      | 3*3.67+4*8.73       | 80               | 37                   | 915000           | Engine problem    |
| 27                    | Maona 33 MW PP(Summit)                  | SIPP, REB      | 4*8.73              | 33               | 25                   | 777400           | Engine problem    |
| 28                    | Rupganj 33 MW PP(Summit)                | SIPP, REB      | 4*8.73              | 33               | 18                   | 480700           | Engine problem    |
| 29                    | Gazipur 52 MW PP                        | RPCL           | 8*6.9               | 52               | 25                   | 283680           | Fuel shortage     |
| 30                    | Tongi 80 MW GTTP                        | PDB            | 1*105               | 105              | 0                    | 0                | Under maint.      |
| 31                    | Kodda 300 MW PP Unit-2 (Summit)         | IPP            | 18*17.076           | 300              | 60                   | 1558145          | Fuel shortage     |
| 32                    | Keraniganj 300 MW PP (APR)              | IPP            | 256*1.4             | 300              | 0                    | 0                | Fuel shortage     |
| 33                    | Branaganj 100 MW PP (Aggreko)           | IPP            | 3*19.3+9.59         | 0                | 0                    | 0                | Contract Expired  |
| 34                    | Auraha 100MW PP (Aggreko)               | IPP            | 0.85*23+0.95*91     | 0                | 0                    | 0                | Contract Expired  |
| 35                    | Kodda 149 MW PP Unit-1 (Summit)         | IPP            | 8*18.45+8.97        | 149              | 140                  | 1407020          | Machine problem   |
| 36                    | Gazipur 100 MW PP                       | RPCL           | 6*17.5              | 105              | 88                   | 1310467          | Engine problem    |
| 37                    | Meghnaghat 104 MW PP (OPCL)             | IPP            | 18.5*6              | 104              | 53                   | 629760           | Fuel shortage     |
| 38                    | Manikganj 162MW PP(MPL)                 | IPP            | 9*18                | 162              | 162                  | 1357920          |                   |
| 39                    | Spectra Solar Plant Ltd                 | IPP            | 0                   | 35               | 0                    | 176524           |                   |
| 40                    | Kanchan Purbachal Power Generation Ltd. | IPP            | 18.4*3              | 55               | 17                   | 431640           | Fuel shortage     |
| Dhaka area Total      |                                         |                |                     | 5722             | 3125                 | 61657595         |                   |
| 41                    | Chattogram TPP-1                        | PDB            | 1*210               | 180              | 118                  | 2700000          | Gas shortage      |
| 42                    | Chattogram TPP-2                        | PDB            | 1*210               | 180              | 0                    | 0                | Gas shortage      |
| 43                    | Razzan 25 MW PP                         | RPCL           | 3*8.9               | 25               | 25                   | 281887           |                   |
| 43                    | Teknaf 20MW PP (Solaritech)             | IPP            | 20                  | 20               | 0                    | 84375            |                   |
| 44                    | Patenga 50MW PP (Baraka)                | IPP            | 8*6.98              | 50               | 6                    | 142560           | Fuel shortage     |
| 45                    | Kapila Hydro Unit-1,2,3,4, 5            | PDB            | 2*40+3*50           | 230              | 207                  | 3893400          | Low water level   |
| 46                    | Sikalbaha 225MW                         | PDB            | 1*150+1*75          | 225              | 226                  | 5637623          |                   |
| 47                    | Sikalbaha Peaking GT                    | PDB            | 1*150               | 150              | 0                    | 0                | Under maint.      |
| 48                    | Sikalbaha 105 MW PP (Baraka Sikalbaha)  | IPP            | 6*17.5              | 105              | 34                   | 840545           | Fuel shortage     |
| 49                    | Halhazari 100 MW peaking PP             | PDB            | 11*8.9              | 98               | 33                   | 537168           | Fuel shortage     |
| 50                    | Dohazari -Kalaish 100 MW Peaking        | PDB            | 6*17                | 102              | 0                    | 0                | Reserve.          |
| 51                    | Juldah 100 MW Unit-1 (Acom)             | NENP           | 8*13.45             | 100              | 58                   | 730800           | Fuel shortage     |
| 52                    | Juldah 100 MW PP Unit-3 (Acom)          | IPP            | 8*13.5              | 100              | 50                   | 675840           | Fuel shortage     |
| 53                    | Barakunda 22 MW PP (Regent)             | SIPP, PDB      | 8*2.90              | 22               | 12                   | 254832           | Contract Expired  |
| *                     | Malancha, Ctp, EPZ (United)             |                | 5*8.73+3*9.34       | 0                | 24                   | 385320           | Engine problem    |
| 54                    | Chattogram 108 MW PP (ECPV)             | IPP            | 16*7                | 108              | 30                   | 172800           | Fuel shortage     |
| 55                    | Kapila 7 MW Solar PP                    | PDB            | 7.4 MW              | 7                | 0                    | 9238             |                   |
| 56                    | Anwara 300 MW PP (United)               | IPP            | 17*17+24            | 300              | 270                  | 2273236          | Fuel shortage     |
| 57                    | Jodda Power                             | IPP            | 3*18.58+13*6        | 54               | 17                   | 528689           | Fuel shortage     |
| 58                    | Karnaphuli Power Ltd.                   | IPP            | 18.415*6+8.5        | 110              | 55                   | 1319780          | Fuel shortage     |
| 59                    | Juldah unit-2 (Acom)                    | IPP            | 8*13.6              | 100              | 50                   | 701760           | Fuel shortage     |
| 60                    | Anilima Energy Ltd.                     | IPP            | 6*21.2              | 116              | 34                   | 840545           | Fuel shortage     |
|                       | Mirshara 150 MW                         | BPDB-RPCL      | 18.5*9              | 163              | 143                  | 1165890          | Fuel shortage     |
|                       | SS Power-1                              | SS Power       | 0                   | 0                | 0                    | 0                | On test.          |
|                       | Cox's Bazar Wind                        | IPP            | 68                  | 0                | 0                    | 74400            | On test.          |
|                       | Matscheri 2*600 MW (CPGCL)              | CPGCL          | 0                   | 0                | 0                    | 0                | On test.          |
| Chattogram area Total |                                         |                |                     | 2545             | 1392                 | 22969768         |                   |
| 61                    | Ashuganj TPP Unit- 3                    | APSCL          | 1*150               | 0                | 0                    | 0                | Contract Expired  |
|                       | Ashuganj TPP Unit- 4                    | APSCL          | 1*150               | 0                | 0                    | 0                | Contract Expired  |
|                       | Ashuganj TPP Unit- 5                    | APSCL          | 0                   | 0                | 0                    | 0                | Contract Expired  |
| 62                    | Ashuganj 225 MW CCPP                    | APSCL          | 1*142+1*75          | 221              | 170                  | 4258000          | Gas shortage      |
| 63                    | Ashuganj 450 MW CCPP(North)             | APSCL          | 1*360               | 360              | 270                  | 7051800          | Gas shortage      |
| 64                    | Ashuganj 450 MW CCPP(South)             | APSCL          | 1*360               | 360              | 245                  | 5786000          | Gas shortage      |
| 65                    | Ashuganj 420 MW CCPP(East)              | APSCL          | 284*1+1*6*1         | 400              | 230                  | 6015600          | Gas shortage      |
| 65                    | Ashuganj 50 MW PP                       | APSCL          | 14*3.968            | 45               | 0                    | 0                | Gas shortage      |
| 66                    | Ashuganj 55 MW PP (Precision)           | QRPP           | 15*4                | 0                | 0                    | 0                | Contract Expired  |
| 67                    | Ashuganj 195 MW PP (APSCL-United)       | IPP            | 20*9.73+1*16        | 195              | 0                    | 0                | Gas shortage      |
| 68                    | Ashuganj 51 MW PP (Midland)             | IPP            | 6*9.34              | 51               | 51                   | 1074024          |                   |
| 69                    | Ashuganj 150 MW PP (Midland)            | IPP            | 23*7.015            | 150              | 26                   | 239200           | Fuel shortage     |
| 70                    | Titas 50 MW Peaking PP                  | PDB            | 8*9.92              | 52               | 48                   | 1014240          |                   |
| 71                    | Chandpur 150 MW CCPP                    | PDB            | 1*108+1*57          | 165              | 0                    | 0                | Under maint.      |
| 72                    | Chandpur 200 MW (Desh energy)           | IPP            | 12*18.4             | 200              | 155                  | 1694880          | Fuel shortage     |
| 73                    | Feni 22 MW PP (Doreen)                  | SIPP, PDB      | 8*2.90              | 22               | 18                   | 448560           | Engine problem    |
| 74                    | Feni 11 MW PP (Doreen)                  | SIPP, REB      | 4*2.90              | 11               | 11                   | 247320           |                   |
| **                    | Imported (Tijura)                       | Imported power | 0                   | 160              | 160                  | 3523200          |                   |
| 75                    | Jangalia 33 MW PP (Summit)              | SIPP, PDB      | 4*8.73              | 33               | 33                   | 789000           |                   |
| 76                    | Jangalia 52 MW PP (Lakdanavi)           | IPP            | 6*8.92              | 52               | 43                   | 1039061          | Engine problem    |
| 77                    | Cumilla 25 MW PP (Summit)               | SIPP, REB      | 3*3.67+2*6.97       | 25               | 20                   | 481420           | Engine problem    |
| 78                    | Daudkandi 200 MW PP (B.Trac)            | IPP            | 154*1.4             | 200              | 0                    | 0                | Contract Expired  |
| 79                    | Feni Lanka Power                        | IPP            | 7*18.415+1*9.78     | 114              | 17                   | 414960           | Fuel shortage     |
| 80                    | Chowmuhani 113 MW                       | IPP            | 12*9.78+2*3.1       | 113              | 28                   | 365400           | Fuel shortage     |
| 81                    | Bhairab 54.5 MW                         | IPP            | 3*18.2              | 54               | 32                   | 454680           | Engine problem    |
| 82                    | Chandpur 115(Doreen)                    | IPP            | 4*18.5+2*22.5       | 115              | 72                   | 1398720          | Fuel shortage     |
| Cumilla Area Total    |                                         |                |                     | 3096             | 1629                 | 36305065         |                   |
| 83                    | RPCL 210MW CCPP                         | IPP            | 4*35+1*70           | 202              | 32                   | 1142400          | Gas shortage      |
| 84                    | Tangail 22 MW PP (Doreen)               | SIPP, PDB      | 8*2.90              | 22               | 16                   | 339624           | Engine problem    |
| 85                    | Jamailpur 55 MW PP(Powerpac)            | IPP            | 12*8.94             | 0                | 0                    | 0                | Under maint.      |
| 86                    | Sarishabari 3 MW Solar Plant            | IPP            | 1*3                 | 3                | 0                    | 12350            |                   |
| 87                    | Mymensingh 200 MW PP (United)           | IPP            | 9*78*21             | 200              | 87                   | 1720800          | Fuel shortage     |
| 88                    | Jamailpur 115 MW PP (United)            | IPP            | 9*78*12             | 115              | 84                   | 685200           | Fuel shortage     |
| 89                    | Subahatli 50 MW Solar PP                | IPP            | 50                  | 50               | 0                    | 210530           |                   |
| 90                    | Tangail Pali Power Gen 22 MW            | IPP            | 4*6.7               | 22               | 6                    | 144960           | Fuel shortage     |
| Mymensingh Area Total |                                         |                |                     | 614              | 225                  | 4255864          |                   |
| 91                    | Fenchugonj CCPP Phase-1                 | PDB            | 2*32+1*33           | 70               | 43                   | 1022000          | Machine problem   |
| 92                    | Fenchugonj CCPP Phase-2                 | PDB            | 2*35+1*35           | 90               | 42                   | 954000           | Machine problem   |
| 93                    | Kusthiara 163 MW CCPP (KP)              | IPP            | 1*109+1*54          | 163              | 112                  | 2348509          | ST Under maint.   |
| 94                    | Shahbaz 130 MW CCPP                     | PDB            | 2*110               | 0                | 0                    | 0                | Under maint.      |
| 95                    | Fenchugonj 51 MW PP (Barakatullah)      | RPP            | 19*2.90             | 51               | 49                   | 1075200          |                   |
|                       | Fenchuganj 44 MW (Energyprima)          | NENP           | 12*3.3+5*2          | 50               | 50                   | 1174968          |                   |
| 96                    | Hobiganj 11 MW PP Confidence-E          | SIPP, REB      | 4*2.90              | 11               | 11                   | 215040           |                   |
| 97                    | Shahjibazar GTTP Unit- 8 & 9            | PDB            | 2*35                | 66               | 20                   | 486528           | GT-9 Under maint. |
| 98                    | Shahjibazar 86 MW PP (Shahjibazar)      | RPP            | 32*2*90             | 86               | 86                   | 1877760          |                   |
| 99                    | Shahjibazar 100 MW GTTP                 | PDB            | 1*100               | 100              | 0                    | 135745           | Under maint.      |
| 100                   | Sylhet 225 MW CCPP                      | PDB            | 1*142+1*89          | 231              | 181                  | 4686990          | Machine problem   |
| 101                   | Sylhet 20 MW GTTP                       | PDB            | 1*20                | 20               | 17                   | 392000           | Machine problem   |
| 102                   | Sylhet 50 MW PP (EPL)                   | NENP           | 2*7.2               | 0                | 0                    | 0                | Contract Expired  |
| 102                   | Shahjahanulla 25 MW PP                  | SIPP, REB      | 3*9.34              | 25               | 24                   | 560098           |                   |
| 104                   | Bibiana-I 341 MW CCPP (Summit)          | IPP            | 1*222+1*119         | 341              | 270                  | 7128000          | FGMO              |
| 104                   | Bibiyana-III 400 MW CCPP                | PDB            | 285*1+134*1         | 400              | 402                  | 8890000          | FGMO              |
| 105                   | Sylhet 10MW PP (Desh)                   | RPP            | 6*1.95              | 10               | 10                   | 243900           |                   |
| 106                   | Bibiyana South 400 MW                   | PDB            | 400 MW              | 363              | 360                  | 8481300          |                   |
| Sylhet Area Total     |                                         |                |                     | 2427             | 1677                 | 39872028         |                   |
| 107                   | Bheramara GTTP Unit-3                   | PDB            | 1*20                | 16               | 0                    | 0                | Fuel shortage     |
| **                    | Bheramara (HVDC )                       | Imported power | 2*500               | 1000             | 794                  | 20582545         |                   |
| 108                   | Khulna 115 PP MW (KPCL-2)               | NENP           | 7*17                | 115              | 98                   | 1770240          | Fuel shortage     |
| 109                   | Fardipur 50 MW Peaking PP               | IPP            | 6*9.89              | 54               | 40                   | 196320           | Engine problem    |
| 110                   | Khulna 225 MW CCPP                      | NWP/PGCL       | 1*150+1*75          | 220              | 160                  | 3049536          |                   |
| 111                   | Gopalganj 100 MW Peaking PP             | PDB            | 16*6.98             | 109              | 60                   | 678144           | Engine problem    |
| 112                   | Bheramara 410 MW CCPP                   | NWP/PGCL       | 1*278+1*132         | 410              | 60                   | 2043936          | Gas shortage      |
|                       | Noapara 40 MW PP (Khanjahan Ali)        | NENP           | 5*8.5               | 40               | 8                    | 49500            | Fuel shortage     |
| 113                   | Noapara 100 MW PP (Bangla Trac)         | IPP            | 70*1.4              | 0                | 0                    | 0                | Contract Expired  |
| 114                   | Rupsha 105 MW PP (Orion rupsha)         | IPP            | 6*18.445            | 105              | 17                   | 415200           | Fuel shortage     |
| 115                   | Madhumati 100 MW PP                     | NWP            |                     |                  |                      |                  |                   |