

Bangladesh Power Development Board
DAY1 ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564657, 9551095

Month August, 2023						Day : Sunday				Date : 13.08.23					
Probable Maximum Demand :				13500 MW		Probable Maximum Generation :				14635 MW					
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 101.32 ft		Today = 101.78 ft		13.08.23		Rule Curve = 92.84 ft					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	12.08.23 (Yesterday)		13.08.23 (Today)		12.08.23 (Yesterday)		13.08.23 (Today)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Machines shut down (MW)		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening							
(A) Plants in operation:															
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0			260		Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	190	190	190	190						
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180						
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0						
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	12	12	12	12	96				Gas Shortage	
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105				Gas Shortage	
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0						
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	331	332	330	330						
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450						
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0			115		Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	403	397	400	400						
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	186	191	200	200						
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	321	323	330	330						
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	115				Under maint.	
14	Madangan-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	15	15						
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	25	16	64						
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	16	19	18	20						
17	Summit Power, (Madhabdi-Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	38	40	41	41						
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33						
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	30	30	32	32						
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	25	8	25						
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	35	88	35	88						
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	48	113	48	100						
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	35	17	35						
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	47	45	45	95						
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	149	17	149						
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	0	0						
27	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	5	55	35	55						
28	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	35	35						
29	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	52	17	53						
30	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	54	162	54	162						
31	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	17	0	35	0						
32	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	17						
33	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	24	16	35	60						
34	Meghnaghat 100 MW(EL)	HFO (NENP)	12x8.9	100	100	17	17	17	33						
35	Madangan 102 PP(Summit)	HFO (NENP)	6x17	102	102	34	17	17	17						
36	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	22	11	22	45						
Dhaka Zone Total				5904	5722	2627	3074	2701	3266	201	490				
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	200	203	204	204						
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	117	119	120	120						
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180				Under maint.	
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	3	0	5	0						
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	25	8	25						
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	20	0	20	0						
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	33	6	33						
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	17	17	51						
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150				Under maint.	
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	224	226	225	225						
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	70	272	70	280						
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	50	25	50						
48	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	17	0	34						
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	16	75	17	75						
50	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	12	12	10	10						
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			8	18	25	35						
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	16	0	16						
52	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17						
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	55	73	51	51						
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	25	25	50						
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRRP)	8x13.45	100	100	35	70	46	70						
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	34	34	34	34						
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	17	142	17	144						
	SS Power Unit-1	Coal (IPP)				0	0	0	0						
	Matarbari 2*600 MW (CPGCL)	Coal				0	170	0	0					Test run	
	Cox's Bazar Wind PP	(Wind) (IPP)				1	5	22	22						
Chattogram Zone Total				2605	2545	910	1619	964	1546	0	330				
58	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	0	0	0	0	45				Gas Shortage	
59	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	173	172	190	200						
60	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	240	240	240	240	120				Gas Shortage	
61	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	270	270	280	280	90				Gas Shortage	
62	Ashuganj 420 MW CCPP(East)	Gas (APSCL)	1x284+1x116	400	400	230	230	230	230	170				Gas Shortage	
63	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*116	195	195	0	0	0	0	195				Gas Shortage	
64	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51						
65	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	5	26	6	30						
66	Titlas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	15	40	48						
67	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163				Under maint.	
68	Chandpur 200MW (Desh energy)	HFO (IPP)	12x16.415	200	200	69	136	68	155						
69	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	16	20	22						
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	8	11	11						
71	Jangalia 33 MW PP (Summit))	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33						
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	8	8	8						
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	14	20	20	20						
74	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	17	17						
75	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	28	9	28						
76	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	35						
77	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	72	115	72	115						
**	Impoqrit (Tripura)	India		160	160	130	154	146	163						
Cumilla Zone Total				2904	2896	1339	1539	1458	1686	620	163				
78	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	34	32	45	70	170				Gas Shortage	
79	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	16	16	16						
80	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	19	84	18	85						
81	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	67	87	68	88						
82	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.1							

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	12.08.23 (Yesterday)		13.08.23 (Today)		12.08.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)		
85	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.	
86	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42	42		48	GT-4 Under maint.	
87	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	44	47	50	50				
88	Kushiera 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	112	112		54	ST Under maint.	
89	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
90	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	20	20	20	20				
91	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
92	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	78	86	80	86				
93	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	181	180	180	180				
94	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	17	17	17	17				
95	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
96	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	24	24	24				
97	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	305	290	290				
98	Bibiyan-II 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	367	368	400	400				
99	Bibiyan South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	360	360	360	360				
100	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	55	0	0	0		100	Under project work	
101	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.4+5*2	50	50	47	46	45	50				
Sylhet Zone Total						2472	2427	1703	1671	1684	1695	0	559
102	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
103	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	115	70	100	110		340	Gas Shortage	
104	Fairdipor 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	10	35	0	40				
105	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	26	45	40	51				
106	Khulna 225 MW CAPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0				
107	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	17	17	17				
108	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	15	85	15	105				
109	Mongla Orion 100 MW Solar PP	Solar (IPP)	100	100	22	0	100	0					
110	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	16	16	16				
111	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	8	8	8				
112	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	0	0	0	0		617	Coal Shortage	
113	Khulna 330 MW CAPP (GT)	Gas/HSD (BDFB)	1x220	220	220	0	100	50	220				
**	Bheramara (HVDC)	India	1000	1000	915	801	933	933					
Khulna Zone Total						3125	3121	1120	1177	1279	1500	957	0
114	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	80	16	80				
115	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	21	28	22	30				
116	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	132	132	132	132				
117	Payra 1320 MW TTP	Coal (BCPCL)	2x622	1244	1244	1244	1244	1244	1244				
118	Potukhal 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	150	17	150				
119	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	0	0	0	0		307	Coal Shortage	
120	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	221	222	220	220				
Barishal Zone Total						2265	2265	1651	1856	1651	1856	307	0
121	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage	
122	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.	
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	35	0	35				
124	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
125	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	30				
126	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	70	50	90				
127	Katakhal 50 MW Peaking PP	HFO (QRPP)	6x8.9	50	50	42	42	8	42				
128	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	24	0	30				
129	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0		210	Gas Shortage	
130	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	170	217	200	220				
131	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	143	133	150	150		87	Gas Shortage	
132	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	387	337	350	350		77	Gas Shortage	
133	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	0	0	0	0	0				
134	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8				
135	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	0	8				
136	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	55	35	55				
137	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	50	35	50				
138	Ammura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	28	28	28	28				
139	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	6	0	6	0				
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	1210	1254	1200	1300				
Rajshahi Zone Total						3675	3631	2064	2298	2100	2433	445	100
140	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage	
141	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
142	Barapukuria 275 MW TTP Unit-3	Coal (PDB)	1 x 274	274	274	200	210	200	220		64	Coal Shortage	
143	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	34	56	35	55				
145	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Majma. Talsia 9 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 9	9	3	0	8	0	0				
147	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	75	35	113				
148	Lalmoharhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	13	0	30	0				
149	Teesa Solar Limited	Solar (IPP)	1 x 200	200	200	175	0	130	0				
Rangpur Zone Total						1030	950	425	341	438	388	149	85
Sub-total: Plants in operation						24602	24171	11989.0	13800	12480	14635	2849	1727
(B) Plants under long term maintenance/ contract expired													
150	Jamailpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
151	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
152	Bosilla 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
153	Ashugani 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	0	0	0	0				
Sub-Total: Plants under long term maintenance/ contract expired						309	0	0	0	0	0	0	0
Gross Total						24911	24171	11989	13800	12480	14635	2849	1727
(C) Actual data of 12.08.23 (Yesterday) Saturday :													
01.	Max. Demand at eve. peak (Generation end)	:	13889 MW, at =	19:30 hrs	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :								
02.	Max. Demand at eve. peak (Sub-station end)	:	13315 MW, at =	19:30 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW	
03.	Highest Generation (Generation end)	:	13800 MW, at =	19:30 hrs	Dhaka	4887	4862	25	Mymensingh	1043	983	60	
04.	Minimum Generation (Generation end)	:	10801 MW, at =	8:00 hrs	Chattogram	1257	1257	0	Sylhet	565	565	0	
05.	Day-peak Generation (Generation end)	:	11989 MW, at =	12:00 hrs	Khulna	1575	1575	0	Barishal	424	424	0	
06.	Evening-peak Generation (Generation end)	:	13800 MW, at =	19:30 hrs	Rajshahi	1346	1346	0	Rangpur	943	943	0	
07.	Evening Peak Load-shed (Sub-station end)	:	85 MW, at =	19:30 hrs	Cumilla	1276	1276	0					
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10524 MW, at =	5:00 hrs									
09.	Generation shortfall at evening peak due to :	:			Total								
	a) Gas/LF limitation	:	2700 MW		Total = 13315								
	d) Coal supply Limitation	:	149 MW		Total = 13230								
	b) Low water level in Kaptai lake	:	0 MW		Total = 1054457376 Taka								
	c) Plants under shut down/ maintenance	:	1727 MW										
10.	Total Energy (Generation + India Import)	:	290.40 MKWh										
	By Gas = 148.959 MKWh	By Oil =	44.739 MKWh										
	By Coal = 65.640 MKWh	By Hydro =	4.652 MKWh										
	By Solar= 1.547 MKWh												
11.	Total Gas Supplied	:	1143.26 MMCFD										
(D) Forecast of 13.08.23 (Today) Sunday :													
01.	Maximum Demand	:	13500 MW (Generation end)		04.	Maximum Load-shed	:	0 MW	At evening peak (Sub-station end)				
02.	Maximum Generation	:	14635 MW (Generation end)		05.	Total Generation	:	284.09 MKWh					
03.	Reserve / Shortage	:	1135 MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	31.9° C						

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)<