

Bangladesh Power Development Board
DAY1 ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564657, 9551095

Month August, 2023						Day : Monday				Date : 14.08.23					
Probable Maximum Demand :				14300 MW		Probable Maximum Generation :				14799 MW					
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 101.78 ft		Today = 102.02 ft				Rule Curve = 96.16 ft					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	13.08.23 (Yesterday)		14.08.23 (Today)		13.08.23 (Yesterday)		14.08.23 (Today)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Machines shut down (MW)		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening							
(A) Plants in operation:															
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0			260		Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	192	160	170	170						
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180						
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0						
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	12	12	12	12	96				Gas Shortage	
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105				Gas Shortage	
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0						
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	341	343	310	330						
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	420	450	450	450						
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0			115		Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	398	397	360	400						
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	196	134	125	134						
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	332	331	300	330						
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	115				Under maint.	
14	Madangan-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	15	15						
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	16	92	16	92						
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	20	20	20						
17	Summit Power, Madhabdi-Ashulia	Gas (SIPP, REB)	6x3.67+3x8.73	80	80	40	36	40	40						
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	33	33						
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	30	26	32	32						
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	25	8	25						
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	35	88	35	88						
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	48	98	48	100						
23	Kamalaghat 54 MW PP (Barco Energy)	HFO (IPP)	3x18.69	54	54	0	54	17	54						
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	23	114	45	114						
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	135	17	149						
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	0	0						
27	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	5	55	35	55						
28	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	35	35						
29	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	52	17	53						
30	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	54	146	54	162						
31	Manikgonj 35MW Solar PP (Incepta Solar Ltd.)	Solar (IPP)	1x35	35	35	9	0	35	0						
32	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	17						
33	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	3	40	35	60						
34	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	0	25	17	25						
35	Madangan 102 PP(Summit)	HFO (NENP)	6x17	102	102	1	33	17	33						
36	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	11	0	11						
Dhaka Zone Total				5904	5722	2488	3149	2495	3219	201	490				
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	203	203	204	204						
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	119	120	120	120						
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180				Under maint.	
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	1	0	5	0						
40	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	25	8	25						
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	9	0	20	0						
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	3	6	6	33						
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	51	51	17	51						
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150				Under maint.	
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	228	226	225	225						
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	65	238	70	280						
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	50	25	50						
48	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	33	34	34						
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	25	65	17	75						
50	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	12	10	10	10						
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	26	25	25						
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	12	0	16						
52	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17						
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	55	55	51	51						
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	25	25	50						
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRRP)	8x13.45	100	100	25	46	46	46						
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	34	34	34						
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	0	58	17	144						
	SS Power Unit-1	Coal				0	0	0	0						
	Matarbari 2*600 MW (CPGCL)	Coal				280	255	300	300					Test run	
	Cox's Bazar Wind PP	(Wind) (IPP)				0	7	22	22						
Chattogram Zone Total				2605	2545	1162	1562	1298	1812	0	330				
58	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	0	0	0	0	45				Gas Shortage	
59	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	162	186	190	200						
60	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	240	240	240	240	120				Gas Shortage	
61	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	280	270	280	280	90				Gas Shortage	
62	Ashuganj 420 MW CCPP(East)	Gas (APSCL)	1x284+1x116	400	400	240	230	230	230	170				Gas Shortage	
63	Ashuganj 195MW PP (APSC-United)	Gas (IPP)	20*9.73+1*116	195	195	8	8	0	0	187				Gas Shortage	
64	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	51	51						
65	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	6	40	6	30						
66	Titlas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	48	40	48						
67	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163				Under maint.	
68	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	71	155	68	155						
69	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	17	20	22						
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	11	11						
71	Jangalia 33 MW PP (Summit))	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33						
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	8	8	8						
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	20	20	20						
74	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	17	17						
75	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	28	9	28						
76	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	35						
77	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	66	115	72	115						
**	Import (Tripura)	India		160	160	134	140	146	163						
Cumilla Zone Total				2904	2896	1363	1616	1458	1686	612	163				
78	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	30	52	45	70	150				Gas Shortage	
79	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	15	16	16	16						
80	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	18	84	18	85						
81	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	68	87	68	88						
82	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	0	0	1.6	0						

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	13.08.23 (Yesterday)		14.08.23 (Today)		13.08.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)		
85	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.	
86	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	31	31	42	42		59	GT-4 Under maint.	
87	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	47	50	50	50				
88	Kushiera 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	112	112		54	ST Under maint.	
89	Hobigari 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	5	11	11				
90	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	25	20	20	20				
91	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
92	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	78	86	80	86				
93	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	181	182	180	180				
94	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	17	17	17	17				
95	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10				
96	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	24	24	24	24				
97	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	295	280	290	290				
98	Bibiya-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	341	367	400	400				
99	Bibiya South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	360	360	360	360				
100	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
101	Fenchuganji 44MW (Energyprima)	Gas (NENP)	12*3.4+5*2	50	50	50	50	45	50				
Sylhet Zone Total						2472	2427	1624	1637	1684	1695	0	570
102	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
103	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	110	105	225	225	305		Gas Shortage	
104	Fairdipor 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	37	0	40				
105	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	30	40	51				
106	Khulna 225 MW CAPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	150				
107	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	17	17	17				
108	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	15	32	15	105				
109	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	33	0	100	0				
110	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	16	16	16	16				
111	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	8	8				
112	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	0	0	0	0	617		Coal Shortage	
113	Khulna 330 MW CAPP (GT)	Gas/HSD (BPDB)	1x220	220	220	0	0	0	0				
**	Bheramara (HVDC)	India		1000	1000	915	893	933	933				
Khulna Zone Total						3125	3121	1089	1130	1354	1545	922	0
114	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	16	80				
115	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	21	27	22	30				
116	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	132	92	80	132				
117	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	1244	1230	1244	1244				
118	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	5	150	17	150				
119	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	0	0	0	0	307		Coal Shortage	
120	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	205	183	220	220				
Barishal Zone Total						2265	2265	1607	1698	1599	1856	307	0
121	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
122	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Under maint.	
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	28	0	35				
124	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
125	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	24	0	30				
126	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	48	50	90				
127	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	21	30	35				
128	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	16	8	34				
129	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	16	0	30				
130	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage	
131	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	140	140	140	140			HSD	
132	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	140	142	150	150	78		Gas Shortage	
133	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	300	394	350	350	20		Gas Shortage	
134	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	0	0	0	0	0				
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8				
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	0	8				
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	25	55	35	55				
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	11	50	35	50				
139	Ammura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	28	28	28				
139	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	0	0	6	0				
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	1208	1317	1200	1300				
Rajshahi Zone Total						3675	3631	1832	2295	2040	2343	379	100
140	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
141	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling	
141	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	220	210	180	210	64		Coal Shortage	
142	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
143	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	32	49	35	55				
144	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
145	Majpara, Taldia 9 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 9	9	8	2	0	8	0				
146	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	74	35	113				
147	Lalmorhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	13	0	30	0				
148	Teesa Solar Limited	Solar (IPP)	1 x 200	200	200	42	0	130	0				
Rangpur Zone Total						1030	950	309	333	418	378	149	85
Sub-total: Plants in operation						24602	24171	11620.0	13665	12551	14799	2720	1738
(B) Plants under long term maintenance/ contract expired													
149	Jamailpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
150	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
151	Bosilia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
152	Ashugani 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	0	0	0	0				
Sub-Total: Plants under long term maintenance/ contract expired						309	0	0	0	0	0	0	0
Gross Total						24911	24171	11620	13665	12551	14799	2720	1738
(C) Actual data of 13.08.23 (Yesterday) Sunday :													
01.	Max. Demand at eve. peak (Generation end)	:	13665 MW, at =	19:30 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :								
02.	Max. Demand at eve. peak (Sub-station end)	:	12904 MW, at =	19:30 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW	
03.	Highest Generation (Generation end)	:	13665 MW, at =	19:30 hrs	Dhaka	4673	4673	0	Mymensingh	1042	1042	0	
04.	Minimum Generation (Generation end)	:	10524 MW, at =	7:00 hrs	Chattogram	1195	1195	0	Sylhet	541	541	0	
05.	Day-peak Generation (Generation end)	:	11620 MW, at =	12:00 hrs	Khulna	1632	1632	0	Barishal	406	406	0	
06.	Evening-peak Generation (Generation end)	:	13665 MW, at =	19:30 hrs	Rajshahi	1326	1326	0	Rangpur	882	882	0	
07.	Evening Peak Load-shed (Sub-station end)	:	0 MW, at =	19:30 hrs	Cumilla	1206	1206	0					
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10599 MW, at =	5:00 hrs									
09.	Generation shortfall at evening peak due to :	:											
a)	Gas/LF limitation	:	2571 MW										
b)	Coal supply Limitation	:	149 MW										
c)	Low water level in Kaptai lake	:	0 MW										
d)	Plants under shut down/ maintenance	:	1738 MW										
10.	Total Energy (Generation + India Import)	:	286.64 MMkWh										
	By Gas = 146.355 MKWH	By Oil =	39.493 MKWH										
	By Coal = 69.992 MKWH	By Hydro =	4.808 MKWH										
	By Solar= 1.216 MKWH												
11.	Total Gas Supplied	:	1146.31 MMCFD										
(D) Forecast of 14.08.23 (Today) Monday :													
01.	Maximum Demand	:	14300 MW (Generation end)		04.	Maximum Load-shed	:	0 MW	At evening peak (Sub-station end)				
02.	Maximum Generation	:	14799 MW (Generation end)		05.	Total Generation	:	299.97 MKWh					
03.	Reserve / Shortage	:	499 MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	:	31.9° C					

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation