

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564657, 9551095

Month August, 2023				Day : Wednesday				Date : 16.08.23					
Probable Maximum Demand : 14800 MW				Probable Maximum Generation : 15469 MW									
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 102.08 ft		Today = 102.08 ft		Rule Curve = 93.80 ft					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	15.08.23 (Yesterday)		16.08.23 (Today)		15.08.23 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)	Probable Peak Generation (MW)	Probable Peak Generation (MW)	Gen. shortfall for : Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date		
												Day	Evening
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work		
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	150	220	150	150				
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180				
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0				
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	12	12	12	12	96	Gas Shortage		
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage		
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0				
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	302	337	300	330				
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	420	450	450	450				
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling		
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	404	383	360	400				
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	124	184	125	180				
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	280	324	300	330				
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	115	Under maint.		
14	Madangan-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	15	15				
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	8	48	102				
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	20	20	20				
17	Summit Power, Madhabdi-Ashulia	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	38	41	40	40				
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	16	33	33				
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	23	32	32	32				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	25	8	25				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	50	35	88				
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	16	32	64				
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	17	17	35				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	15	65	145				
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	71	149	70	149				
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	0	0				
27	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	17	35	55				
28	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	17	35	35				
29	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	51	90	34	55				
30	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	35	54	162				
31	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	11	0	35	0				
32	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	33	17	17				
33	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	8	80	80				
34	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	0	48	8	33				
35	Madangan 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	34	17	30				
36	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	0	60	60				
Dhaka Zone Total			5904	5722	2200	2776	2667	3307	201	490			
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	157	199	195	195				
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	120	120	120	120				
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.		
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	6	0	5	0				
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	25	8	25				
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	5	0	20	0				
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	6	6	47				
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	51	51	51	51				
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.		
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	221	226	225	225				
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	69	282	70	280				
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	0	50	25	50				
48	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	32	34	34	34				
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	25	25	25				
50	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	9	9	10	10				
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			36	42	30	35				
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	12	0	12				
52	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	20	17	17				
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	55	55	55	55				
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	50	25	50				
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRRP)	8x13.45	100	100	0	46	35	46				
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	34	34	34				
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	0	52	142	142				
	SS Power Unit-1	Coal				0	0	0	0				
	Matarbari 2*600 MW (CPGCL)	Coal				301	242	300	300		Test run		
	Cox's Bazar Wind PP	(Wind) (IPP)				0	0	22	22				
Chattogram Zone Total			2605	2545	1127	1580	1454	1775	0	330			
58	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	0	20	5	5	25	Gas Shortage		
59	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	205	204	170	200				
60	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	240	270	270	270	90	Gas Shortage		
61	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	270	280	280	280	80	Gas Shortage		
62	Ashuganj 420 MW CCPP(East)	Gas (APSCL)	1x284+1x116	400	400	230	230	240	240	170	Gas Shortage		
63	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	0	0	0	0	195	Gas Shortage		
64	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	34	51	51	51				
65	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	6	50	5	50				
66	Titlas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	36	43	47	47				
67	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under maint.		
68	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	68	155	68	155				
69	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	15	13	20	22				
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	11	11				
71	Jangalia 33 MW PP (Summit))	Gas (SIPP, PDB)	4x8.73	33	33	25	33	33	33				
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	0	0	0				
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	20	20	20				
74	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	17	34	17				
75	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	28	9	28				
76	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17				
77	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	72	115	72	115				
**	Import (Tirupura)	India		160	160	144	158	146	163				
Cumilla Zone Total			2904	2896	1418	1714	1498	1724	560	163			
78	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	98	152	130	150	50	Gas Shortage		
79	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	13	16	16	16				
80	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	67	87	68	85				
81	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	18	83	18	88				
82	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0				
83	Sulakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	39	0	50	0				
84	Tangail 22 MW PP(PPLG)	HFO (IPP)	4x6.7	22	22	6	6	6	6				
Mymensingh Zone Total			622	614	243	344	290	345	50	0			

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	15.08.23 (Yesterday)		16.08.23 (Today)		15.08.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)		
85	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.	
86	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	40	42	42		50	GT-4 Under maint.	
87	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	50	47	50	50				
88	Kushiera 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	80	112	112	112		54	ST Under maint.	
89	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
90	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	20	40	50	50				
91	Shajibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
92	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	78	86	86	86				
93	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	181	181	180	180				
94	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	17	17	17	17				
95	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
96	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	24	24	24	24				
97	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	280	300	300				
98	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	366	367	400	400				
99	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	360	360	360	360				
100	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
101	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.4+5*2	50	50	46	46	46	46				
Sylhet Zone Total						2472	2427	1618	1664	1731	1731	0	561
102	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
103	Bheramara 410 MW CCPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	195	325	325	325		85	Gas Shortage	
104	Fairdipor 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	24	0	40				
105	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	12	40	51				
106	Khulna 225 MW CCPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	150				
107	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	17	17	17				
108	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	15	32	15	105				
109	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	92	0	100	0				
110	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	49	16	48				
111	Nopara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	16	8	8				
112	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	378	377	370	370		240	Coal Shortage	
113	Khulna 330 MW CCPP (GT)	Gas/HSD (BFDDB)	1x220	220	220	0	0	0	0				
**	Bheramara (HVDC)	India		1000	1000	909	859	911	911				
Khulna Zone Total						3125	3121	1606	1711	1802	2025	325	0
114	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	16	110				
115	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	8	32	22	30				
116	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	130	124	130	132				
117	Payra 1320 MW TTP	Coal (BCPCL)	2x622	1244	1244	900	1244	1244	1244				
118	Potukhalhi 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	17	17	150				
119	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	0	0	0	0		307	Coal Shortage	
120	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	184	220	220	220				
Barishal Zone Total						2265	2265	1239	1637	1649	1886	307	0
121	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.	
122	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	28	0	35				
123	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
124	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	20	0	30				
125	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	92	50	90				
126	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	15	30	35				
127	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	8	34				
128	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	22	0	30				
129	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	0	0	0	0		210	Gas Shortage	
130	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	0	0	0	0			HSD	
131	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	170	140	200	200		80	Gas Shortage	
132	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	360	392	400	400		22	Gas Shortage	
133	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	0	0	0	0	0				
134	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8				
135	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	0	8				
136	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	55	35	57				
137	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	50	35	50				
138	Ammura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	28	28				
139	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	3	0	0	6	0				
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	1124	1209	1200	1300				
Rajshahi Zone Total						3675	3631	1665	2039	2000	2305	383	100
140	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
141	Barapukuria 275 MW TTP Unit-3	Coal (PDB)	1 x 274	274	274	180	200	200	200		74	Coal Shortage	
142	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
143	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	30	41	35	56				
144	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
145	Majma. Talsia 9 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 9	9	8	7	0	8	0				
146	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6*20	119	115	0	75	35	115				
147	Lalmoharhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	33	0	30	0				
148	Teesa Solar Limited	Solar (IPP)	1 x 200	200	200	110	0	130	0				
Rangpur Zone Total						1030	950	360	316	438	371	159	85
Sub-total: Plants in operation						24602	24171	11476.0	13781	13529	15469	1985	1729
(B) Plants under long term maintenance/ contract expired													
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
150	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
151	Bosilia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
152	Ashugani 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	0	0	0	0				
Sub-Total: Plants under long term maintenance/ contract expired						309	0	0	0	0	0	0	0
Gross Total						24911	24171	11476	13781	13529	15469	1985	1729
(C) Actual data of 15.08.23 (Yesterday) Tuesday :													
01.	Max. Demand at eve. peak (Generation end)	:	13904 MW, at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :								
02.	Max. Demand at eve. peak (Sub-station end)	:	13238 MW, at =	21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW	
03.	Highest Generation (Generation end)	:	13781 MW, at =	21:00 hrs	Dhaka	4322	4322	0	Mymensingh	1190	1170	20	
04.	Minimum Generation (Generation end)	:	10791 MW, at =	9:00 hrs	Chattogram	1212	1212	0	Sylhet	583	583	0	
05.	Day-peak Generation (Generation end)	:	11476 MW, at =	12:00 hrs	Khulna	1666	1666	0	Barishal	449	449	0	
06.	Evening-peak Generation (Generation end)	:	13781 MW, at =	21:00 hrs	Rajshahi	1502	1502	0	Rangpur	979	882	97	
07.	Evening Peak Load-shed (Sub-station end)	:	117 MW, at =	21:00 hrs	Cumilla	1336	1336	0					
08.	Minimum Generation Forecast up to 8:00 hrs.	:	11437 MW, at =	5:00 hrs					Total	13238	13121	117	
09.	Generation shortfall at evening peak due to :	:											
	a) Gas/LF limitation	:	1826 MW										
	d) Coal supply Limitation	:	159 MW										
	b) Low water level in Kaptai lake	:	0 MW										
	c) Plants under shut down/ maintenance	:	1729 MW										
10.	Total Energy (Generation + India Import)	:	295.97 MMkWh										
	By Gas =	148.393 MKWH	By Oil =	38.445 MKWH									
	By Coal =	77.500 MKWH	By Hydro =	4.357 MKWH									
	By Solar=	2.290 MKWH											
11.	Total Gas Supplied	:	1166.50 MMCFD										
(D) Forecast of 16.08.23 (Today) Wednesday :													
01.	Maximum Demand	:	14800 MW (Generation end)		04.	Maximum Load-shed	:	0 MW	At evening peak (Sub-station end)				
02.	Maximum Generation	:	15469 MW (Generation end)		05.	Total Generation	:	317.85 MKWh					
03.	Reserve / Shortage	:	669 MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	:	34.4° C					

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md.