

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564657, 9551095

Month August, 2023				Day : Thursday				Date : 17.08.23					
Probable Maximum Demand : 14900 MW				Probable Maximum Generation : 14909 MW									
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 102.08 ft		Today = 102.09 ft		Rule Curve = 94.12 ft					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	16.08.23 (Yesterday)		17.08.23 (Today)		16.08.23 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)	Probable Peak Generation (MW)	Probable Peak Generation (MW)	Gen. shortfall for : Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date		
												Day	Evening
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work		
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	116	170	140	170				
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180				
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0				
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	12	12	12	12	96	Gas Shortage		
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage		
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0				
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	331	332	330	330				
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450				
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling		
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	400	404	400	400				
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	131	75	90	90				
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	318	318	330	330				
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	115	Under maint.		
14	Madangan-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	15	15				
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	24	42	16	74				
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	19	20	20				
17	Summit Power, (Madhabdi-Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	38	39	40	40				
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	0	33	33	33				
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	24	31	32	32				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	25	8	25				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	52	88	35	88				
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	32	64	16	64				
23	Kamalaghat 54 MW PP (Barco Energy)	HFO (IPP)	3x18.69	54	54	17	35	17	35				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	63	145	65	145				
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	75	149	70	149				
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	0	0				
27	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	55	35	55				
28	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	35	35				
29	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	27	54	34	55				
30	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	54	162	54	162				
31	Manikgonj 35MW Solar PP (Incepta Solar Ltd.)	Solar (IPP)	1x35	35	35	23	0	35	0				
32	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	17				
33	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	42	33	24	32				
34	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	9	9	8	16				
35	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	30	31	17	30				
36	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	46	56	60	60				
Dhaka Zone Total				5904	5722	2569	3078	2618	3144	201	490		
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	201	201	195	195				
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	113	115	120	120				
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.		
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	2	0	5	0				
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	16	8	25				
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	7	0	20	0				
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	46	6	47				
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	51	51	51	51				
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.		
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	222	222	225	225				
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	78	285	70	280				
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	50	25	50				
48	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	17	32	34	34				
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	16	42	40	40				
50	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	10	10	10	10				
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	26	5	25				
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	11	0	12				
52	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17				
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	55	55	55	55				
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	50	25	50				
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRRP)	8x13.45	100	100	35	46	35	46				
56	Chattogram 116 MW PP (Anilma Energy Ltd.)	HFO (IPP)	6x21.06	116	116	27	51	34	51				
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	17	140	17	142				
	SS Power Unit-1	Coal (IPP)				0	0	0	0				
	Matarbari 2*600 MW (CPGCL)	Coal				129	0	0	0		Test run		
	Cox's Bazar Wind PP	(Wind) (IPP)				1	2	10	10				
Chattogram Zone Total				2605	2545	1064	1468	1007	1485	0	330		
58	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	5	5	5	5	40	Gas Shortage		
59	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	192	187	170	200				
60	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	240	240	270	270	120	Gas Shortage		
61	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	270	280	280	280	80	Gas Shortage		
62	Ashuganj 420 MW CCPP(East)	Gas (APSCL)	1x284+1x116	400	400	240	240	240	240	160	Gas Shortage		
63	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	0	0	0	0	195	Gas Shortage		
64	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51				
65	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	5	87	6	150				
66	Tilas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	47	47	47	47				
67	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under maint.		
68	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	68	103	51	100				
69	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	13	15	20	22				
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	11	11				
71	Jangalia 33 MW PP (Summit))	Gas (SIPP, PDB)	4x8.73	33	33	0	25	33	33				
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	0	0	0				
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	20	20	20				
74	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	17	17	105				
75	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	28	9	28				
76	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17				
77	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	72	101	72	115				
**	Impoqri (Tripura)	India		160	160	148	130	146	163				
Cumilla Zone Total				2904	2896	1424	1603	1465	1857	595	163		
78	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	81	85	50	85	117	Gas Shortage		
79	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	16	16	16				
80	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	65	85	68	85				
81	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	18	83	18	88				
82	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0				
83	Sulakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	42	0	50	0				
84	Tangail 22 MW PP(PPLG)	HFO (IPP)	4x6.7	22	22	6	6	6	6				
Mymensingh Zone Total				622	614	230	275	210	280	117	0		

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	16.08.23 (Yesterday)		17.08.23 (Today)		16.08.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Machines shut down (MW)			
85	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43	27	GT-1 Under maint.	
86	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	40	40	42	42	50	GT-4 Under maint.	
87	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	50	50	50	50			
88	Kushiera 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	112	112	54	ST Under maint.	
89	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	5	11	11			
90	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	50	50	50	50			
91	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	330	Under maint.	
92	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	72	81	86	86			
93	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	181	178	180	180			
94	Sylhet 20 MW GTTP	Gas (PDB)	1x 20	20	20	17	17	17	17			
95	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10			
96	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	24	24	24	24			
97	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	290	300	300			
98	Bibiana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	0	232	280	280			
99	Bibiana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	340	350	360	360			
100	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0	100	Under project work	
101	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.4+5*2	50	50	43	46	46	46			
Sylhet Zone Total					2472	2427	1276	1528	1611	1611	0	561
102	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
103	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	280	260	290	290	150	Gas Shortage	
104	Fairdipor 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	21	0	40			
105	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	42	40	51			
106	Khulna 225 MW CAPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0			
107	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	17	17	17			
108	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	15	67	15	105			
109	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	59	0	100	0			
110	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	65	16	48			
111	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	16	8	8			
112	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	373	517	500	500	100	Coal Shortage	
113	Khulna 330 MW CAPP (GT)	Gas/HSD (BDFB)	1x220	220	220	50	50	0	0			
**	Bheramara (HVDC)	India		1000	1000	911	795	911	911			
Khulna Zone Total					3125	3121	1705	1850	1897	1970	250	0
114	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	110	16	110			
115	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	22	32	22	30			
116	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	124	130	130	132			
117	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	1244	1244	1244	1244			
118	Potukhalhi 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	150	17	150			
119	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	0	0	0	0	307	Coal Shortage	
120	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	221	220	220	220			
Barishal Zone Total					2265	2265	1644	1886	1649	1886	307	0
121	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage	
122	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Under maint.	
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	35	0	35			
124	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0			
125	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	16	0	30			
126	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	92	50	90			
127	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	23	30	35			
128	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	8	34			
129	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	23	0	30			
130	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210	Gas Shortage	
131	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0			
132	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	196	190	200	200			
133	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	414	0	400			
134	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	0	0	0	0	0			
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8			
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	8	8	8			
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	55	35	57			
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	50	35	50			
139	Ammura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	28	28	28	28			
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0			
**	Adani Power Jharkhand Ltd	(Import)	2x748	1496	1496	1311	1357	1200	1300			
Rajshahi Zone Total					3675	3631	2040	2299	1608	2305	281	100
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Coal Shortage	
142	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overhauling	
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	220	200	200	200	74	Coal Shortage	
144	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	34	49	35	56			
146	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
147	Mapara Taluk 9 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 9	9	9	7	0	8	0			
148	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6*20	119	115	0	75	35	115			
149	Lalmourihat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	29	0	30	0			
150	Teesa Solar Limited	Solar (IPP)	1 x 200	200	200	182	0	130	0			
Rangpur Zone Total					1030	950	472	324	438	371	159	85
Sub-total: Plants in operation					24602	24171	12424.0	14311	12503	14909	1910	1729
(B) Plants under long term maintenance/ contract expired												
151	Jamailpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			
152	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			
153	Bosilia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			
154	Ashugani 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	0	0	0	0			
Sub-Total: Plants under long term maintenance/ contract expired					309	0	0	0	0	0	0	0
Gross Total					24911	24171	12424	14311	12503	14909	1910	1729
(C) Actual data of 16.08.23 (Yesterday) Wednesday :												
01.	Max. Demand at eve. peak (Generation end)	:	14750 MW, at =	21:00 hrs	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	14047 MW, at =	21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	14311 MW, at =	21:00 hrs	Dhaka	4902	4902	0	Mymensingh	1201	1041	160
04.	Minimum Generation (Generation end)	:	11437 MW, at =	7:00 hrs	Chattogram	1347	1347	0	Sylhet	648	609	39
05.	Day-peak Generation (Generation end)	:	12424 MW, at =	12:00 hrs	Khulna	1736	1736	0	Barishal	473	473	0
06.	Evening-peak Generation (Generation end)	:	14311 MW, at =	21:00 hrs	Rajshahi	1509	1479	30	Rangpur	1001	901	100
07.	Evening Peak Load-shed (Sub-station end)	:	419 MW, at =	21:00 hrs	Cumilla	1230	1140	90				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	11389 MW, at =	5:00 hrs								
09.	Generation shortfall at evening peak due to :	:										
	a) Gas/LF limitation	:	1751 MW									
	d) Coal supply Limitation	:	159 MW									
	b) Low water level in Kaptai lake	:	0 MW									
	c) Plants under shut down/ maintenance	:	1729 MW									
10.	Total Energy (Generation + India Import)	:	304.13 MKWh									
	By Gas =	152.666 MKWH	By Oil =	42.578 MKWh								
	By Coal =	77.348 MKWH	By Hydro =	4.462 MKWh								
	By Solar=	2.177 MKWH										
11.	Total Gas Supplied	:	1155.58 MMCFD									
(D) Forecast of 17.08.23 (Today) Thursday :												
01.	Maximum Demand	:	14900 MW	(Generation end)	04.	Maximum Load-shed	:	0 MW	At evening peak (Sub-station end)			
02.	Maximum Generation	:	14909 MW	(Generation end)	05.	Total Generation	:	316.65 MKWh				
03.	Reserve / Shortage	:	9 MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	32° C				

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation