

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564657, 9551095

Month August, 2023					Day : Friday				Date : 18.08.23						
Probable Maximum Demand : 14300 MW					Probable Maximum Generation : 15312 MW				Rule Curve = 94.44 ft.						
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 102.09 ft		Today = 102.65 ft.								
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	17.08.23 (Yesterday)		18.08.23 (Today)		17.08.23 (Yesterday)		18.08.23 (Today)		Status of Machines under shut-down/ Maintenance	Probable start-up date	
					Actual Peak Generation (MW)	Probable Peak Generation (MW)	Gen. shortfall for : Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)	Description/ Remarks						
										Day	Evening	Day			Evening
(A) Plants in operation:															
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0			260	Under project work		
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	136	120	140	170						
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180						
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0						
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	12	12	12	12	96			Gas Shortage		
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105			Gas Shortage		
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0						
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	321	332	330	330						
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450						
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0			115	Under Overhauling		
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	395	390	400	400						
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	62	37	93	93						
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	316	318	330	330						
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0			115	Under maint.		
14	Madangan-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	15	15						
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	33	102	16	102						
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	20	20						
17	Summit Power, Madhabdi-Ashulia	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	37	38	40	40						
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33						
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	22	8	32	32						
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	24	8	25						
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	35	88	35	88						
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	32	16	64						
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	35	17	35						
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	65	148	65	145						
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	72	149	70	149						
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	0	0						
27	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	55	35	55						
28	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	35	35						
29	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	45	43	34	55						
30	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	54	162	54	162						
31	Manikgonj 35MW Solar PP (Spectra Solar Ltd.)	Solar (IPP)	1x35	35	35	31	0	35	0						
32	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	17						
33	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	25	38	24	38						
34	Meghnaghat 100 MW(EL)	HFO (NENP)	12x8.9	100	100	9	49	34	49						
35	Madangan 102 PP(Summit)	HFO (NENP)	6x17	102	102	17	51	17	51						
36	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	23	33	33	33						
Dhaka Zone Total				5904	5722	2481	2994	2620	3208	201	490				
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	167	211	211	211						
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	119	123	120	120			180	Under maint.		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0						
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	3	0	5	0						
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	0	8	25						
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	14	0	20	0						
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	40	6	47						
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	68	68	68	68						
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0			150	Under maint.		
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	218	224	225	225						
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	70	297	70	297						
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	50	25	50						
48	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	32	32	34	34						
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	32	59	40	59						
50	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	10	10	10	10						
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			6	33	42	30						
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	12	0	12						
52	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17						
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	41	55	55	55						
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	50	25	50						
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRRP)	8x13.45	100	100	35	46	35	46						
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	34	51	34	51						
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	17	125	17	142						
	SS Power Unit-1	Coal (IPP)				0	0	0	0						
	Matarbari 2*600 MW (CPGCL)	Coal				0	0	0	0				Test run		
	Cox's Bazar Wind PP	(Wind) (IPP)				4	21	10	10						
Chattogram Zone Total				2605	2545	951	1524	1077	1559	0	330				
58	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	0	0	0	0	45			Gas Shortage		
59	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	170	188	170	200						
60	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	240	240	270	270	120			Gas Shortage		
61	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	290	270	280	280	90			Gas Shortage		
62	Ashuganj 420 MW CCPP(East)	Gas (APSCL)	1x284+1x116	400	400	240	230	240	240	170			Gas Shortage		
63	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*116	195	195	0	0	0	0	195			Gas Shortage		
64	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51						
65	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	8	135	6	150						
66	Titlas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	32	38	47	47						
67	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0			163	Under maint.		
68	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	51	103	51	100						
69	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	13	14	20	22						
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	11	11						
71	Jangalia 33 MW PP (Summit))	Gas (SIPP, PDB)	4x8.73	33	33	25	25	33	33						
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	0	0	0						
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	17	20	20						
74	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	106	17	105						
75	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	29	9	28						
76	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17						
77	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	72	96	72	115						
**	Import (Tripura)	India		160	160	124	106	146	163						
Cumilla Zone Total				2904	2896	1389	1675	1460	1852	620	163				
78	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	46	85	65	85	117			Gas Shortage		
79	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	16	16	16						
80	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	71	84	68	85						
81	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	18	147	95	142						
82	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0						
83	Suliakhali 50 MW Solar PP	Solar (IPP)	1x50	50	50	46	0	50	0						
84	Tangail 22 MW PP(PDGL)	HFO (IPP)	4x6.7	22	22	6	6	6	6						
Mymensingh Zone Total				622	614	205	338	302	334	117	0				

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	17.08.23 (Yesterday)		18.08.23 (Today)		17.08.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening				
85	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.	
86	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	39	40	42	42		50	GT-4 Under maint.	
87	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)		51	51	50	50	50	50				
88	Kushiera 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	112	112		54	ST Under maint.	
89	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	3	11	11				
90	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	48	55	50	50				
91	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
92	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	82	86	86	86				
93	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	179	181	180	180				
94	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	17	17	17	17				
95	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
96	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	24	24	24	24				
97	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	300	300	300				
98	Bibiyana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	260	80	350	350				
99	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	350	350	360	360				
100	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
101	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.4+5*2	50	50	40	45	46	46				
Sylhet Zone Total						2472	2427	1559	1396	1681	1681	0	561
102	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
103	Bheramara 410 MW CAPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	300	210	290	290		200	Gas Shortage	
104	Fairdipor 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	5	21	0	40				
105	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	18	37	40	51				
106	Khulna 225 MW CAPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	0				
107	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	17	35	35				
108	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	15	67	15	105				
109	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	87	0	100	0				
110	Khulna 115 MW PP (KPLCL-2)	HFO (NENP)	7x17	115	115	0	64	16	48				
111	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	8	8	8				
112	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	499	564	568	568				
113	Khulna 330 MW CAPP (GT)	Gas/HSD (B/PDB)	1x220	220	220	100	150	0	0				
**	Bheramara (HVDC)	India		1000	1000	912	794	911	911				
Khulna Zone Total						3125	3121	1936	1932	1983	2056	200	0
114	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	32	110	16	110				
115	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	23	33	22	30				
116	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	126	130	130	132				
117	Payra 1320 MW TTP	Coal (BCPCL)	2x622	1244	1244	1244	1244	1244	1244				
118	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	150	17	150				
119	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	0	0	0	0		307	Coal Shortage	
120	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	217	222	220	220				
Barishal Zone Total						2265	2265	1659	1889	1649	1886	307	0
121	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage	
122	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.	
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	28	0	35				
124	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
125	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	26	0	30				
126	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	22	92	50	90				
127	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	25	30	35				
128	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	8	34				
129	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	23	0	30				
130	Sirajgonj 225MW CAPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	0	0	0	0		210	Gas Shortage	
131	Sirajgonj 225MW CAPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	0	0	0	0		220	Gas Shortage	
132	Sirajgonj 225MW CAPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	208	194	200	200				
133	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	0	414	360	400				
134	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	0	0	0	0	0				
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8				
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	8	8	8				
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	35	35	57				
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	50	35	50				
139	Ammura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	28	28	28	28				
139	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	3	0	6	0				
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	1291	1362	1200	1360				
Rajshahi Zone Total						3675	3631	1638	2293	1968	2365	501	100
140	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage	
141	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
141	Barapukuria 275 MW TTP Unit-3	Coal (PDB)	1 x 274	274	274	220	220	200	200		54	Coal Shortage	
142	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
143	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	34	56	35	56				
144	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
145	Majma. Talsia 9 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 9	9	8	7	0	8	0				
146	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	75	35	115				
147	Lalmoharhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	36	0	30	0				
148	Teesa Solar Limited	Solar (IPP)	1 x 200	200	200	194	0	130	0				
Rangpur Zone Total						1030	950	491	351	438	371	139	85
Sub-total: Plants in operation						24602	24171	12309.0	14392	13178	15312	2085	1729
(B) Plants under long term maintenance/ contract expired													
149	Jamelpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
150	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
151	Bosilia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
152	Ashugani 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	0	0	0	0				
Sub-Total: Plants under long term maintenance/ contract expired						309	0	0	0	0	0	0	0
Gross Total						24911	24171	12309	14392	13178	15312	2085	1729
(C) Actual data of 17.08.23 (Yesterday) Thursday :													
01.	Max. Demand at eve. peak (Generation end)	:	14847 MW, at =	21:00 hrs	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :								
02.	Max. Demand at eve. peak (Sub-station end)	:	14253 MW, at =	21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW	
03.	Highest Generation (Generation end)	:	14392 MW, at =	21:00 hrs	Dhaka	5018	4973	45	Mymensingh	1215	1101	114	
04.	Minimum Generation (Generation end)	:	11389 MW, at =	8:00 hrs	Chattogram	1304	1304	0	Sylhet	602	592	10	
05.	Day-peak Generation (Generation end)	:	12309 MW, at =	12:00 hrs	Khulna	1754	1744	10	Barishal	478	478	0	
06.	Evening-peak Generation (Generation end)	:	14392 MW, at =	21:00 hrs	Rajshahi	1562	1517	45	Rangpur	967	867	100	
07.	Evening Peak Load-shed (Sub-station end)	:	437 MW, at =	21:00 hrs	Cumilla	1354	1241	113					
08.	Minimum Generation Forecast up to 8:00 hrs.	:	11235 MW, at =	5:00 hrs					Total	14253	13816	437	
09.	Generation shortfall at evening peak due to :	:											
	a) Gas/LF limitation	:	1946 MW										
	d) Coal supply Limitation	:	139 MW										
	b) Low water level in Kaptai lake	:	0 MW										
	c) Plants under shut down/ maintenance	:	1729 MW										
10.	Total Energy (Generation + India Import)	:	299.33 MKWh										
	By Gas =	143.239 MKWh	By Oil =	45.160 MKWh									
	By Coal =	79.618 MKWh	By Hydro =	4.299 MKWh									
	By Solar =	2.771 MKWh											
11.	Total Gas Supplied	:	1122.10 MMCFD										
(D) Forecast of 18.08.23 (Today) Friday :													
01.	Maximum Demand	:	14300 MW (Generation end)		04.	Maximum Load-shed	:	0 MW	At evening peak (Sub-station end)				
02.	Maximum Generation	:	15312 MW (Generation end)		05.	Total Generation	:	297.41 MKWh					
03.	Reserve / Shortage	:	1012 MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	:	35.8° C					

#Remarks: Highest Generation 15648 MW