

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564657, 9551095

Month August, 2023				Day : Saturday				Date : 19.08.23						
Probable Maximum Demand : 14400 MW				Probable Maximum Generation : 15001 MW										
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 102.65 ft		Today = 102.82 ft		Rule Curve = 94.76 ft						
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	18.08.23 (Yesterday)		19.08.23 (Today)		18.08.23 (Yesterday)		19.08.23 (Today)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Machines shut down (MW)		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening						
(A) Plants in operation:														
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260		Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	150	170	140	170					
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180					
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0					
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	12	12	12	12	96			Gas Shortage	
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105			Gas Shortage	
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0					
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	332	336	330	330					
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	420	450	450	450					
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115		Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	372	396	0	0					
11	Siddhirganj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	94	62	90	65					
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	313	319	330	330					
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	115			Under maint.	
14	Madangan-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	15	15					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	58	25	102					
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	19	19	19					
17	Summit Power, Madhabdi-Ashulia	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	36	40	40	40					
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25					
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	31	33	33					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	12	8	25					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	88	35	88					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	32	16	48					
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	35	17	35					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	147	65	145					
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	35	110	70	149					
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	0	0					
27	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	5	55	35	55					
28	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	35	35	35					
29	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	53	71	34	55					
30	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	162	54	162					
31	Manikganj 35MW Solar PP (Incepta Solar Ltd.)	Solar (IPP)	1x35	35	35	36	0	35	0					
32	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	17					
33	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	20	60	70					
34	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	15	11	34	72					
35	Madangan 102 PP(Summit)	HFO (NENP)	6x17	102	102	5	51	17	51					
36	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	18	24	24					
Dhaka Zone Total				5904	5722	2225	2977	2245	2802	201	490			
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	203	200	200	200					
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	117	116	120	120					
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180			Under maint.	
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	1	0	5	0					
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	17	8	25					
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	13	0	20	0					
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	6	6	47					
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	34	34	68	68					
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150			Under maint.	
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	219	220	225	225					
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	66	177	70	297					
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	50	25	50					
48	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	32	34	34					
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	32	23	34	50					
50	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	10	10	10	10					
*	Malancha, Cig EPZ (United)	Gas	5x8.73+3x9.34			32	42	10	25					
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	12	0	12					
52	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17					
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	55	55	55	55					
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	50	25	50					
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRRP)	8x13.45	100	100	35	46	35	46					
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	34	34	51					
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	0	108	17	142					
	SS Power Unit-1	Coal				0	0	0	0					
	Matarbari 2*600 MW (CPGCL)	Coal				0	0	100	400				Test run	
	Cox's Bazar Wind PP	(Wind) (IPP)				12	12	10	10					
Chattogram Zone Total				2605	2545	927	1261	1128	1934	0	330			
58	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	0	0	0	0	45			Gas Shortage	
59	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	173	178	170	200					
60	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	240	270	270	270	90			Gas Shortage	
61	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	270	270	270	270	90			Gas Shortage	
62	Ashuganj 420 MW CCPP(East)	Gas (APSCL)	1x284+1x116	400	400	230	230	230	230	170			Gas Shortage	
63	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	0	0	0	0	195			Gas Shortage	
64	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	20	51	51	51					
65	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	5	147	6	150					
66	Titlas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	24	23	47	47					
67	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163			Under maint.	
68	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	51	100	51	100					
69	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	14	14	20	22					
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	10	11	11					
71	Jangalia 33 MW PP (Summit))	Gas (SIPP, PDB)	4x8.73	33	33	25	25	33	33					
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	0	0	0					
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	17	17	17	17					
74	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	52	106	17	105					
75	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	10	29	9	28					
76	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17					
77	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	74	92	72	115					
**	Impoort (Tirupura)	India		160	160	118	142	146	163					
Cumilla Zone Total				2904	2896	1348	1721	1437	1829	590	163			
78	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	58	102	105	105	100			Gas Shortage	
79	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	16	16	16					
80	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	66	82	68	85					
81	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	56	162	95	150					
82	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	0	0	1.6	0					
83	Sulakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	28	0	50	0					
84	Tangail 22 MW PP(PPLGL)	HFO (IPP)	4x6.7	22	22	6	6	6	6					
Mymensinghym														

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	18.08.23 (Yesterday)		19.08.23 (Today)		18.08.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening				
85	Fenchuganj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43	27	GT-1 Under maint.	
86	Fenchuganj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	39	40	42	42	50	GT-4 Under maint.	
87	Fenchuganj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	22	50	50	50			
88	Kushiera 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	80	112	112	112	54	ST Under maint.	
89	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	8	8	11			
90	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	40	55	50	50			
91	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	330	Under maint.	
92	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	78	84	86	86			
93	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	179	179	180	180			
94	Sylhet 20 MW GTTP	Gas (PDB)	1x 20	20	20	0	0	0	0			
95	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10			
96	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	24	24	24	24			
97	Bibiya-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	310	300	300			
98	Bibiya-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	319	347	350	350			
99	Bibiya South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	350	350	360	360			
100	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0	100	Under project work	
101	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.4+5*2	50	50	25	36	46	46			
Sylhet Zone Total					2472	2427	1510	1648	1661	1664	0	561
102	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
103	Bheramara 410 MW CAPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	95	70	105	105	340	Gas Shortage	
104	Fairdipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	40			
105	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	53	40	51			
106	Khulna 225 MW CAPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	0			
107	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	53	35	53			
108	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	67	15	105			
109	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	55	0	100	0			
110	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	81	16	48			
111	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	8	8	8			
112	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	568	505	400	400			
113	Khulna 330 MW CAPP (GT)	Gas/HSD (PDB)	1x220	220	220	0	0	0	220			
**	Bheramara (HVDC)	India		1000	1000	912	795	909	909			
Khulna Zone Total					3125	3121	1630	1632	1628	1939	340	0
114	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	48	16	110			
115	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	17	29	22	30			
116	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	130	130	130	132			
117	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	1030	1244	1244	1244			
118	Potukhalhi 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	17	150			
119	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	0	0	0	0	307	Coal Shortage	
120	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	221	220	220			
Barishal Zone Total					2265	2265	1397	1672	1649	1886	307	0
121	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage	
122	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Under maint.	
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	35	0	35			
124	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0			
125	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	24	0	30			
126	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	48	92	50	90			
127	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	38	30	35			
128	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	0			
129	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	24	0	30			
130	Sirajganj 225MW CAPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	0	0	0	0	210	Gas Shortage	
131	Sirajganj 225MW CAPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	0	0	0	0	220	Gas Shortage	
132	Sirajganj 225MW CAPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	148	149	150	155	71	Gas Shortage	
133	Sirajganj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	300	414	414	414			
134	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	0	0	0	0			
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8			
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	8	8			
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	55	35	55			
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	50	35	57			
139	Amnura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	0	0			
140	Sirajganj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	4	0	6	0			
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	1216	1311	1200	1360			
Rajshahi Zone Total					3675	3631	1724	2208	1936	2277	572	100
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Coal Shortage	
142	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overhauling	
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	220	180	180	180	94	Coal Shortage	
144	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	26	63	35	56			
146	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
147	Majma. Talsia 9 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 9	9	9	7	0	8	0			
148	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6*20	119	115	0	75	0	72			
149	Lalmourihat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	38	0	30	0			
150	Teesa Solar Limited	Solar (IPP)	1 x 200	200	200	171	0	130	0			
Rangpur Zone Total					1030	950	462	318	383	308	179	85
Sub-total: Plants in operation					24602	24171	11453.0	13805	12409	15001	2289	1729
(B) Plants under long term maintenance/ contract expired												
151	Jamailpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			
152	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			
153	Bosilia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			
154	Ashugani 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	0	0	0	0			
Sub-Total: Plants under long term maintenance/ contract expired					309	0	0	0	0	0	0	0
Gross Total					24911	24171	11453	13805	12409	15001	2289	1729
(C) Actual data of 18.08.23 (Yesterday) Friday :												
01.	Max. Demand at eve. peak (Generation end)	:	13957 MW, at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	13347 MW, at =	21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	13937 MW, at =	22:00 hrs	Dhaka	4439	4439	0	Mymensingh	1230	1151	79
04.	Minimum Generation (Generation end)	:	10810 MW, at =	9:00 hrs	Chattogram	1277	1277	0	Sylhet	612	612	0
05.	Day-peak Generation (Generation end)	:	11453 MW, at =	12:00 hrs	Khulna	1665	1665	0	Barishal	434	434	0
06.	Evening-peak Generation (Generation end)	:	13805 MW, at =	21:00 hrs	Rajshahi	1448	1448	0	Rangpur	958	931	27
07.	Evening Peak Load-shed (Sub-station end)	:	145 MW, at =	21:00 hrs	Cumilla	1284	1245	39				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	11068 MW, at =	5:00 hrs					Total	13347	13202	145
09.	Generation shortfall at evening peak due to :	:			13.	Fuel cost :	(a) Gas = 161109050 Taka (b) Oil = 503991895 Taka	(c) Coal = 298265729 Taka Total = 963448574 Taka				
	a) Gas/LF limitation	:	2110 MW									
	d) Coal supply Limitation	:	179 MW									
	b) Low water level in Kaptai lake	:	0 MW									
	c) Plants under shut down/ maintenance	:	1729 MW									
10.	Total Energy (Generation + India Import)	:	293.95 MKWh		14.	Maximum Temperature in Dhaka was :	34.4° C					
	By Gas = 146.169 MKWh	By Oil =	38.909 MKWh		15.	Export through East-West interconnections :						
	By Coal = 78.119 MKWh	By Hydro =	4.783 MKWh			At evening peak-hour	:	11453 MW, at	21:00 hrs			
	By Solar= 2.797 MKWh					Maximum	:	580 MW, at	19:00 hrs			
						Energy	:	0 MKWh				
11.	Total Gas Supplied	:	1119.53 MMCFD									
(D) Forecast of 19.08.23 (Today) Saturday :												
01.	Maximum Demand	:	14400 MW (Generation end)		04.	Maximum Load-shed	:	0 MW	At evening peak (Sub-station end)			
02.	Maximum Generation	:	15001 MW (Generation end)		05.	Total Generation	:	303.72 MKWh				
03.	Reserve / Shortage	:	601 MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	34.4° C					

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation