

Bangladesh Power Development Board
DAY1 ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564657, 9551095

Month August, 2023						Day : Monday				Date : 21.08.23					
Probable Maximum Demand :				15500 MW		Probable Maximum Generation :				14799 MW					
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 102.98 ft		Today = 102.99 ft.				Rule Curve = 95.40 ft.					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	20.08.23 (Yesterday)		21.08.23 (Today)		20.08.23 (Yesterday)		21.08.23 (Today)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Machines shut down (MW)		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW						
(A) Plants in operation:															
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0			260		Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	140	150	150	150						
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180						
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0						
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108				Gas Shortage	
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105				Gas Shortage	
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0						
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	327	333	330	330						
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450						
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0			115		Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	279	281	380	400						
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	115	120	100	120						
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	306	317	330	330						
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	115				Under maint.	
14	Madangan-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	25	15	15						
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	66	75	66	102						
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	16	18	19	19						
17	Summit Power, Madhabdi-Ashulia	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	37	43	40	40						
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33						
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	32	33	33	33						
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	25	8	25						
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	35	88	35	88						
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	48	98	48	98						
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	35	17	35						
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	65	197	132	200						
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	70	132	70	132						
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	0	0						
27	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	5	55	35	55						
28	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	35	35						
29	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	69	72	53	70						
30	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	90	72	54	108						
31	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	27	0	35	0						
32	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	11	31	17	17						
33	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	64	32	60	86						
34	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	61	41	74	74						
35	Madangan 102 PP(Summit)	HFO (NENP)	6x17	102	102	3	51	17	34						
36	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	0	0	55						
Dhaka Zone Total				5904	5722	2604	3022	2816	3314	213	490				
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	203	204	200	200						
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	115	115	120	120						
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180				Under maint.	
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0						
40	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	17	8	25						
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	20	0	20	0						
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	39	6	47						
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	34	51	51	51						
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150				Under maint.	
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	218	225	225	225						
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	103	300	100	300						
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	37	25	25	25						
48	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	0	0	0						
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	33	65	34	65						
50	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	10	10	10	10						
*	Malancha, Cig EPZ (United)	Gas	5x8.73+3x9.34			9	32	10	25						
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	11	0	12						
52	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17						
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	55	55	55	55						
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	38	25	25	25						
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRRP)	8x13.45	100	100	35	35	35	35						
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	37	51	34	51						
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	17	142	17	143						
	SS Power Unit-1	Coal (IPP)				0	0	0	0						
	Matarbari 2*600 MW (CPGCL)	Coal				0	300	0	0					Test run	
	Cox's Bazar Wind PP	(Wind) (IPP)				1	0	10	10						
Chattogram Zone Total				2605	2545	994	1719	1007	1441	0	330				
58	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	0	0	0	0	45				Gas Shortage	
59	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	175	197	180	190						
60	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	240	240	240	240	120				Gas Shortage	
61	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	280	270	270	280	90				Gas Shortage	
62	Ashuganj 420 MW CCPP(East)	Gas (APSCL)	1x284+1x116	400	400	230	230	230	230	170				Gas Shortage	
63	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	0	0	0	0	195				Gas Shortage	
64	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51						
65	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	5	31	6	30						
66	Tilas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	23	47	47						
67	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163				Under maint.	
68	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	109	104	51	100						
69	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	16	16	16						
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	11	11						
71	Jangalia 33 MW PP (Summit))	Gas (SIPP, PDB)	4x8.73	33	33	25	25	25	25						
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	43	43	43						
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	17	20	19	19						
74	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	52	106	106	106						
75	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	12	29	9	30						
76	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17						
77	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	72	114	72	115						
**	Import (Tripura)	India		160	160	132	144	146	163						
Cumilla Zone Total				2904	2896	1443	1670	1539	1713	620	163				
78	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	33	79	32	80	123				Gas Shortage	
79	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	16	16	16						
80	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	38	74	24	85						
81	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	116	171	115	165						
82	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2									

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	20.08.23 (Yesterday)		21.08.23 (Today)		20.08.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening				
85	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	42	43	43	43		27	GT-1 Under maint.	
86	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	40	40	40	40		50	GT-4 Under maint.	
87	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	46	50	50	50				
88	Kushiera 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	112	112		54	ST Under maint.	
89	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	5	5	5				
90	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	52	51	60	60				
91	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
92	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	72	84	86	86				
93	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	181	113	113	113				
94	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	17	17	17				
95	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
96	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	24	24	24	24				
97	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	310	300	300				
98	Bibiya-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	392	367	350	370				
99	Bibiya South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	350	350	350	350				
100	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
101	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.4+5*2	50	50	42	43	42	42				
Sylhet Zone Total						2472	2427	1658	1619	1602	1622	0	561
102	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
103	Bheramara 410 MW CAPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	0	0	0	0		410	Gas Shortage	
104	Fairdipor 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	5	25	0	40				
105	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	14	53	40	52				
106	Khulna 225 MW CAPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	0				
107	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	29	17	17	17				
108	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	15	15	15	50				
109	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	43	0	100	0				
110	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	16	16	16	16				
111	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	8	8				
112	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	400	503	400	500				
113	Khulna 330 MW CAPP (GT)	Gas/HSD (BPDB)	1x220	220	220	230	232	0	230				
**	Bheramara (HVDC)	India		1000	1000	904	793	909	909				
Khulna Zone Total						3125	3121	1656	1654	1505	1622	410	0
114	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	48	110	16	110				
115	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	20	33	22	30				
116	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	123	130	130	132				
117	Payra 1320 MW TTP	Coal (BCPCL)	2x622	1244	1244	1244	1244	1244	1244				
118	Potukhalhi 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	35	150	35	150				
119	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	0	0	0	0		307	Coal Shortage	
120	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	222	220	220	220				
Barishal Zone Total						2265	2265	1692	1887	1667	1886	307	0
121	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage	
122	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.	
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	28	0	35				
124	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
125	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	18	0	20				
126	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	48	91	50	92				
127	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	39	30	40				
128	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	0				
129	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	5	24	0	24				
130	Sirajgonj 225MW CAPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	0	0	0	0		210	Gas Shortage	
131	Sirajgonj 225MW CAPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	0	0	0	0		220	Gas Shortage	
132	Sirajgonj 225MW CAPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	208	208	180	200				
133	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	414	414	414				
134	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	0	0	0	0	0				
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8				
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	52	8	40				
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	55	35	55				
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	50	35	50				
139	Amnura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	0	0				
139	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	5	0	6	0				
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	1314	1408	1300	1360				
Rajshahi Zone Total						3675	3631	2080	2395	2066	2338	501	100
140	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage	
141	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
141	Barapukuria 275 MW TTP Unit-3	Coal (PDB)	1 x 274	274	274	230	210	180	180		64	Coal Shortage	
142	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	13	0	0				
143	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	34	41	35	56				
144	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
145	Majmaera, Talsia 9 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 9	9	8	2	0	8	0				
146	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	75	0	75				
147	Lalmoharhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	32	0	30	0				
148	Teesa Solar Limited	Solar (IPP)	1 x 200	200	200	90	0	130	0				
Rangpur Zone Total						1030	950	388	339	383	311	149	85
Sub-total: Plants in operation						24602	24171	12738.0	14651	12830	14799	2323	1729
(B) Plants under long term maintenance/ contract expired													
149	Jamailpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
150	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
151	Bosilia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
152	Ashugani 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	0	0	0	0				
Sub-Total: Plants under long term maintenance/ contract expired						309	0	0	0	0	0	0	0
Gross Total						24911	24171	12738	14651	12830	14799	2323	1729
(C) Actual data of 20.08.23 (Yesterday) Sunday :													
01.	Max. Demand at eve. peak (Generation end)	:	15200 MW, at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :								
02.	Max. Demand at eve. peak (Sub-station end)	:	14424 MW, at =	21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW	
03.	Highest Generation (Generation end)	:	14651 MW, at =	21:00 hrs	Dhaka	5085	5075	10	Mymensingh	1233	1083	150	
04.	Minimum Generation (Generation end)	:	11564 MW, at =	9:00 hrs	Chattogram	1337	1337	0	Sylhet	619	599	20	
05.	Day-peak Generation (Generation end)	:	12738 MW, at =	12:00 hrs	Khulna	1786	1711	75	Barishal	478	478	0	
06.	Evening-peak Generation (Generation end)	:	14651 MW, at =	21:00 hrs	Rajshahi	1558	1488	70	Rangpur	963	843	120	
07.	Evening Peak Load-shed (Sub-station end)	:	524 MW, at =	21:00 hrs	Cumilla	1365	1286	79					
08.	Minimum Generation Forecast up to 8:00 hrs.	:	11506 MW, at =	5:00 hrs									
09.	Generation shortfall at evening peak due to :	:											
a)	Gas/LF limitation	:	2174 MW										
c)	Coal supply Limitation	:	149 MW										
b)	Low water level in Kaptai lake	:	0 MW										
c)	Plants under shut down/ maintenance	:	1729 MW										
10.	Total Energy (Generation + India Import)	:	308.60 MMkWh										
	By Gas =	145.360 MKWH	By Oil =	48.359 MKWH									
	By Coal =	83.039 MKWH	By Hydro =	4.595 MKWH									
	By Solar=	2.747 MKWH											
11.	Total Gas Supplied	:	1136.48 MMCFD										
(D) Forecast of 21.08.23 (Today) Monday :													
01.	Maximum Demand	:	15500 MW (Generation end)		04.	Maximum Load-shed	:	670 MW (Generation end)	At evening peak (Sub-station end)				
02.	Maximum Generation	:	14799 MW (Generation end)		05.	Total Generation	:	326.48 MKWh (Generation end)					
03.	Reserve / Shortage	:	-701 MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	:	35.0° C					

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation