

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564657, 9551095

Month August, 2023				Day : Tuesday				Date : 22.08.23				
Probable Maximum Demand : 15500 MW				Probable Maximum Generation : 14760 MW								
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 102.99 ft		Today = 102.81 ft		Rule Curve = 95.72 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	21.08.23 (Yesterday)		22.08.23 (Today)		21.08.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)	Probable Peak Generation (MW)	Probable Peak Generation (MW)	Gen. shortfall for : Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)			
										Day		Evening
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	150	126	150	150	108	Gas Shortage	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	100	100	100			
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0			
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	12	12	108	Gas Shortage	
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage	
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	332	332	330	330			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450			
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	371	407	380	400			
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	64	59	100	100	151	Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	312	317	330	330			
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	115	Under maint.	
14	Madangan-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	15	30			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	50	92	64	102			
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	19	19	19			
17	Summit Power, Madhabdi-Ashulia	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	42	42	40	40			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	31	33	33	33			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	25	8	25			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	35	88	35	88			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	48	147	48	100			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	35	17	35			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	130	197	130	198			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	71	135	70	135			
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	0	0			
27	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	5	55	35	55			
28	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	35	35			
29	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	53	72	53	70			
30	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	54	108	54	108			
31	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	25	0	35	0			
32	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	17			
33	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	65	60	70	70			
34	Meghnaghat 100 MW(EL)	HFO (NENP)	12x8.9	100	100	49	83	74	74			
35	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	17	17	17	51			
36	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	22	12	55			
Dhaka Zone Total			5904	5722	2659	3201	2766	3245	364	490		
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	202	201	200	200			
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	115	119	120	120	180	Under maint.	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0			
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	2	0	5	0			
40	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	17	8	25			
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	5	0	20	0			
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	39	6	47			
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	51	37	51	51			
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	214	227	225	225			
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	105	300	66	300			
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	25	25	25			
48	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	0	0	0			
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	24	73	34	65			
50	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	10	10	10	10			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			3	27	5	25			
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	12	0	12			
52	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17			
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	68	64	55	55			
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	25	25	25			
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRRP)	8x13.45	100	100	25	35	35	35			
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	34	51	34	51			
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	17	142	17	143			
	SS Power Unit-1	Coal (IPP)				0	0	0	0			
	Matarbari 2*600 MW (CPGCL)	Coal				233	300	180	180		Test run	
	Cox's Bazar Wind PP	(Wind) (IPP)				0	0	10	10			
Chattogram Zone Total			2605	2545	1189	1721	1148	1621	0	330		
58	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	0	0	0	45		Gas Shortage	
59	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	177	204	180	190			
60	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	240	240	240	240	120	Gas Shortage	
61	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	270	270	270	270	90	Gas Shortage	
62	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	230	240	230	230	160	Gas Shortage	
63	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	0	0	0	0	195	Gas Shortage	
64	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51			
65	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	5	30	5	30			
66	Titlas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	47	47	47	47			
67	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under maint.	
68	Chandpur 200MW (Desh energy)	HFO (IPP)	12x16.415	200	200	51	86	51	85			
69	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	15	12	16	16			
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	11	11			
71	Jangalia 33 MW PP (Summit))	Gas (SIPP, PDB)	4x8.73	33	33	25	25	25	25			
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	42	43	43	43			
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	20	19	19			
74	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	52	106	17	106			
75	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	28	9	30			
76	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17			
77	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	72	114	72	115			
**	Importo (Tripura)	India		160	160	126	148	146	163			
Cumilla Zone Total			2904	2896	1459	1691	1449	1688	610	163		
78	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	33	74	32	80	128	Gas Shortage	
79	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	16	16	16			
80	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	28	92	24	85			
81	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	115	153	115	165			
82	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
83	Sulakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	37	0	50	0			
84	Tangail 22 MW PP(PPLGL)	HFO (IPP)	4x6.7	22	22	6	6	6	6			
Mymensingh Zone Total			622	614	237	341	245	352	128	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	21.08.23 (Yesterday)		22.08.23 (Today)		21.08.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)		
85	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.	
86	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	40	39	40	40		51	GT-4 Under maint.	
87	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	44	50	50	50				
88	Kushiera 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	112	112		54	ST Under maint.	
89	Hobigunj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	5	5	5				
90	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	40	56	60	60				
91	Shajibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
92	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	75	85	86	86				
93	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	113	113	113	113				
94	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	17	17	17	17				
95	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
96	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	24	24	24				
97	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	285	300	300				
98	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	400	368	350	370				
99	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	350	330	350	350				
100	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
101	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.4+5*2	50	50	43	46	42	42				
Sylhet Zone Total						2472	2427	1600	1583	1602	1622	0	562
102	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
103	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0		410	Gas Shortage	
104	Fairdipor 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	9	21	0	40				
105	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	20	60	40	52				
106	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0				
107	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	17	17	17				
108	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	15	15	15	50				
109	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	98	0	100	0				
110	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	15	16	16	16				
111	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	8	8	8				
112	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	400	571	400	500				
113	Khulna 330 MW CCPP (GT)	Gas/HSD (BFD)	1x220	220	220	125	105	120	120				
**	Bheramara (HVDC)	India		1000	1000	909	786	909	909				
Khulna Zone Total						3125	3121	1608	1599	1625	1712	410	0
114	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	32	110	16	110				
115	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	23	34	22	30				
116	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	120	130	130	132				
117	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	1244	1244	1244	1244				
118	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	35	150	35	150				
119	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	0	0	0	0		307	Coal Shortage	
120	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	222	207	220	220				
Barishal Zone Total						2265	2265	1676	1875	1667	1886	307	0
121	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage	
122	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.	
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	28	0	35				
124	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
125	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	16	0	20				
126	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	91	50	92				
127	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	38	30	40				
128	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	0				
129	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	24	24	0	24				
130	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0		210	Gas Shortage	
131	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0		220	Gas Shortage	
132	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	190	208	180	200				
133	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	350	414	414	414				
134	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	0	0	0	0	0				
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8				
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	25	8	25				
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	55	35	55				
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	40	35	50				
139	Amnura 50 MW PPS(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	0	0				
139	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	2	0	6	0				
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	1359	1414	1300	1360				
Rajshahi Zone Total						3675	3631	2011	2361	2066	2323	501	100
140	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage	
141	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
141	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	220	200	180	180		74	Coal Shortage	
142	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
143	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	34	55	35	56				
144	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
145	Majma. Taluk 9 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 9	9	9	4	0	8	0				
146	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	74	0	75				
147	Lalmoharhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	9	0	30	0				
148	Teesa Solar Limited	Solar (IPP)	1 x 200	200	200	80	0	130	0				
Rangpur Zone Total						1030	950	347	329	383	311	159	85
Sub-total: Plants in operation						24602	24171	12786.0	14701	12951	14760	2479	1730
(B) Plants under long term maintenance/ contract expired													
149	Jamailpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
150	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
151	Bosilia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
152	Ashugani 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	0	0	0	0				
Sub-Total: Plants under long term maintenance/ contract expired						309	0	0	0	0	0	0	0
Gross Total						24911	24171	12786	14701	12951	14760	2479	1730
(C) Actual data of 21.08.23 (Yesterday) Monday :													
01.	Max. Demand at eve. peak (Generation end)	:	15360 MW, at =	21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	14582 MW, at =	21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW	
03.	Highest Generation (Generation end)	:	14701 MW, at =	21:00 hrs	Dhaka	5176	5141	35	Mymensingh	1202	1112	90	
04.	Minimum Generation (Generation end)	:	11506 MW, at =	8:00 hrs	Chattogram	1315	1280	35	Sylhet	610	565	45	
05.	Day-peak Generation (Generation end)	:	12786 MW, at =	12:00 hrs	Khulna	1820	1736	84	Barishal	491	491	0	
06.	Evening-peak Generation (Generation end)	:	14701 MW, at =	21:00 hrs	Rajshahi	1586	1476	110	Rangpur	970	860	110	
07.	Evening Peak Load-shed (Sub-station end)	:	629 MW, at =	21:00 hrs	Cumilla	1412	1292	120					
08.	Minimum Generation Forecast up to 8:00 hrs.	:	11931 MW, at =	5:00 hrs									
09.	Generation shortfall at evening peak due to :	:											
a)	Gas/LF limitation	:	2320 MW										
d)	Coal supply Limitation	:	159 MW										
b)	Low water level in Kaptai lake	:	0 MW										
c)	Plants under shut down/ maintenance	:	1730 MW										
10.	Total Energy (Generation + India Import)	:	309.71 MKWh										
	By Gas = 144.071 MKWh		By Oil = 48.418 MKWh										
	By Coal = 85.571 MKWh		By Hydro = 4.703 MKWh										
	By Solar= 2.364 MKWh												
11.	Total Gas Supplied	:	1134.47 MMCFD										
(D) Forecast of 22.08.23 (Today) Tuesday :													
01.	Maximum Demand	:	15500 MW (Generation end)		04.	Maximum Load-shed	:	682 MW	At evening peak (Sub-station end)				
02.	Maximum Generation	:	14760 MW (Generation end)		05.	Total Generation	:	326.54 MKWh					
03.	Reserve / Shortage	:	-740 MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	:	34.5° C					

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation